

Series PM172 Powermeters

Modbus Communications Protocol

Reference Guide

Every effort has been made to ensure that the material herein is complete and accurate. However, the manufacturer is not responsible for any mistakes in printing or faulty instructions contained in this book. Notification of any errors or misprints will be received with appreciation.

For further information regarding a particular installation, operation or maintenance of equipment, contact the manufacturer or your local representative or distributor.

This document is applicable to the devices with firmware versions 13.XX and 15.XX (PM172P/E), and 14.XX and 16.XX (PM172EH).

Revision History

Rev.A2 (firmware versions 13.1.7, 14.1.7, 15.1.8, 16.1.9 and later)

1. Added GE EGD protocol setup (V13.1.7, 14.1.7)
2. Added 16-bit BC scaling option in the DNP Options setup

Rev.A3 (firmware versions 13.1.11, 14.1.11 and later)

1. Maximum CT primary current is increased to 20,000A.

Rev.A4 (PM172P/E, firmware versions 13.1.16 and later)

1. Added 16-bit and 32-bit frozen analog inputs and Time and Date object to the Class 0 point list.
2. Added 3-min power demand interval.
3. Added DST start/end hour setup.
4. Added the current unbalance trigger.

Rev.A5 (PM172P/E, firmware versions 13.1.19 and later, 13.71.12 and later)

1. Added transformer correction setup.
2. Added programmable starting current.

Modbus is a trademark of Schneider Electric.

Table of Contents

1 GENERAL	8
2 MODBUS PROTOCOL IMPLEMENTATION.....	9
2.1 TRANSMISSION MODES	9
2.2 ADDRESS FIELD.....	9
2.3 FUNCTION FIELD.....	9
2.4 EXCEPTION RESPONSES	9
2.5 MODBUS REGISTER ADDRESSES	9
2.6 DATA FORMATS	10
2.6.1 16-BIT SCALED INTEGER FORMAT	10
2.6.2 32-BIT LONG INTEGER FORMAT.....	11
2.6.3 32-BIT MODULO-10000 FORMAT	12
2.7 USER ASSIGNABLE REGISTERS.....	12
2.8 PASSWORD PROTECTION	12
2.9 DATA RECORDING AND FILE TRANSFERS	13
2.9.1 LOG FILE ORGANIZATION.....	13
Multi-section Files	13
Data Log Files.....	13
Profile Data Log Files.....	13
Waveform Log Files.....	14
2.9.2 FILE TRANSFERS	14
Common File Transfer	14
Reading a Profile Log File.....	15
Reading Waveform Files.....	15
Reading Real-time Waveforms	16
3 MODBUS REGISTER MAP	17
3.1 MODBUS SETUP REGISTERS	17
Modbus Assignable Registers.....	17
Assignable Registers Map	17
Modbus Conversion Scales	17
Device Data Scales.....	17
3.2 16-BIT SCALED ANALOG REGISTERS AND ENERGY COUNTERS - BASIC REGISTER SET	18
3.3 16-BIT SCALED ANALOG REGISTERS, BINARY REGISTERS AND COUNTERS.....	20
None	20
Special Inputs	20
Event Flags (bitmap) ^{EH}	20
Digital Inputs (bitmap)	20
Relay Outputs (bitmap)	20
Counters	20
1-Cycle Phase Values.....	20
1-Cycle Total Values.....	21
1-Cycle Auxiliary Values.....	21
Phasor.....	21
1-Second Phase Values.....	22
1-Second Total Values.....	22
1-Second Auxiliary Values	23
Present Harmonic Demands	23
Present Volt, Ampere and Power Demands.....	23
Total Energies ^E	24
Phase Energies ^E	24
V1/V12 Harmonic Distortions ^{EH}	24
V2/V23 Harmonic Distortions ^{EH}	25
V3/V31 Harmonic Distortions ^{EH}	25
I1 Harmonic Distortions ^{EH}	25
I2 Harmonic Distortions ^{EH}	25

I3 Harmonic Distortions ^{EH}	25
Fundamental (H01) Phase Values	25
Harmonic Total Values.....	26
Minimum 1-Cycle Phase Values	26
Minimum 1-Cycle Total Values.....	26
Minimum 1-Cycle Auxiliary Values	26
Maximum 1-Cycle Phase Values	27
Maximum 1-Cycle Total Values.....	27
Maximum 1-Cycle Auxiliary Values	27
Maximum Demands	27
Maximum Harmonic Demands	28
Scaled Analog Inputs	28
Raw Analog Inputs	28
TOU Parameters ^E	28
Scaled Analog Outputs	28
TOU Energy Register #1 ^E	28
TOU Energy Register #2 ^E	28
TOU Energy Register #3 ^E	29
TOU Energy Register #4 ^E	29
TOU Energy Register #5 ^E	29
TOU Energy Register #6 ^E	29
TOU Energy Register #7 ^E	29
TOU Energy Register #8 ^E	29
Summary Energy Accumulated Demands ^E	29
Summary Energy Block Demands ^E	29
Summary Energy Sliding Window Demands ^E	30
Summary Energy Maximum Demands ^E	30
TOU Maximum Demand Register #1 ^E	30
TOU Maximum Demand Register #2 ^E	30
TOU Maximum Demand Register #3 ^E	30
TOU Maximum Demand Register #4 ^E	30
TOU Maximum Demand Register #5 ^E	30
TOU Maximum Demand Register #6 ^E	30
TOU Maximum Demand Register #7 ^E	31
TOU Maximum Demand Register #8 ^E	31
V1/V12 Harmonic Angles ^{EH}	31
V2/V23 Harmonic Angles ^{EH}	31
V1/V31 Harmonic Angles ^{EH}	31
I1 Harmonic Angles ^{EH}	31
I2 Harmonic Angles ^{EH}	31
I3 Harmonic Angles ^{EH}	31
Setpoint Status (bitmap).....	32
3.4 32-BIT ANALOG REGISTERS, BINARY REGISTERS AND COUNTERS	33
Special Inputs	33
Event Flags (bitmap) ^{EH}	33
Digital Inputs DI1-DI2 (bitmap)	33
Relay Outputs RO1-RO2 (bitmap)	33
Counters	33
1-Cycle Phase Values.....	33
1-Cycle Total Values.....	34
1-Cycle Auxiliary Values.....	34
Phasor.....	34
1-Second Phase Values.....	35
1-Second Total Values.....	35
1-Second Auxiliary Values	36
Present Harmonic Demands	36
Present Volt, Ampere and Power Demands.....	36
Total Energies ^E	37
Summary Energy Registers ^E	37
Phase Energies ^E	37
V1/V12 Harmonic Distortions ^{EH}	38
V2/V23 Harmonic Distortions ^{EH}	38
V3/V31 Harmonic Distortions ^{EH}	38

I1 Harmonic Distortions ^{EH}	38
I2 Harmonic Distortions ^{EH}	38
I3 Harmonic Distortions ^{EH}	38
Fundamental (H01) Phase Values	38
Harmonic Total Values.....	39
Minimum 1-Cycle Phase Values	39
Minimum 1-Cycle Total Values.....	39
Minimum 1-Cycle Auxiliary Values	40
Maximum 1-Cycle Phase Values	40
Maximum 1-Cycle Total Values.....	40
Maximum 1-Cycle Auxiliary Values	40
Maximum Demands	40
Maximum Harmonic Demands	41
Scaled Analog Inputs	41
Raw Analog Inputs	41
TOU Parameters ^E	41
Scaled Analog Outputs	41
TOU Energy Register #1 ^E	41
TOU Energy Register #2 ^E	42
TOU Energy Register #3 ^E	42
TOU Energy Register #4 ^E	42
TOU Energy Register #5 ^E	42
TOU Energy Register #6 ^E	42
TOU Energy Register #7 ^E	42
TOU Energy Register #8 ^E	42
Summary Energy Accumulated Demands ^E	42
Summary Energy Block Demands ^E	43
Summary Energy Sliding Window Demands ^E	43
Summary Energy Maximum Demands ^E	43
TOU Maximum Demand Register #1 ^E	43
TOU Maximum Demand Register #2 ^E	43
TOU Maximum Demand Register #3 ^E	43
TOU Maximum Demand Register #4 ^E	43
TOU Maximum Demand Register #5 ^E	43
TOU Maximum Demand Register #6 ^E	44
TOU Maximum Demand Register #7 ^E	44
TOU Maximum Demand Register #8 ^E	44
V1/V12 Harmonic Angles ^{EH}	44
V2/V23 Harmonic Angles ^{EH}	44
V1/V31 Harmonic Angles ^{EH}	44
I1 Harmonic Angles ^{EH}	44
I2 Harmonic Angles ^{EH}	44
I3 Harmonic Angles ^{EH}	45
Generic TOU Season Energy Registers ID's ^E	45
Generic TOU Season Maximum Demand Registers ID's ^E	45
Setpoint Status SP1-SP16 (bitmap)	45
3.5 MINIMUM/MAXIMUM LOG REGISTERS	46
Minimum Phase Values	46
Minimum Total Values.....	46
Minimum Auxiliary Values	47
Maximum Phase Values	47
Maximum Total Values.....	48
Maximum Auxiliary Values	48
Summary Energy Maximum Demands ^E	48
Maximum Demands	48
Maximum Harmonic Demands	49
TOU Maximum Demand Register #1 ^E	50
TOU Maximum Demand Register #2 ^E	50
TOU Maximum Demand Register #3 ^E	50
TOU Maximum Demand Register #4 ^E	50
TOU Maximum Demand Register #5 ^E	50
TOU Maximum Demand Register #6 ^E	51
TOU Maximum Demand Register #7 ^E	51

TOU Maximum Demand Register #8 ^E	51
3.6 DEVICE CONTROL AND STATUS REGISTERS	52
Device Restart Register	52
Device Authorization Registers	52
Event Flags Control ^{EH}	52
Remote Relay Control	52
Device Reset/Clear Registers	52
Device Identification	53
Device Status Registers.....	53
Log Notification Registers ^E	53
Alarm Notification Registers.....	53
3.7 DEVICE SETUP REGISTERS	55
Device Identification	55
Factory Device Settings	55
Basic Setup	55
Communication Ports Setup	56
Device Options Setup	57
Local Settings	57
Clock Indication and Setup	58
Alarm/Event Setpoints Setup	58
Data Log Setup ^E	59
Pulse Counters Setup	60
Analog Outputs Setup	60
Analog Expander Setup	60
Digital Inputs Setup	61
Periodic Timers Setup ^E	61
File Setup ^E	61
Network Setup.....	61
Password Setup	62
Expert Power Service Setup	62
Internet Service Provider (ISP) accounts	62
Transformer Correction Setup.....	62
EGD Producer Exchanges Setup.....	62
DNP Options Setup.....	63
DNP Events Setup	64
DNP Class 0 Point Assignments	64
Waveform Recorder Setup ^{EH}	64
TOU Daily Profile Setup ^E	65
TOU Calendar Setup ^E	65
Summary Energy/TOU Registers Setup ^E	66
Summary Energy/TOU Registers Source Setup ^E	66
Digital Inputs Setup	67
Relay Outputs Setup	67
Analog Inputs Setup.....	67
Analog Outputs Setup	67
3.8 ANALOG AND DIGITAL I/O CONFIGURATION	68
I/O Slots Configuration Info	68
I/O Type Info	68
3.9 FILE TRANSFER REGISTERS ^E	69
File Allocation Status Registers.....	69
File Transfer Control/Status Registers	69
Event Log File Transfer Registers.....	71
Data Log File Transfer Registers	71
Waveform Header Transfer Registers ^{EH}	73
Waveform Series Transfer Block ^{EH}	74
4 DATA SCALES AND UNITS	75
Data Scales.....	75
Data Units	75
5 DATA FORMATS	76
Timestamp	76

Wiring Mode	76
File Attributes	76
File Status Word	76
File Record Status Word	76
File Allocation Map	76
Profile Log Sections Map	76
Waveform Log Channel Mask	76
TOU Tariff Change Time	76
Summary/TOU Energy Register Source ID	77
Setpoint Trigger Parameters ID	77
Pulse Inputs	77
Relays	77
Setpoint Action ID	79
Counter Source ID	80
Relay Output Pulse Source ID ^E	80
AO/Analog Expander Output Parameters ID	80
Event Cause/Point ID	80
Event Effect ID	81
Data Point ID	81
Device Diagnostics	82
DNP Object Types	82
DNP Class 0 Objects	83
Log Notification Status	83
Data Log Notification Status	83
Instrument Options	83
I/O Slot Types	83

1 General

This document specifies a subset of the Modbus serial communications protocol used to transfer data between a master computer station and the PM172. The document provides the complete information necessary to develop third-party communications software capable of communication with the Series PM172 instruments. Additional information concerning communications operation, configuring the communications parameters, and communications connections is found in "Series PM172 Powermeters, Installation and Operation Manual".

IMPORTANT

1. In 3-wire connection schemes, the unbalanced current and phase readings for power factor, active power, and reactive power will be zeros, because they have no meaning. Only the total three-phase power values will be shown.
2. Most of the advanced features are configured using multiple setup parameters that can be accessed in a number of contiguous registers. When writing the setup registers, it is recommended to write all the registers at once using a single request, or to clear (zero) the setup before writing into separate registers.

Designations used in the guide:

- E - available in the meters with the E and EH suffixes
- EH - available in the meters with the EH suffix

2 Modbus Protocol Implementation

For detailed information about Modbus protocol, Modbus message framing and error checking, refer to the "Modicon Modbus Protocol Reference Guide". It can be downloaded from the www.modbus.org Website. The following paragraphs outline some issues concerning the implementation of the Modbus protocol in the PM172.

2.1 Transmission Modes

The PM172 can be set up to communicate on a Modbus network using RTU transmission mode. Refer to the "Series PM172 Powermeters, Installation and Operation Manual" on how to select the transmission mode in your meter.

2.2 Address Field

The address field contains a user assigned address of the instrument (1-247) on a Modbus network. Broadcast mode using address 0 is not supported.

2.3 Function Field

The Modbus functions implemented in the PM172 are shown in Table 2-1. Function 04 can be used in the same context as function 03.

Table 2-1 Modbus Function Codes

Code (decimal)	Meaning in Modbus	Action
03	Read holding registers	Read multiple registers
04	Read input registers	Read multiple registers
06	Preset single register	Write single register
16	Preset multiple registers	Write multiple registers
08 ¹	Loop-back test	Communications test

¹ The PM172 supports only diagnostic code 0 - return query data.

2.4 Exception Responses

The instrument sends an exception response when an error is detected in the received message. To indicate that the response is notification of an error, the high order bit of the function code is set to 1. Implemented exception response codes:

- 01** - Illegal function
- 02** - Illegal data address
- 03** - Illegal data value
- 04** - Device failure

When the character framing, parity, or redundancy check detects a communication error, processing of the master's request stops. The instrument will not act on or respond to the message.

2.5 Modbus Register Addresses

The PM172 Modbus registers are numbered in the range of 0 to 65535. From the Modbus applications, the PM172 Modbus registers can be accessed by simulating holding registers of the Modicon 584, 884 or 984 Programmable Controller, using a 5-digit "4XXXX" or 6-digit "4XXXXX" addressing scheme. To map the PM172 register address to the range of the Modbus holding registers, add a value of 40001 to the PM172 register address. When a register address exceeds 9999, use a 6-digit addressing scheme by adding 400001 to the PM172 register address.

2.6 Data Formats

The PM172 uses three data formats to pass data between a master application and the instrument: 16-bit short integer, 32-bit long integer and 32-bit modulo-10000 formats. Binary values and counters are always transmitted in 32-bit registers, while analog values can be read both in 32-bit and in 16-bit scaled registers.

Analog registers 256 through 308 and 6656 through 10935 contain scaled 16-bit values.

2.6.1 16-bit Scaled Integer Format

16-bit scaled analog data is transmitted in a single 16-bit Modbus register being scaled to the range of 0 to 9999. To get a true reading, a reverse conversion should be done using the following formula:

$$Y = \frac{X \times (HI - LO)}{9999} + LO$$

where:

- Y - True reading in engineering units
- X - Raw input data in the range of 0 to 9999
- LO and HI - Data low and high scales in engineering units

The engineering scales are indicated for every scaled 16-bit register. Refer to Section 4 “Data Scales and Units” for applicable data scales and measurement units. The default voltage scale in the device is 144V (120V+20%). It can be changed through register 242 (see Section 3.1, Device Data Scales), or via the supplemental PAS software. The recommended voltage scale is 120V+20% = 144V for using with external PT’s, and 690V+20% = 828V for a direct connection to power line.

CONVERSION EXAMPLES

1. Voltage readings

a) Assume device settings (direct wiring): PT ratio = 1; Voltage scale = 828V (690V + 20%).

Voltage engineering scales (see Section 4):

$$\begin{aligned} HI_ENG &= V_{max} = 828.0 \times PT \text{ ratio} = 828.0 \times 1 = 828.0V \\ LO_ENG &= 0V \end{aligned}$$

If the raw data reading is 1449 then the voltage reading in engineering units will be as follows:

$$\text{Volts reading} = 1449 \times (828.0 - 0) / (9999 - 0) + 0 = 120.0V$$

b) Assume device settings (wiring via PT): PT ratio = 14,400V : 120V = 120; Voltage scale = 144V.

Voltage engineering scales (see Section 4):

$$\begin{aligned} HI_ENG &= V_{max} = 144.0 \times PT \text{ ratio} = 144 \times 120 = 17,280V \\ LO_ENG &= 0V \end{aligned}$$

If the raw data reading is 8314 then the voltage reading in engineering units will be as follows:

$$\text{Volts reading} = 8314 \times (17,280 - 0) / 9999 + 0 = 14,368V$$

2. Current readings

Assume device settings: CT primary current = 200A.

Current engineering scales (see Section 4):

$$\begin{aligned} HI_ENG &= I_{max} = CT \text{ primary current} \times 2 = 200.00 \times 2 = 400.00A \\ LO_ENG &= 0A \end{aligned}$$

If the raw data reading is 250 then the current reading in engineering units will be as follows:

$$\text{Amps reading} = 250 \times (400.00 - 0) / (9999 - 0) + 0 = 10.00A$$

3. Power readings

a) Assume device settings (direct wiring): Wiring 4LL3; PT = 1; CT primary current = 200A; Voltage scale = 828V.

Active Power engineering scales (see Section 4):

$$\begin{aligned} \text{HI_ENG} &= P_{\text{max}} = V_{\text{max}} \times I_{\text{max}} \times 2 = (828.0 \times 1) \times (200.00 \times 2) \times 2 = 662,400\text{W} = 662.400\text{kW} \\ \text{LO_ENG} &= -P_{\text{max}} = -662.400\text{kW} \end{aligned}$$

If the raw data reading is 5500 then the power reading in engineering units will be as follows:

$$\text{Watts reading} = 5500 \times (662.400 - (-662.400)) / (9999 - 0) + (-662.400) = 66.313\text{kW}$$

If the raw data reading is 500 then the power reading in engineering units will be as follows:

$$\text{Watts reading} = 500 \times (662.400 - (-662.400)) / (9999 - 0) + (-662.400) = -596.153\text{kW}$$

b) Assume device settings (wiring via PT): Wiring 4LN3; PT = 120; CT primary current = 200A.

Active Power engineering scales (see Section 4):

$$\begin{aligned} \text{HI_ENG} &= P_{\text{max}} = V_{\text{max}} \times I_{\text{max}} \times 3 = (828 \times 120) \times (200.00 \times 2) \times 3 / 1000 = 119,232\text{kW} \\ \text{LO_ENG} &= -P_{\text{max}} = -119,232\text{kW} \end{aligned}$$

If the raw data reading is 5500 then the power reading in engineering units will be as follows:

$$\text{Watts reading} = 5500 \times (119,232 - (-119,232)) / (9999 - 0) + (-119,232) = 11,936\text{kW}$$

If the raw data reading is 500 then the power reading in engineering units will be as follows:

$$\text{Watts reading} = 500 \times (119,232 - (-119,232)) / (9999 - 0) + (-119,232) = -107,307\text{kW}$$

4. Power Factor readings

Power factor engineering scales (see Section 3.3):

$$\begin{aligned} \text{HI_ENG} &= 1.000. \\ \text{LO_ENG} &= -1.000. \end{aligned}$$

If the raw data reading is 8900 then the power factor in engineering units will be as follows:

$$\text{Power factor reading} = 8900 \times (1.000 - (-1.000)) / (9999 - 0) + (-1.000) = 0.78$$

2.6.2 32-bit Long Integer Format

32-bit long integer data is transmitted in two adjacent 16-bit Modbus registers as unsigned (UINT32) or signed (INT32) whole numbers. The first register contains the low-order word (lower 16 bits) and the second register contains the high order word (higher 16 bits). The low-order word always starts at an even Modbus address. The value range for unsigned data is 0 to 4,294,967,295; for signed data the range is -2,147,483,648 to 2,147,483,647.

If your Modbus driver does not support a 32-bit long integer format, you can read the two 16-bit registers separately, and then convert them into a 32-bit value as follows (using C notation):

$$\text{32-bit value} = (\text{signed short})\text{high_order_register} \times 65536\text{L} + (\text{unsigned short})\text{low_order_register}$$

Examples

1. Unsigned 32-bit Values

If you read unsigned Voltage V1 of 69,000V from registers 13952-13953, then the register readings will be as follows:

$$\begin{aligned} (13952) &= 3464 \\ (13953) &= 1 \end{aligned}$$

The 32-bit value is $(1 \times 65536 + 3464) = 69000\text{V}$.

2. Signed 32-bit Values

If you read signed kW of -789kW from registers 14336-14337, then the register readings will be:

$$\begin{aligned} (14336) &= 64747 \text{ (unsigned)} \\ (14337) &= 65535 \text{ (unsigned) or } -1 \text{ (signed value)}. \end{aligned}$$

To take the high order register as a signed value, compare it with 32767. If the value is less or equal to 32767, use it as is. If it is greater than 32767, then this is a negative number in a two's complement code (like in our example) - just subtract it from 65536 to get the original negative value.

The 32-bit reading is $(-1 \times 65536 + 64747) = -789\text{kW}$.

Fractional 32-bit data is transmitted using a decimal pre-multiplier to pass fractional numbers in an integer format. Fractional numbers are pre-multiplied by 10^N , where N is the number of digits in the fractional part. For example, the frequency reading of 50.01 Hz is transmitted as 5001, having been pre-multiplied by 100. Whenever a data register contains a fractional number, the register measurement unit is given with a multiplier $\times 0.1$, $\times 0.01$ or $\times 0.001$, showing the weight of the least significant decimal digit. To get an actual fractional number with specified precision, multiply the register value by the given multiplier. To write a fractional number into the register, divide the number by the given multiplier.

2.6.3 32-bit Modulo-10000 Format

Energy counters 287-294 and 301-302 are read in two contiguous 16-bit registers in a modulo-10000 format. The first (low order) register contains the value mod 10000, and the second (high order) register contains the value/10000. To get the true energy reading, the high order register value should be multiplied by 10,000 and added to the low order register.

2.7 User Assignable Registers

The PM172 contains 120 user assignable registers in the address range of 0 to 119, any of which you can map to any register address accessible in the instrument. Registers that reside in different locations may be accessed by a single request by re-mapping them to adjacent addresses in the user assignable registers area.

The actual addresses of the assignable registers, which are accessed via addresses 0 through 119, are specified in the register map (registers 120 through 239), where register 120 contains the actual address of the register accessed via register 0, register 121 contains the actual address of the register accessed via register 1, and so on. The assignable registers and the map registers themselves may not be re-mapped.

To build your own register map, write to map registers 120 to 239 the actual addresses you want to read from or write to via the assignable area (registers 0 to 119). 32-bit long registers should always be aligned at even addresses. For example, if you want to read registers 7136 (1-second V1 voltage, scaled short integer) and 14720-14721 (kWh Import, long integer) via registers 0-2, do the following:

- write 14720 to register 120
- write 14721 to register 121
- write 7136 to register 122

Reading from registers 0-2 will return the kWh reading in registers 0 (low 16 bits) and 1 (high 16 bits), and the voltage reading in register 2.

2.8 Password Protection

The PM172 has a password protection option allowing you to protect your setups, cumulative registers and logs from being changed or cleared through communications. You can disable or enable password protection through communications or via the front display. For details, refer to your instrument Installation and Operation Manual. When password protection is enabled, the user password you set in your instrument should be written into the device authorization register (2575) before another write request is issued. If the correct password is not supplied while password protection is enabled, the instrument will respond to all write requests with the exception code 01 (illegal operation). It is recommended to clear the password register after you have completed your changes in order to activate password protection.

2.9 Data Recording and File Transfers

2.9.1 Log File Organization

Historical files are stored to the non-volatile memory with a battery backup. Memory is allocated for each file statically when you set up your files and will not change unless you re-organize the files. The PM172 automatically performs de-fragmentation of the memory each time you re-organize your files. This helps keep all free memory in one continuous chunk and thus prevents possible leakage of memory caused by fragmentation.

Data records in a file are arranged in the order of their recording. Each record has a unique 16-bit sequence number that is incremented modulo 65536 with each new record. The sequence number can be used to point to a particular record in the file, or to check the sequence of records when uploading files from the device.

Each file has a write position pointer that indicates the place where the next record will be recorded, and a read position pointer that indicates the place from where the current record will be read. Both pointers show sequence numbers of the records they point to rather than record offsets in the file.

After acknowledging a record you have read, the read pointer automatically advances to the next record in the file. When the read pointer gets to the record to which the file write pointer points, the end-of-file (EOF) flag is set. It is automatically cleared when a new record is added to the file, or when you explicitly move the read pointer to any record within a file.

If a file has a wrap-around attribute (circular file), the most recent records can overwrite the oldest records. When this happens at the current read position, the read pointer automatically advances forward in order to point to the oldest record in the file.

The PM172 keeps a separate read pointer for each communication port so that access to the same file through a different port will not affect current active sessions for other ports.

Multi-section Files

Log files can have one or more (up to 16) sections for multi-channel recording. An ordinal file consists of a single section. Some files, such as daily profile log files and waveform log files, are arranged as multi-section files.

A multi-section file is subdivided into multiple sections of the same structure, one section per recording channel. The number of sections in each file is defined at the time you set up your files and may not change unless you re-organize the file. Each section within a multi-section file can be addressed through a particular register window related to the section.

A multi-section file has a single write position pointer for all sections and stores data in all sections simultaneously. This means that records with the same sequence number in all sections are associated with the same event. A multi-section file has also a single read position pointer for all sections.

Data Log Files

Data log files can store up to 16 measured parameters per a record. Any data measured by the device can be stored in the log file. The number of parameters that each record will hold and the list of parameters you want to be recorded in the file can be selected through the Data log setup registers for a particular file.

Recording data to the data log files can be triggered through the setpoints, either on a time basis using the meter clock or periodic timers, or upon any event detected by the setpoints.

Profile Data Log Files

Data log file #8 can be configured to store a daily profile log of the energy/usage and maximum demand registers. A profile log file is organized as a multi-section file that has a separate section for each energy and maximum demand register. The number of sections is taken automatically from your Summary/TOU Registers setup. Since each Summary/TOU energy register has a shadow maximum demand register, the number of sections in the file can be twice the number of allocated

Summary/TOU registers. In order to correctly allocate the memory space for the profile log file, you should set up the Summary/TOU registers before you allocate memory for your profile log file.

A daily profile log file stores the daily summary (total of all tariffs) data and/or all tariff data for each configured Summary/TOU register. New records are added to the file automatically every day at midnight. You can review the list of parameters that are recorded to the file through the Data log #8 setup. It is preset automatically by the meter and shows the recorded data for the first file section, which represents the first configured energy/usage register.

Waveform Log Files

Waveform log files are organized as multi-section files that store data for each recording channel in a separate section. A waveform log file can record 6 AC channels simultaneously: three voltage and three current waveforms. The number of sections in a file, or channels that a file can store, is defined when you set up the file. The channels that a file will record are selected in the waveform log setup. All selected channels are recorded in successive file sections.

A waveform file has a single read pointer for all sections, so that data from all channels of a single record can be read together without repositioning the file pointer. When you point to a particular file record, data from all sections related to the same event are all available for a read. Moreover, the PM172 takes all channel data for the currently accessed record to a separate buffer, so that even when the record is overwritten at the time of reading, you are still prevented from receiving partially updated data.

A single waveform record for a channel can contain up to 512 points of the sampled input signal. Refer to the line frequency field in the channel header record to correctly set up the time scale for the waveforms.

If a waveform log is configured to record more samples per event than a single record can hold, the waveform recorder will store as many records per event as required to record the entire event. All waveform records related to the event are merged in a series and have the same series number, so that they can be plotted together. Each record within a series has a unique serial number that allows tracking the sequence of records in a series. A single waveform series can hold up to 81,920 points (2,560 cycles at a rate of 32 samples per cycle) of a sampled AC signal.

2.9.2 File Transfers

File transfer protocol provides both data transfer and information services. File transfer is performed through blocks of registers separate for each file and file section. File transfer control registers allow changing the file or section position in order to point to the desired record.

The information service uses separate status/control registers for each file. The extended file information is available including current file pointers' positions, the number of records in the file, allocated file size, and more.

Common File Transfer

Log files can be read either in a sequence record-by-record, or in a random order. Each read request fills the corresponding register block with the data of the record pointed to by the file (or section) read pointer. If you want to begin reading a file from a particular record, which sequence number is known, you can change the pointer position by writing the desired sequence number into the file transfer control register. If you want to read a file from the beginning, you can simply write a corresponding command to the file command register that moves the pointer to the oldest file record. If you do not change the file position, then you will continue reading the file from the record following the one you have read the last time you accessed the file.

You need not explicitly move the file position to the following record if you want to continue reading a file in a sequence after you have uploaded the current record. Instead, continue reading the file through the file transfer block.

For the event log files, the file transfer block can contain up to 12 records that can be read at once: the file position automatically moves to the record following the last one you have just read in the file transfer block.

The file transfer is completed after you have read the last record of the file. Before storing a file record to your database, always check bit 1 in the record status word, which contains the end-of-file (EOF) flag. This bit set to 1 indicates that the file read pointer does not point to any record within the file, and you should not store any record that has this bit set. The EOF flag is set only after you have read the last record of the file, so that testing for end-of-file requires one extra read. If you wish to stop the transfer just after storing the last file record, check bit 0 in the record status word. Bit 0 is set to 1 only once when you read the last record of the file.

The following gives a summary of steps you should do to read an ordinal log file:

- 1) If you want to begin reading a file from a particular record or from the first record, either set the file position to the desired record sequence number, or preset the file position to point to oldest record.
- 2) Read the record data through the corresponding file transfer block. The file pointer will be automatically moved to the next file record.
- 3) Repeat steps 1-2 until all the file records are read, i.e., until either bit 0 or bit 1 is set in the record status word.

Reading a Profile Log File

Reading a multi-section profile log file does not differ from reading ordinal files with the only exception that each file section is accessed through a separate transfer block.

If you want to know which registers are recorded to the file sections before reading them, check the daily profile log sections map through registers 3504-3505 (see Section 3.9, File Transfer Registers). This is a bitmap that contains one in a bit position if a designated register is recorded to the file, and contains zero if it is not.

The following gives a summary of steps for a multi-section file:

- 1) If you want to begin reading a file section from a particular record or from the first record, either set the file section position to the desired record sequence number, or preset the file section position to point to oldest record.
- 2) Read the record data through the corresponding file section transfer block. The file pointer automatically moves to the next file record.
- 3) Repeat steps 1-2 until all the file section records are read, i.e., until either bit 0 or bit 1 is set in the record status word.

Reading Waveform Files

Each waveform record consists of 6 channel records that are read in sequence always starting with channel V1. Each channel's data is read in two stages. The channel header record is read first through a separate transfer block followed by reading the channel sample series. When the channel V1 header is first accessed, the meter stores the waveform records for all channels together into a communication buffer so you can then read them through the dedicated transfer blocks without the risk of losing data. The following gives a summary of steps for a waveform file:

- 1) If you want to begin reading a file from a particular record or from the first record, either set the file position to the desired record sequence number, or preset the file position to point to oldest record.
- 2) Read the V1 channel header data through the corresponding waveform header transfer block. The record data is moved to the port's communication buffer, and then the file pointer automatically moves to the next record.
- 3) Read the V1 channel sample series through the waveform series transfer block.
- 4) Read the next channel's header data through the corresponding waveform header transfer block.
- 5) Read the sample series for the selected channel through the waveform series transfer block.
- 6) Repeat steps 4, 5 until all channels' records are read.

- 7) Repeat steps 2-6 until all the file records are read.

Reading Real-time Waveforms

Real-time waveforms are accessed through the separate transfer blocks just like the waveform log data. The meter provides a large waveform buffer that can simultaneously store 6 waveform records – three voltage and three current waveforms. Each time you read the V1 channel header record, the meter captures new waveforms to the buffer so that you can then read all of them through the waveform transfer blocks. The following gives a summary of steps for reading real-time waveforms:

- 1) Read the V1 channel header data through the corresponding real-time waveform header transfer block. The captured waveform's data is moved to the port's communication buffer.
- 2) Read the V1 channel sample series through the waveform series transfer block.
- 3) Read the next channel's header data through the corresponding waveform header transfer block.
- 4) Read the sample series for the selected channel through the waveform series transfer block.
- 5) Repeat steps 3, 4 until all channels' records are read.

3 Modbus Register Map

3.1 Modbus Setup Registers

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
Modbus Assignable Registers							
0-119							
+0		Register 0 contents	0-65535		UINT16	R/W	
+1		Register 1 contents	0-65535		UINT16	R/W	
		...					
+119		Register 119 contents	0-65535		UINT16	R/W	
Assignable Registers Map							
120-239							
+0		Mapped register 0 address	0-65535		UINT16	R/W	
+1		Mapped register 1 address	0-65535		UINT16	R/W	
+119		Mapped register 119 address	0-65535		UINT16	R/W	
Modbus Conversion Scales							
240		Low raw scale	0		UINT16	R	
241		High raw scale	9999		UINT16	R	
Device Data Scales							
242		Voltage scale, in secondary volts	60-828 (default 144V)	1V	UINT16	R/W	
243		Current scale, in secondary amps = CT secondary current (1A, 5A) × Current overload	20, 100 (2.0A, 10.0A)	×0.1A	UINT16	R	

3.2 16-bit Scaled Analog Registers and Energy Counters - Basic Register Set

Address	Point ID	Description	Low and High Scales ²	Units ²	Type	R/W	Notes
256-308							
+0	0x1100	V1/V12 Voltage	0-Vmax	U1	UINT16	R	1
+1	0x1101	V2/V23 Voltage	0-Vmax	U1	UINT16	R	1
+2	0x1102	V3/V31 Voltage	0-Vmax	U1	UINT16	R	1
+3	0x1103	I1 Current	0-Imax	U2	UINT16	R	
+4	0x1104	I2 Current	0-Imax	U2	UINT16	R	
+5	0x1105	I3 Current	0-Imax	U2	UINT16	R	
+6	0x1106	kW L1	-Pmax-Pmax	U3	INT16	R	
+7	0x1107	kW L2	-Pmax-Pmax	U3	INT16	R	
+8	0x1108	kW L3	-Pmax-Pmax	U3	INT16	R	
+9	0x1109	kvar L1	-Pmax-Pmax	U3	INT16	R	
+10	0x110A	kvar L2	-Pmax-Pmax	U3	INT16	R	
+11	0x110B	kvar L3	-Pmax-Pmax	U3	INT16	R	
+12	0x110C	kVA L1	-Pmax-Pmax	U3	UINT16	R	
+13	0x110D	kVA L2	-Pmax-Pmax	U3	UINT16	R	
+14	0x110E	kVA L3	-Pmax-Pmax	U3	UINT16	R	
+15	0x110F	Power factor L1	-1.000-1.000	0.001	INT16	R	
+16	0x1110	Power factor L2	-1.000-1.000	0.001	INT16	R	
+17	0x1111	Power factor L3	-1.000-1.000	0.001	INT16	R	
+18	0x1403	Total PF	-1.000-1.000	0.001	INT16	R	
+19	0x1400	Total kW	-Pmax-Pmax	U3	INT16	R	
+20	0x1401	Total kvar	-Pmax-Pmax	U3	INT16	R	
+21	0x1402	Total kVA	-Pmax-Pmax	U3	UINT16	R	
+22	0x1501	In (neutral) Current	0-Imax	U2	UINT16	R	
+23	0x1502	Frequency	45.00-65.00	0.01Hz	UINT16	R	
+24	0x3709	Maximum kW import sliding window demand	-Pmax-Pmax	U3	UINT16	R	
+25	0x160F	kW import accumulated demand	-Pmax-Pmax	U3	UINT16	R	
+26	0x370B	Maximum kVA sliding window demand	-Pmax-Pmax	U3	UINT16	R	
+27	0x1611	kVA accumulated demand	-Pmax-Pmax	U3	UINT16	R	
+28	0x3703	I1 Maximum ampere demand	0-Imax	U2	UINT16	R	
+29	0x3704	I2 Maximum ampere demand	0-Imax	U2	UINT16	R	
+30	0x3705	I3 Maximum ampere demand	0-Imax	U2	UINT16	R	
+31		kWh import (low)	0-9999	1kWh	UINT16	R	5
+32		kWh import (high)	0-9999	×10MWh	UINT16	R	5
+33		kWh export (low)	0-9999	1kWh	UINT16	R	5
+34		kWh export (high)	0-9999	×10MWh	UINT16	R	5
+35		+kvarh net (low)	0-9999	1kvarh	UINT16	R	3, 5
+36		+kvarh net (high)	0-9999	×10Mvarh	UINT16	R	3, 5
+37		-kvarh net (low)	0-9999	1kvarh	UINT16	R	4, 5

Address	Point ID	Description	Low and High Scales ²	Units ²	Type	R/W	Notes
+38		-kvarh net (high)	0-9999	×10Mvarh	UINT16	R	4, 5
+39	0x1112	V1/V12 Voltage THD	0-999.9	0.1%	UINT16	R	¹ 3-sec value
+40	0x1113	V2/V23 Voltage THD	0-999.9	0.1%	UINT16	R	¹ 3-sec value
+41	0x1114	V3/V31 Voltage THD	0-999.9	0.1%	UINT16	R	¹ 3-sec value
+42	0x1115	I1 Current THD	0-999.9	0.1%	UINT16	R	3-sec value
+43	0x1116	I2 Current THD	0-999.9	0.1%	UINT16	R	3-sec value
+44	0x1117	I3 Current THD	0-999.9	0.1%	UINT16	R	3-sec value
+45		kVAh (low)	0-9999	1kVAh	UINT16	R	⁵
+46		kVAh (high)	0-9999	10MVAh	UINT16	R	⁵
+47	0x1609	Present kW import sliding window demand	-Pmax-Pmax	U3	UINT16	R	
+48	0x160B	Present kVA sliding window demand	-Pmax-Pmax	U3	UINT16	R	
+49	0x1615	PF (import) at Max. kVA sliding window demand	0-1.000	0.001	UINT16	R	
+50	0x111B	I1 Current TDD	0-100.0	0.1%	UINT16	R	3-sec value
+51	0x111C	I2 Current TDD	0-100.0	0.1%	UINT16	R	3-sec value
+52	0x111D	I3 Current TDD	0-100.0	0.1%	UINT16	R	3-sec value

NOTES:

Energy and Power demand readings are only available in the meters with suffixes E and EH.

¹ Voltage and Voltage Harmonics Readings:

When the 4LN3, 3LN3 or 3BLN3 wiring mode is selected, the voltages will be line-to-neutral; for any other wiring mode, they will be line-to-line voltages.

When the 4LN3, 4LL3, 3LN3, 3LL3, 3BLN3 or 3BLL3 wiring mode is selected, the voltage harmonics will be line-to-neutral; for any other wiring mode, they will be line-to-line.

² All analog registers except of harmonics are 1-second average values. For volts, amps and power scales and units, refer to Section 4 "Data Scales and Units". For analog data scaling formulas and examples, see Section 2.6.1, "16-bit Scaled Integer Format".

³ Positive readings of kvarh net

⁴ Negative readings of kvarh net

⁵ If you use these energy registers instead of 32-bit registers, limit the energy roll value to 8 digits (see Device Options Setup) to avoid overflow.

3.3 16-bit Scaled Analog Registers, Binary Registers and Counters

Address	Point ID	Description	Low and High Scales ²	Units ²	Type	R/W	Notes
6656	0x0000	None	0		UINT16	R	
6696-6697		Special Inputs					
+0	0x0100	Voltage disturbance ^{EH}	0-100	%	UINT16	R	
+1	0x0101	Phase rotation order	0=error, 1=positive (ABC), 2=negative (CBA)		UINT16	R	
6776	0x0300	Event Flags (bitmap) ^{EH}	0x0000-0x00FF		UINT16	R	
6896	0x0600	Digital Inputs (bitmap)	0x0000-0x0003		UINT16	R	
6976	0x0800	Relay Outputs (bitmap)	0x0000-0x0003		UINT16	R	
7056-7063		Counters					
+0,1	0x0A00	Counter #1	0-999,999		UINT32	R/W	
+2,3	0x0A01	Counter #2	0-999,999		UINT32	R/W	
+4,5	0x0A02	Counter #3	0-999,999		UINT32	R/W	
+6,7	0x0A03	Counter #4	0-999,999		UINT32	R/W	
7136-7168		1-Cycle Phase Values					
+0	0x0C00	V1/V12 Voltage	0-Vmax	U1	UINT16	R	¹
+1	0x0C01	V2/V23 Voltage	0-Vmax	U1	UINT16	R	¹
+2	0x0C02	V3/V31 Voltage	0-Vmax	U1	UINT16	R	¹
+3	0x0C03	I1 Current	0-Imax	U2	UINT16	R	
+4	0x0C04	I2 Current	0-Imax	U2	UINT16	R	
+5	0x0C05	I3 Current	0-Imax	U2	UINT16	R	
+6	0x0C06	kW L1	-Pmax-Pmax	U3	INT16	R	
+7	0x0C07	kW L2	-Pmax-Pmax	U3	INT16	R	
+8	0x0C08	kW L3	-Pmax-Pmax	U3	INT16	R	
+9	0x0C09	kvar L1	-Pmax-Pmax	U3	INT16	R	
+10	0x0C0A	kvar L2	-Pmax-Pmax	U3	INT16	R	
+11	0x0C0B	kvar L3	-Pmax-Pmax	U3	INT16	R	
+12	0x0C0C	kVA L1	0-Pmax	U3	UINT16	R	
+13	0x0C0D	kVA L2	0-Pmax	U3	UINT16	R	
+14	0x0C0E	kVA L3	0-Pmax	U3	UINT16	R	
+15	0x0C0F	Power factor L1	-1.000-1.000	0.001	INT16	R	
+16	0x0C10	Power factor L2	-1.000-1.000	0.001	INT16	R	
+17	0x0C11	Power factor L3	-1.000-1.000	0.001	INT16	R	
+18	0x0C12	V1/V12 Voltage THD	0-999.9	0.1%	UINT16	R	¹ 4-cycle value
+19	0x0C13	V2/V23 Voltage THD	0-999.9	0.1%	UINT16	R	¹ 4-cycle value
+20	0x0C14	V3/V31 Voltage THD	0-999.9	0.1%	UINT16	R	¹ 4-cycle value
+21	0x0C15	I1 Current THD	0-999.9	0.1%	UINT16	R	4-cycle value
+22	0x0C16	I2 Current THD	0-999.9	0.1%	UINT16	R	4-cycle value
+23	0x0C17	I3 Current THD	0-999.9	0.1%	UINT16	R	4-cycle value
+24	0x0C18	I1 K-Factor	1.0-999.9	0.1	UINT16	R	4-cycle value

Address	Point ID	Description	Low and High Scales ²	Units ²	Type	R/W	Notes
+25	0x0C19	I2 K-Factor	1.0-999.9	0.1	UINT16	R	4-cycle value
+26	0x0C1A	I3 K-Factor	1.0-999.9	0.1	UINT16	R	4-cycle value
+27	0x0C1B	I1 Current TDD	0-100.0	0.1%	UINT16	R	4-cycle value
+28	0x0C1C	I2 Current TDD	0-100.0	0.1%	UINT16	R	4-cycle value
+29	0x0C1D	I3 Current TDD	0-100.0	0.1%	UINT16	R	4-cycle value
+30	0x0C1E	V12 Voltage	0-Vmax	U1	UINT16	R	
+31	0x0C1F	V23 Voltage	0-Vmax	U1	UINT16	R	
+32	0x0C20	V31 Voltage	0-Vmax	U1	UINT16	R	
7256-7359		1-Cycle Total Values					
+0	0x0F00	Total kW	-Pmax-Pmax	U3	INT16	R	
+1	0x0F01	Total kvar	-Pmax-Pmax	U3	INT16	R	
+2	0x0F02	Total kVA	0-Pmax	U3	UINT16	R	
+3	0x0F03	Total PF	-1.000-1.000	0.001	INT16	R	
+4	0x0F04	Total PF lag	0-1.000	0.001	UINT16	R	
+5	0x0F05	Total PF lead	0-1.000	0.001	UINT16	R	
+5	0x0F06	Total kW import	0-Pmax	U3	UINT32	R	
+7	0x0F07	Total kW export	0-Pmax	U3	UINT32	R	
+8	0x0F08	Total kvar import	0-Pmax	U3	UINT32	R	
+9	0x0F09	Total kvar export	0-Pmax	U3	UINT32	R	
+10	0x0FOA	3-phase average L-N/L-L voltage	0-Vmax	U1	UINT32	R	¹
+11	0x0FOB	3-phase average L-L voltage	0-Vmax	U1	UINT32	R	
+12	0x0FOC	3-phase average current	0-Imax	U2	UINT32	R	
7296-7300		1-Cycle Auxiliary Values					
+0	0x1000	Not used			UINT16	R	
+1	0x1001	In (neutral) Current	0-Imax	U2	UINT16	R	
+2	0x1002	Frequency	0-Fmax	0.01Hz	UINT16	R	
+3	0x1003	Voltage unbalance	0-300	%	UINT16	R	
+4	0x1004	Current unbalance	0-300	%	UINT16	R	
7316-7331		Phasor					
+0	0x1080	V1/V12 Voltage magnitude	0-Vmax	U1	UINT16	R	¹
+1	0x1081	V2/V23 Voltage magnitude	0-Vmax	U1	UINT16	R	¹
+2	0x1082	V3/V31 Voltage magnitude	0-Vmax	U1	UINT16	R	¹
+3	0x1083	Not used			UINT16	R	
+4	0x1084	I1 Current magnitude	0-Imax	U2	UINT16	R	
+5	0x1085	I2 Current magnitude	0-Imax	U2	UINT16	R	
+5	0x1086	I3 Current magnitude	0-Imax	U2	UINT16	R	
+7	0x1087	Not used			UINT16	R	
+8	0x1088	V1/V12 Voltage angle	-180.0-180.0	0.1°	INT16	R	¹
+9	0x1089	V2/V23 Voltage angle	-180.0-180.0	0.1°	INT16	R	¹
+10	0x108A	V3/V31 Voltage angle	-180.0-180.0	0.1°	INT16	R	¹
+11	0x108B	Not used			INT16	R	
+12	0x108C	I1 Current angle	-180.0-180.0	0.1°	INT16	R	
+13	0x108D	I2 Current angle	-180.0-180.0	0.1°	INT16	R	

Address	Point ID	Description	Low and High Scales ²	Units ²	Type	R/W	Notes
+14	0x108E	I3 Current angle	-180.0-180.0	0.1°	INT16	R	
+15	0x108F	Not used			INT16	R	
7336-7368		1-Second Phase Values					
+0	0x1100	V1/V12 Voltage	0-Vmax	U1	UINT16	R	¹
+1	0x1101	V2/V23 Voltage	0-Vmax	U1	UINT16	R	¹
+2	0x1102	V3/V31 Voltage	0-Vmax	U1	UINT16	R	¹
+3	0x1103	I1 Current	0-Imax	U2	UINT16	R	
+4	0x1104	I2 Current	0-Imax	U2	UINT16	R	
+5	0x1105	I3 Current	0-Imax	U2	UINT16	R	
+6	0x1106	kW L1	-Pmax-Pmax	U3	INT16	R	
+7	0x1107	kW L2	-Pmax-Pmax	U3	INT16	R	
+8	0x1108	kW L3	-Pmax-Pmax	U3	INT16	R	
+9	0x1109	kvar L1	-Pmax-Pmax	U3	INT16	R	
+10	0x110A	kvar L2	-Pmax-Pmax	U3	INT16	R	
+11	0x110B	kvar L3	-Pmax-Pmax	U3	INT16	R	
+12	0x110C	kVA L1	0-Pmax	U3	UINT16	R	
+13	0x110D	kVA L2	0-Pmax	U3	UINT16	R	
+14	0x110E	kVA L3	0-Pmax	U3	UINT16	R	
+15	0x110F	Power factor L1	-1.000-1.000	0.001	INT16	R	
+16	0x1110	Power factor L2	-1.000-1.000	0.001	INT16	R	
+17	0x1111	Power factor L3	-1.000-1.000	0.001	INT16	R	
+18	0x1112	V1/V12 Voltage THD	0-999.9	0.1%	UINT16	R	¹ 3-sec value
+19	0x1113	V2/V23 Voltage THD	0-999.9	0.1%	UINT16	R	¹ 3-sec value
+20	0x1114	V3/V31 Voltage THD	0-999.9	0.1%	UINT16	R	¹ 3-sec value
+21	0x1115	I1 Current THD	0-999.9	0.1%	UINT16	R	3-sec value
+22	0x1116	I2 Current THD	0-999.9	0.1%	UINT16	R	3-sec value
+23	0x1117	I3 Current THD	0-999.9	0.1%	UINT16	R	3-sec value
+24	0x1118	I1 K-Factor	1.0-999.9	0.1	UINT16	R	3-sec value
+25	0x1119	I2 K-Factor	1.0-999.9	0.1	UINT16	R	3-sec value
+26	0x111A	I3 K-Factor	1.0-999.9	0.1	UINT16	R	3-sec value
+27	0x111B	I1 Current TDD	0-100.0	0.1%	UINT16	R	3-sec value
+28	0x111C	I2 Current TDD	0-100.0	0.1%	UINT16	R	3-sec value
+29	0x111D	I3 Current TDD	0-100.0	0.1%	UINT16	R	3-sec value
+30	0x111E	V12 Voltage	0-Vmax	U1	UINT16	R	
+31	0x111F	V23 Voltage	0-Vmax	U1	UINT16	R	
+32	0x1120	V31 Voltage	0-Vmax	U1	UINT16	R	
7456-7459		1-Second Total Values					
+0	0x1400	Total kW	-Pmax-Pmax	U3	INT16	R	
+1	0x1401	Total kvar	-Pmax-Pmax	U3	INT16	R	
+2	0x1402	Total kVA	0-Pmax	U3	UINT16	R	
+3	0x1403	Total PF	-1.000-1.000	0.001	INT16	R	
+4	0x1404	Total PF lag	0-1.000	0.001	UINT16	R	
+5	0x1405	Total PF lead	0-1.000	0.001	UINT16	R	

Address	Point ID	Description	Low and High Scales ²	Units ²	Type	R/W	Notes
+5	0x1406	Total kW import	0-Pmax	U3	UINT32	R	
+7	0x1407	Total kW export	0-Pmax	U3	UINT32	R	
+8	0x1408	Total kvar import	0-Pmax	U3	UINT32	R	
+9	0x1409	Total kvar export	0-Pmax	U3	UINT32	R	
+10	0x140A	3-phase average L-N/L-L voltage	0-Vmax	U1	UINT32	R	1
+11	0x140B	3-phase average L-L voltage	0-Vmax	U1	UINT32	R	
+12	0x140C	3-phase average current	0-Imax	U2	UINT32	R	
7496-7500		1-Second Auxiliary Values					
+0	0x1500	Not used			UINT16	R	
+1	0x1501	In (neutral) Current	0-Imax	U2	UINT16	R	
+2	0x1502	Frequency	0-Fmax	0.01Hz	UINT16	R	
+3	0x1503	Voltage unbalance	0-300	%	UINT16	R	
+4	0x1504	Current unbalance	0-300	%	UINT16	R	
7516-7527		Present Harmonic Demands					
+0	0x1580	V1/V12 THD demand	0-999.9	0.1%	UINT16	R	1
+1	0x1581	V2/V23 THD demand	0-999.9	0.1%	UINT16	R	1
+2	0x1582	V3/V31 THD demand	0-999.9	0.1%	UINT16	R	1
+3	0x1583	Not used			UINT16	R	
+4	0x1584	I1 THD demand	0-999.9	0.1%	UINT16	R	
+5	0x1585	I2 THD demand	0-999.9	0.1%	UINT16	R	
+5	0x1586	I3 THD demand	0-999.9	0.1%	UINT16	R	
+7	0x1587	Not used			UINT16	R	
+8	0x1588	I1 TDD demand	0-100.0	0.1%	UINT16	R	
+9	0x1589	I2 TDD demand	0-100.0	0.1%	UINT16	R	
+10	0x158A	I3 TDD demand	0-100.0	0.1%	UINT16	R	
+11	0x158B	Not used			UINT16	R	
7536-7565		Present Volt, Ampere and Power Demands					
+0	0x1600	V1/V12 Volt demand	0-Vmax	U1	UINT16	R	1
+1	0x1601	V2/V23 Volt demand	0-Vmax	U1	UINT16	R	1
+2	0x1602	V3/V31 Volt demand	0-Vmax	U1	UINT16	R	1
+3	0x1603	I1 Ampere demand	0-Imax	U2	UINT16	R	
+4	0x1604	I2 Ampere demand	0-Imax	U2	UINT16	R	
+5	0x1605	I3 Ampere demand	0-Imax	U2	UINT16	R	
+6	0x1606	kW import block demand	0-Pmax	U3	UINT16	R	
+7	0x1607	kvar import block demand	0-Pmax	U3	UINT16	R	
+8	0x1608	kVA block demand	0-Pmax	U3	UINT16	R	
+9	0x1609	kW import sliding window demand	0-Pmax	U3	UINT16	R	
+10	0x160A	kvar import sliding window demand	0-Pmax	U3	UINT16	R	
+11	0x160B	kVA sliding window demand	0-Pmax	U3	UINT16	R	
+12	0x160C	Not used			UINT16	R	
+13	0x160D	Not used			UINT16	R	
+14	0x160E	Not used			UINT16	R	
+15	0x160F	kW import accumulated demand	0-Pmax	U3	UINT16	R	

Address	Point ID	Description	Low and High Scales ²	Units ²	Type	R/W	Notes
+16	0x1610	kvar import accumulated demand	0-Pmax	U3	UINT16	R	
+17	0x1611	kVA accumulated demand	0-Pmax	U3	UINT16	R	
+18	0x1612	kW import predicted sliding window demand	0-Pmax	U3	UINT16	R	
+19	0x1613	kvar import predicted sliding window demand	0-Pmax	U3	UINT16	R	
+20	0x1614	kVA predicted sliding window demand	0-Pmax	U3	UINT16	R	
+21	0x1615	PF (import) at Max. kVA sliding window demand	0-1.000	0.001	UINT16	R	
+22	0x1616	kW export block demand	0-Pmax	U3	UINT16	R	
+23	0x1617	kvar export block demand	0-Pmax	U3	UINT16	R	
+24	0x1618	kW export sliding window demand	0-Pmax	U3	UINT16	R	
+25	0x1619	kvar export sliding window demand	0-Pmax	U3	UINT16	R	
+26	0x161A	kW export accumulated demand	0-Pmax	U3	UINT16	R	
+27	0x161B	kvar export accumulated demand	0-Pmax	U3	UINT16	R	
+28	0x161C	kW export predicted sliding window demand	0-Pmax	U3	UINT16	R	
+29	0x161D	kvar export predicted sliding window demand	0-Pmax	U3	UINT16	R	
7576-7611		Total Energies^E					
+0,1	0x1700	kWh import	0-10 ⁹ -1	1 kWh	UINT32	R	
+2,3	0x1701	kWh export	0-10 ⁹ -1	1 kWh	UINT32	R	
+4,5		Not used			INT32	R	
+6,7		Not used			UINT32	R	
+8,9	0x1704	kvarh import	0-10 ⁹ -1	1 kvarh	UINT32	R	
+10,11	0x1705	kvarh export	0-10 ⁹ -1	1 kvarh	UINT32	R	
+12,13		Not used			INT32	R	
+14,15		Not used			UINT32	R	
+16,17	0x1708	kVAh total	0-10 ⁹ -1	1 kVAh	UINT32	R	
+18-25		Not used			UINT32	R	
+26,27	0x170D	Harmonic kWh import ^{EH}	0-10 ⁹ -1	1 kWh	UINT32	R	
+28,29	0x170E	Harmonic kWh export ^{EH}	0-10 ⁹ -1	1 kWh	UINT32	R	
+30-33		Not used			UINT32	R	
+34,35	0x1711	Harmonic kVAh total ^{EH}	0-10 ⁹ -1	1 kVAh	UINT32	R	
7616-7633		Phase Energies^E					
+0,1	0x1800	kWh import L1	0-10 ⁹ -1	1 kWh	UINT32	R	
+2,3	0x1801	kWh import L2	0-10 ⁹ -1	1 kWh	UINT32	R	
+4,5	0x1802	kWh import L3	0-10 ⁹ -1	1 kWh	UINT32	R	
+6,7	0x1803	kvarh import L1	0-10 ⁹ -1	1 kvarh	UINT32	R	
+8,9	0x1804	kvarh import L2	0-10 ⁹ -1	1 kvarh	UINT32	R	
+10,11	0x1805	kvarh import L3	0-10 ⁹ -1	1 kvarh	UINT32	R	
+12,13	0x1806	kVAh total L1	0-10 ⁹ -1	1 kVAh	UINT32	R	
+14,15	0x1807	kVAh total L2	0-10 ⁹ -1	1 kVAh	UINT32	R	
+16,17	0x1808	kVAh total L3	0-10 ⁹ -1	1 kVAh	UINT32	R	
7656-7695		V1/V12 Harmonic Distortions^{EH}					1
+0	0x1900	H01 Harmonic distortion	0-100.00	0.01%	UINT16	R	

Address	Point ID	Description	Low and High Scales ²	Units ²	Type	R/W	Notes
+1	0x1901	H02 Harmonic distortion	0-100.00	0.01%	UINT16	R	
		...					
+39	0x1927	H40 Harmonic distortion	0-100.00	0.01%	UINT16	R	
7696-7735		V2/V23 Harmonic Distortions ^{EH}					1
+0	0x1A00	H01 Harmonic distortion	0-100.00	0.01%	UINT16	R	
+1	0x1A01	H02 Harmonic distortion	0-100.00	0.01%	UINT16	R	
		...					
+39	0x1A27	H40 Harmonic distortion	0-100.00	0.01%	UINT16	R	
7736-7775		V3/V31 Harmonic Distortions ^{EH}					1
+0	0x1B00	H01 Harmonic distortion	0-100.00	0.01%	UINT16	R	
+1	0x1B01	H02 Harmonic distortion	0-100.00	0.01%	UINT16	R	
		...					
+39	0x1B27	H40 Harmonic distortion	0-100.00	0.01%	UINT16	R	
7776-7815		I1 Harmonic Distortions ^{EH}					
+0	0x1C00	H01 Harmonic distortion	0-100.00	0.01%	UINT16	R	
+1	0x1C01	H02 Harmonic distortion	0-100.00	0.01%	UINT16	R	
		...					
+39	0x1C27	H40 Harmonic distortion	0-100.00	0.01%	UINT16	R	
7816-7855		I2 Harmonic Distortions ^{EH}					
+0	0x1D00	H01 Harmonic distortion	0-100.00	0.01%	UINT16	R	
+1	0x1D01	H02 Harmonic distortion	0-100.00	0.01%	UINT16	R	
		...					
+39	0x1D27	H40 Harmonic distortion	0-100.00	0.01%	UINT16	R	
7856-7895		I3 Harmonic Distortions ^{EH}					
+0	0x1E00	H01 Harmonic distortion	0-100.00	0.01%	UINT16	R	
+1	0x1E01	H02 Harmonic distortion	0-100.00	0.01%	UINT16	R	
		...					
+39	0x1E27	H40 Harmonic distortion	0-100.00	0.01%	UINT16	R	
8296-8313		Fundamental (H01) Phase Values					4-cycle values
+0	0x2900	V1/V12 Voltage	0-Vmax	U1	UINT16	R	1
+1	0x2901	V2/V23 Voltage	0-Vmax	U1	UINT16	R	1
+2	0x2902	V3/V31 Voltage	0-Vmax	U1	UINT16	R	1
+3	0x2903	I1 Current	0-Imax	U2	UINT16	R	
+4	0x2904	I2 Current	0-Imax	U2	UINT16	R	
+5	0x2905	I3 Current	0-Imax	U2	UINT16	R	
+6	0x2906	kW L1	-Pmax-Pmax	U3	INT16	R	
+7	0x2907	kW L2	-Pmax-Pmax	U3	INT16	R	
+8	0x2908	kW L3	-Pmax-Pmax	U3	INT16	R	
+9	0x2909	kvar L1	-Pmax-Pmax	U3	INT16	R	
+10	0x290A	kvar L2	-Pmax-Pmax	U3	INT16	R	
+11	0x290B	kvar L3	-Pmax-Pmax	U3	INT16	R	

Address	Point ID	Description	Low and High Scales ²	Units ²	Type	R/W	Notes
+12	0x290C	kVA L1	0-Pmax	U3	UINT16	R	
+13	0x290D	kVA L2	0-Pmax	U3	UINT16	R	
+14	0x290E	kVA L3	0-Pmax	U3	UINT16	R	
+15	0x290F	Power factor L1	-1.000-1.000	0.001	INT16	R	
+16	0x2910	Power factor L2	-1.000-1.000	0.001	INT16	R	
+17	0x2911	Power factor L3	-1.000-1.000	0.001	INT16	R	
8336-8343		Harmonic Total Values					4-cycle values
+0	0x2A00	Total fundamental kW	-Pmax-Pmax	U3	INT16	R	
+1	0x2A01	Total fundamental kvar	-Pmax-Pmax	U3	INT16	R	
+2	0x2A02	Total fundamental kVA	0-Pmax	U3	UINT16	R	
+3	0x2A03	Total fundamental PF	-1.000-1.000	0.001	INT16	R	
+4	0x2A04	Total harmonic kW ^{EH}	-Pmax-Pmax	U3	INT16	R	
+5	0x2A05	Not used			INT16	R	
+6	0x2A06	Total harmonic kVA ^{EH}	0-Pmax	U3	UINT16	R	
+7	0x2A07	Not used			INT16	R	
8416-8445		Minimum 1-Cycle Phase Values					
+0	0x2C00	V1/V12 Voltage	0-Vmax	U1	UINT16	R	¹
+1	0x2C01	V2/V23 Voltage	0-Vmax	U1	UINT16	R	¹
+2	0x2C02	V3/V31 Voltage	0-Vmax	U1	UINT16	R	¹
+3	0x2C03	I1 Current	0-Imax	U2	UINT16	R	
+4	0x2C04	I2 Current	0-Imax	U2	UINT16	R	
+5	0x2C05	I3 Current	0-Imax	U2	UINT16	R	
+6-17	0x2C06-0x2C11	Not used	0		INT16	R	
+18	0x2C12	V1/V12 Voltage THD	0-9999	0.1%	UINT16	R	¹ 4-cycle value
+19	0x2C13	V2/V23 Voltage THD	0-9999	0.1%	UINT16	R	¹ 4-cycle value
+20	0x2C14	V3/V31 Voltage THD	0-999.9	0.1%	UINT16	R	¹ 4-cycle value
+21	0x2C15	I1 Current THD	0-999.9	0.1%	UINT16	R	4-cycle value
+22	0x2C16	I2 Current THD	0-999.9	0.1%	UINT16	R	4-cycle value
+23	0x2C17	I3 Current THD	0-999.9	0.1%	UINT16	R	4-cycle value
+24	0x2C18	I1 K-Factor	1.0-999.9	0.1	UINT16	R	4-cycle value
+25	0x2C19	I2 K-Factor	1.0-999.9	0.1	UINT16	R	4-cycle value
+26	0x2C1A	I3 K-Factor	1.0-999.9	0.1	UINT16	R	4-cycle value
+27	0x2C1B	I1 Current TDD	0-100.0	0.1%	UINT16	R	4-cycle value
+28	0x2C1C	I2 Current TDD	0-100.0	0.1%	UINT16	R	4-cycle value
+29	0x2C1D	I3 Current TDD	0-100.0	0.1%	UINT16	R	4-cycle value
8456-8459		Minimum 1-Cycle Total Values					
+0	0x2D00	Total kW	-Pmax-Pmax	U3	INT16	R	
+1	0x2D01	Total kvar	-Pmax-Pmax	U3	INT16	R	
+2	0x2D02	Total kVA	0-Pmax	U3	UINT16	R	
+3	0x2D03	Total PF	0-1.000	0.001	UINT16	R	Absolute value
8496-8498		Minimum 1-Cycle Auxiliary Values					
+0	0x2E00	Not used		U2	UINT16	R	

Address	Point ID	Description	Low and High Scales ²	Units ²	Type	R/W	Notes
+1	0x2E01	In Current	0-Imax	U2	UINT16	R	
+2	0x2E02	Frequency	0-Fmax	0.01Hz	UINT16	R	
8736-8765		Maximum 1-Cycle Phase Values					
+0	0x3400	V1/V12 Voltage	0-Vmax	U1	UINT16	R	¹
+1	0x3401	V2/V23 Voltage	0-Vmax	U1	UINT16	R	¹
+2	0x3402	V3/V31 Voltage	0-Vmax	U1	UINT16	R	¹
+3	0x3403	I1 Current	0-Imax	U2	UINT16	R	
+4	0x3404	I2 Current	0-Imax	U2	UINT16	R	
+5	0x3405	I3 Current	0-Imax	U2	UINT16	R	
+6-17	0x3406-0x3411	Not used	0		INT16	R	
+18	0x3412	V1 Voltage THD	0-999.9	0.1%	UINT16	R	¹ 4-cycle value
+19	0x3413	V2 Voltage THD	0-999.9	0.1%	UINT16	R	¹ 4-cycle value
+20	0x3414	V3 Voltage THD	0-999.9	0.1%	UINT16	R	¹ 4-cycle value
+21	0x3415	I1 Current THD	0-999.9	0.1%	UINT16	R	4-cycle value
+22	0x3416	I2 Current THD	0-999.9	0.1%	UINT16	R	4-cycle value
+23	0x3417	I3 Current THD	0-999.9	0.1%	UINT16	R	4-cycle value
+24	0x3418	I1 K-Factor	1.0-999.9	0.1	UINT16	R	4-cycle value
+25	0x3419	I2 K-Factor	1.0-999.9	0.1	UINT16	R	4-cycle value
+26	0x341A	I3 K-Factor	1.0-999.9	0.1	UINT16	R	4-cycle value
+27	0x341B	I1 Current TDD	0-100.0	0.1%	UINT16	R	4-cycle value
+28	0x341C	I2 Current TDD	0-100.0	0.1%	UINT16	R	4-cycle value
+29	0x341D	I3 Current TDD	0-100.0	0.1%	UINT16	R	4-cycle value
8776-8779		Maximum 1-Cycle Total Values					
+0	0x3500	Total kW	-Pmax-Pmax	U3	INT16	R	
+1	0x3501	Total kvar	-Pmax-Pmax	U3	INT16	R	
+2	0x3502	Total kVA	0-Pmax	U3	UINT16	R	
+3	0x3503	Total PF	0-1.000	0.001	UINT16	R	Absolute value
881608818		Maximum 1-Cycle Auxiliary Values					
+0	0x3600	Not used		U2	UINT16	R	
+1	0x3601	In Current	0-Imax	U2	UINT16	R	
+2	0x3602	Frequency	0-Fmax	0.01Hz	UINT16	R	
8856-8872		Maximum Demands					
+0	0x3700	V1/V12 Maximum volt demand	0-Vmax	U1	UINT16	R	¹
+1	0x3701	V2/V23 Maximum volt demand	0-Vmax	U1	UINT16	R	¹
+2	0x3702	V3/V31 Maximum volt demand	0-Vmax	U1	UINT16	R	¹
+3	0x3703	I1 Maximum ampere demand	0-Imax	U2	UINT16	R	
+4	0x3704	I2 Maximum ampere demand	0-Imax	U2	UINT16	R	
+5	0x3705	I3 Maximum ampere demand	0-Imax	U2	UINT16	R	
+6	0x3706	Not used			UINT16	R	
+7	0x3707	Not used			UINT16	R	
+8	0x3708	Not used			UINT16	R	
+9	0x3709	Maximum kW import sliding window demand	0-Pmax	U3	UINT16	R	

Address	Point ID	Description	Low and High Scales ²	Units ²	Type	R/W	Notes
+10	0x370A	Maximum kvar import sliding window demand	0-Pmax	U3	UINT16	R	
+11	0x370B	Maximum kVA sliding window demand	0-Pmax	U3	UINT16	R	
+12	0x370C	Not used			UINT16	R	
+13	0x370D	Not used			UINT16	R	
+14	0x370E	Not used			UINT16	R	
+15	0x370F	Maximum kW export sliding window demand	0-Pmax	U3	UINT16	R	
+16	0x3710	Maximum kvar export sliding window demand	0-Pmax	U3	UINT16	R	
7200-7211		Maximum Harmonic Demands					
+0	0x3880	V1/V12 THD demand	0-999.9	0.1%	UINT16	R	1
+1	0x3881	V2/V23 THD demand	0-999.9	0.1%	UINT16	R	1
+2	0x3882	V3/V31 THD demand	0-999.9	0.1%	UINT16	R	1
+3	0x3883	Not used			UINT16	R	
+4	0x3884	I1 THD demand	0-999.9	0.1%	UINT16	R	
+5	0x3885	I2 THD demand	0-999.9	0.1%	UINT16	R	
+6	0x3886	I3 THD demand	0-999.9	0.1%	UINT16	R	
+7	0x3887	Not used			UINT16	R	
+8	0x3888	I1 TDD demand	0-100.0	0.1%	UINT16	R	
+9	0x3889	I2 TDD demand	0-100.0	0.1%	UINT16	R	
+10	0x388A	I3 TDD demand	0-100.0	0.1%	UINT16	R	
+11	0x388B	Not used			UINT16	R	
9016-9017		Scaled Analog Inputs					
+0	0x3B00	Analog input AI1	AI1min-AI1Max		UINT16	R	
+1	0x3B01	Analog input AI2	AI2min-AI2Max		UINT16	R	
9036-9037		Raw Analog Inputs					
+0	0x3B80	Analog input AI1	0-4095		UINT16	R	
+1	0x3B81	Analog input AI2	0-4095		UINT16	R	
9056-9057		TOU Parameters E					
+0	0x3C00	Active tariff	0-7		UINT16	R/W	
+1	0x3C01	Active profile	0-15: 0-3 = Season 1 Profile #1-4, 4-7 = Season 2 Profile #1-4, 8-11 = Season 3 Profile #1-4, 12-15 = Season 4 Profile #1-4		UINT16	R/W	
9076-9077		Scaled Analog Outputs					
+0	0x3C80	Analog output AO1	0-4095		UINT16	R/W	
+1	0x3C81	Analog output AO2	0-4095		UINT16	R/W	
9096-9111		TOU Energy Register #1 E					
+0,1	0x3D00	Tariff #1 register	0-10 ⁹ -1	1 kWh	UINT32	R	
+2,3	0x3D01	Tariff #2 register	0-10 ⁹ -1	1 kWh	UINT32	R	
		...				R	
+14,15	0x3D07	Tariff #8 register	0-10 ⁹ -1	1 kWh	UINT32	R	
9136-9151		TOU Energy Register #2 E					
+0,1	0x3E00	Tariff #1 register	0-10 ⁹ -1	1 kWh	UINT32	R	

Address	Point ID	Description	Low and High Scales ²	Units ²	Type	R/W	Notes
+2,3	0x3E01	Tariff #2 register	0-10 ⁹ -1	1 kWh	UINT32	R	
		...				R	
+14,15	0x3E07	Tariff #8 register	0-10 ⁹ -1	1 kWh	UINT32	R	
9176-9191		TOU Energy Register #3^E					
+0,1	0x3F00	Tariff #1 register	0-10 ⁹ -1	1 kWh	UINT32	R	
+2,3	0x3F01	Tariff #2 register	0-10 ⁹ -1	1 kWh	UINT32	R	
		...				R	
+14,15	0x3F07	Tariff #8 register	0-10 ⁹ -1	1 kWh	UINT32	R	
9216-9231		TOU Energy Register #4^E					
+0,1	0x4000	Tariff #1 register	0-10 ⁹ -1	1 kWh	UINT32	R	
+2,3	0x4001	Tariff #2 register	0-10 ⁹ -1	1 kWh	UINT32	R	
		...				R	
+14,15	0x4007	Tariff #8 register	0-10 ⁹ -1	1 kWh	UINT32	R	
9256-9271		TOU Energy Register #5^E					
+0,1	0x4100	Tariff #1 register	0-10 ⁹ -1	1 kWh	UINT32	R	
+2,3	0x4101	Tariff #2 register	0-10 ⁹ -1	1 kWh	UINT32	R	
		...				R	
+14,15	0x4107	Tariff #8 register	0-10 ⁹ -1	1 kWh	UINT32	R	
9296-9311		TOU Energy Register #6^E					
+0,1	0x4200	Tariff #1 register	0-10 ⁹ -1	1 kWh	UINT32	R	
+2,3	0x4201	Tariff #2 register	0-10 ⁹ -1	1 kWh	UINT32	R	
		...				R	
+14,15	0x4207	Tariff #8 register	0-10 ⁹ -1	1 kWh	UINT32	R	
9336-9351		TOU Energy Register #7^E					
+0,1	0x4300	Tariff #1 register	0-10 ⁹ -1	1 kWh	UINT32	R	
+2,3	0x4301	Tariff #2 register	0-10 ⁹ -1	1 kWh	UINT32	R	
		...				R	
+14,15	0x4307	Tariff #8 register	0-10 ⁹ -1	1 kWh	UINT32	R	
9376-9391		TOU Energy Register #8^E					
+0,1	0x4400	Tariff #1 register	0-10 ⁹ -1	1 kWh	UINT32	R	
+2,3	0x4401	Tariff #2 register	0-10 ⁹ -1	1 kWh	UINT32	R	
		...				R	
+14,15	0x4407	Tariff #8 register	0-10 ⁹ -1	1 kWh	UINT32	R	
9416-9423		Summary Energy Accumulated Demands^E					
+0	0x4500	Summary register #1 demand	0-Pmax	U3	UINT16	R	
+1	0x4501	Summary register #2 demand	0-Pmax	U3	UINT16	R	
		...				R	
+7	0x4507	Summary register #8 demand	0-Pmax	U3	UINT16	R	
9436-9443		Summary Energy Block Demands^E					
+0	0x4580	Summary register #1 demand	0-Pmax	U3	UINT16	R	

Address	Point ID	Description	Low and High Scales ²	Units ²	Type	R/W	Notes
+1	0x4581	Summary register #2 demand	0-Pmax	U3	UINT16	R	
		...				R	
+7	0x4587	Summary register #8 demand	0-Pmax	U3	UINT16	R	
9456-9463		Summary Energy Sliding Window Demands^E					
+0	0x4600	Summary register #1 demand	0-Pmax	U3	UINT16	R	
+1	0x4601	Summary register #2 demand	0-Pmax	U3	UINT16	R	
		...				R	
+7	0x4607	Summary register #8 demand	0-Pmax	U3	UINT16	R	
9516-9523		Summary Energy Maximum Demands^E					
+0	0x4780	Summary register #1 maximum demand	0-Pmax	U3	UINT16	R	
+1	0x4781	Summary register #2 maximum demand	0-Pmax	U3	UINT16	R	
		...				R	
+7	0x4787	Summary register #8 maximum demand	0-Pmax	U3	UINT16	R	
9536-9543		TOU Maximum Demand Register #1^E					
+0	0x4800	Tariff #1 maximum demand	0-Pmax	U3	UINT16	R	
+1	0x4801	Tariff #2 maximum demand	0-Pmax	U3	UINT16	R	
		...				R	
+7	0x4807	Tariff #8 maximum demand	0-Pmax	U3	UINT16	R	
9576-9583		TOU Maximum Demand Register #2^E					
+0	0x4900	Tariff #1 maximum demand	0-Pmax	U3	UINT16	R	
+1	0x4901	Tariff #2 maximum demand	0-Pmax	U3	UINT16	R	
		...				R	
+7	0x4907	Tariff #8 maximum demand	0-Pmax	U3	UINT16	R	
9616-9623		TOU Maximum Demand Register #3^E					
+0	0x4A00	Tariff #1 maximum demand	0-Pmax	U3	UINT16	R	
+1	0x4A01	Tariff #2 maximum demand	0-Pmax	U3	UINT16	R	
		...				R	
+7	0x4A07	Tariff #8 maximum demand	0-Pmax	U3	UINT16	R	
9556-9563		TOU Maximum Demand Register #4^E					
+0	0x4880	Tariff #1 maximum demand	0-Pmax	U3	UINT16	R	
+1	0x4881	Tariff #2 maximum demand	0-Pmax	U3	UINT16	R	
		...				R	
+7	0x4887	Tariff #8 maximum demand	0-Pmax	U3	UINT16	R	
9596-9603		TOU Maximum Demand Register #5^E					
+0	0x4980	Tariff #1 maximum demand	0-Pmax	U3	UINT16	R	
+1	0x4981	Tariff #2 maximum demand	0-Pmax	U3	UINT16	R	
		...				R	
+7	0x4987	Tariff #8 maximum demand	0-Pmax	U3	UINT16	R	
9636-9643		TOU Maximum Demand Register #6^E					
+0	0x4A80	Tariff #1 maximum demand	0-Pmax	U3	UINT16	R	

Address	Point ID	Description	Low and High Scales ²	Units ²	Type	R/W	Notes
+1	0x4A81	Tariff #2 maximum demand	0-Pmax	U3	UINT16	R	
		...				R	
+7	0x4A87	Tariff #8 maximum demand	0-Pmax	U3	UINT16	R	
9656-9663		TOU Maximum Demand Register #7^E					
+0	0x5300	Tariff #1 maximum demand	0-Pmax	U3	UINT16	R	
+1	0x5301	Tariff #2 maximum demand	0-Pmax	U3	UINT16	R	
		...				R	
+7	0x5307	Tariff #8 maximum demand	0-Pmax	U3	UINT16	R	
9676-9683		TOU Maximum Demand Register #8^E					
+0	0x5380	Tariff #1 maximum demand	0-Pmax	U3	UINT16	R	
+1	0x5381	Tariff #2 maximum demand	0-Pmax	U3	UINT16	R	
		...				R	
+7	0x5387	Tariff #8 maximum demand	0-Pmax	U3	UINT16	R	
10656-10695		V1/V12 Harmonic Angles^{EH}					1, 3
+0	0x6400	H01 Harmonic angle	-180.0-180.0	0.1°	INT16	R	
+1	0x6401	H02 Harmonic angle	-180.0-180.0	0.1°	INT16	R	
		...					
+39	0x6427	H40 Harmonic angle	-180.0-180.0	0.1°	INT16	R	
10696-10735		V2/V23 Harmonic Angles^{EH}					1, 3
+0	0x6500	H01 Harmonic angle	-180.0-180.0	0.1°	INT16	R	
+1	0x6501	H02 Harmonic angle	-180.0-180.0	0.1°	INT16	R	
		...					
+39	0x6527	H40 Harmonic angle	-180.0-180.0	0.1°	INT16	R	
10736-10775		V1/V31 Harmonic Angles^{EH}					1, 3
+0	0x6600	H01 Harmonic angle	-180.0-180.0	0.1°	INT16	R	
+1	0x6601	H02 Harmonic angle	-180.0-180.0	0.1°	INT16	R	
		...					
+39	0x6627	H40 Harmonic angle	-180.0-180.0	0.1°	INT16	R	
10816-10855		I1 Harmonic Angles^{EH}					3
+0	0x6800	H01 Harmonic angle	-180.0-180.0	0.1°	INT16	R	
+1	0x6801	H02 Harmonic angle	-180.0-180.0	0.1°	INT16	R	
		...					
+39	0x6827	H40 Harmonic angle	-180.0-180.0	0.1°	INT16	R	
10856-10895		I2 Harmonic Angles^{EH}					3
+0	0x6900	H01 Harmonic angle	-180.0-180.0	0.1°	INT16	R	
+1	0x6901	H02 Harmonic angle	-180.0-180.0	0.1°	INT16	R	
		...					
+39	0x6927	H40 Harmonic angle	-180.0-180.0	0.1°	INT16	R	
10896-10935		I3 Harmonic Angles^{EH}					3
+0	0x6A00	H01 Harmonic angle	-180.0-180.0	0.1°	INT16	R	

Address	Point ID	Description	Low and High Scales ²	Units ²	Type	R/W	Notes
+1	0x6A01	H02 Harmonic angle	-180.0-180.0	0.1°	INT16	R	
		...					
+39	0x6A27	H40 Harmonic angle	-180.0-180.0	0.1°	INT16	R	
11616	0x7C00	Setpoint Status (bitmap)	0x0000-0xFFFF		UINT16	R	

NOTES:

Energy and Power demand readings are only available in the meters with suffixes E and EH.

¹ Voltage and Voltage Harmonics Readings:

When the 4LN3, 3LN3 or 3BLN3 wiring mode is selected, the voltages will be line-to-neutral; for any other wiring mode, they will be line-to-line voltages.

When the 4LN3, 4LL3, 3LN3, 3LL3, 3BLN3 or 3BLL3 wiring mode is selected, the voltage harmonics will be line-to-neutral; for any other wiring mode, they will be line-to-line.

² For volts, amps, power and frequency scales and units refer to Section 4 "Data Scales and Units". For analog data scaling formulas and examples, see Section 2.6.1, "16-bit Scaled Integer Format".

³ Harmonic angles are referenced to the fundamental voltage harmonic H01 on phase L1.

3.4 32-bit Analog Registers, Binary Registers and Counters

Address	Point ID	Description	Options/Range ²	Units ²	Type	R/W	Notes
11776-11777	0x0000	None	0		UINT32	R	
11904-11907		Special Inputs					
+0,1	0x0100	Voltage disturbance ^{EH}	0-100	%	UINT32	R	
+2,3	0x0101	Phase rotation order	0=error, 1=positive (ABC), 2=negative (CBA)		UINT32	R	
12160-12161	0x0300	Event Flags (bitmap) ^{EH}	0x00000000-0x000000FF		UINT32	R	
12544-12545	0x0600	Digital Inputs DI1-DI2 (bitmap)	0x00000000-0x00000003		UINT32	R	
12800-12801	0x0800	Relay Outputs RO1-RO2 (bitmap)	0x00000000-0x00000003		UINT32	R	
13056-13063		Counters					
+0,1	0x0A00	Counter #1	0-999,999		UINT32	R/W	
+2,3	0x0A01	Counter #2	0-999,999		UINT32	R/W	
+4,5	0x0A02	Counter #3	0-999,999		UINT32	R/W	
+6,7	0x0A03	Counter #4	0-999,999		UINT32	R/W	
13312-13377		1-Cycle Phase Values					
+0,1	0x0C00	V1/V12 Voltage	0-Vmax	U1	UINT32	R	¹
+2,3	0x0C01	V2/V23 Voltage	0-Vmax	U1	UINT32	R	¹
+4,5	0x0C02	V3/V31 Voltage	0-Vmax	U1	UINT32	R	¹
+6,7	0x0C03	I1 Current	0-Imax	U2	UINT32	R	
+8,9	0x0C04	I2 Current	0-Imax	U2	UINT32	R	
+10,11	0x0C05	I3 Current	0-Imax	U2	UINT32	R	
+12,13	0x0C06	kW L1	-Pmax-Pmax	U3	INT32	R	
+14,15	0x0C07	kW L2	-Pmax-Pmax	U3	INT32	R	
+16,17	0x0C08	kW L3	-Pmax-Pmax	U3	INT32	R	
+18,19	0x0C09	kvar L1	-Pmax-Pmax	U3	INT32	R	
+20,21	0x0C0A	kvar L2	-Pmax-Pmax	U3	INT32	R	
+22,23	0x0C0B	kvar L3	-Pmax-Pmax	U3	INT32	R	
+24,25	0x0C0C	kVA L1	0-Pmax	U3	UINT32	R	
+26,27	0x0C0D	kVA L2	0-Pmax	U3	UINT32	R	
+28,29	0x0C0E	kVA L3	0-Pmax	U3	UINT32	R	
+30,31	0x0C0F	Power factor L1	-1000-1000	×0.001	INT32	R	
+32,33	0x0C10	Power factor L2	-1000-1000	×0.001	INT32	R	
+34,35	0x0C11	Power factor L3	-1000-1000	×0.001	INT32	R	
+36,37	0x0C12	V1/V12 Voltage THD	0-9999	×0.1%	UINT32	R	¹ 4-cycle value
+38,39	0x0C13	V2/V23 Voltage THD	0-9999	×0.1%	UINT32	R	¹ 4-cycle value
+40,41	0x0C14	V3/V31 Voltage THD	0-9999	×0.1%	UINT32	R	¹ 4-cycle value
+42,43	0x0C15	I1 Current THD	0-9999	×0.1%	UINT32	R	4-cycle value
+44,45	0x0C16	I2 Current THD	0-9999	×0.1%	UINT32	R	4-cycle value
+46,47	0x0C17	I3 Current THD	0-9999	×0.1%	UINT32	R	4-cycle value
+48,49	0x0C18	I1 K-Factor	10-9999	×0.1	UINT32	R	4-cycle value

Address	Point ID	Description	Options/Range ²	Units ²	Type	R/W	Notes
+50,51	0x0C19	I2 K-Factor	10-9999	×0.1	UINT32	R	4-cycle value
+52,53	0x0C1A	I3 K-Factor	10-9999	×0.1	UINT32	R	4-cycle value
+54,55	0x0C1B	I1 Current TDD	0-1000	×0.1%	UINT32	R	4-cycle value
+56,57	0x0C1C	I2 Current TDD	0-1000	×0.1%	UINT32	R	4-cycle value
+58,59	0x0C1D	I3 Current TDD	0-1000	×0.1%	UINT32	R	4-cycle value
+60,61	0x0C1E	V12 Voltage	0-Vmax	U1	UINT32	R	
+62,63	0x0C1F	V23 Voltage	0-Vmax	U1	UINT32	R	
+64,65	0x0C20	V31 Voltage	0-Vmax	U1	UINT32	R	
13696-13703		1-Cycle Total Values					
+0,1	0x0F00	Total kW	-Pmax-Pmax	U3	INT32	R	
+2,3	0x0F01	Total kvar	-Pmax-Pmax	U3	INT32	R	
+4,5	0x0F02	Total kVA	0-Pmax	U3	UINT32	R	
+6,7	0x0F03	Total PF	-1000-1000	×0.001	INT32	R	
+8,9	0x0F04	Total PF lag	0-1000	×0.001	UINT16	R	
+10,11	0x0F05	Total PF lead	0-1000	×0.001	UINT16	R	
+12,13	0x0F06	Total kW import	0-Pmax	U3	UINT32	R	
+14,15	0x0F07	Total kW export	0-Pmax	U3	UINT32	R	
+16,17	0x0F08	Total kvar import	0-Pmax	U3	UINT32	R	
+18,19	0x0F09	Total kvar export	0-Pmax	U3	UINT32	R	
+20,21	0x0FOA	3-phase average L-N/L-L voltage	0-Vmax	U1	UINT32	R	1
+22,23	0x0FOB	3-phase average L-L voltage	0-Vmax	U1	UINT32	R	
+24,25	0x0FOC	3-phase average current	0-Imax	U2	UINT32	R	
13824-13833		1-Cycle Auxiliary Values					
+0,1	0x1000	Not used			UINT32	R	
+2,3	0x1001	In (neutral) Current	0-Imax	U2	UINT32	R	
+4,5	0x1002	Frequency	0-Fmax	×0.01Hz	UINT32	R	
+6,7	0x1003	Voltage unbalance	0-300	%	UINT32	R	
+8,9	0x1004	Current unbalance	0-300	%	UINT32	R	
13864-13895		Phasor					
+0,1	0x1080	V1/V12 Voltage magnitude	0-Vmax	U1	UINT32	R	1
+2,3	0x1081	V2/V23 Voltage magnitude	0-Vmax	U1	UINT32	R	1
+4,5	0x1082	V3/V31 Voltage magnitude	0-Vmax	U1	UINT32	R	1
+6,7	0x1083	Not used			UINT32	R	
+8,9	0x1084	I1 Current magnitude	0-Imax	U2	UINT32	R	
+10,11	0x1085	I2 Current magnitude	0-Imax	U2	UINT32	R	
+12,13	0x1086	I3 Current magnitude	0-Imax	U2	UINT32	R	
+14,15	0x1087	Not used			UINT32	R	
+16,17	0x1088	V1/V12 Voltage angle	-1800-1800	×0.1°	INT32	R	1
+18,19	0x1089	V2/V23 Voltage angle	-1800-1800	×0.1°	INT32	R	1
+20,21	0x108A	V3/V31 Voltage angle	-1800-1800	×0.1°	INT32	R	1
+22,23	0x108B	Not used			INT32	R	
+24,25	0x108C	I1 Current angle	-1800-1800	×0.1°	INT32	R	
+26,27	0x108D	I2 Current angle	-1800-1800	×0.1°	INT32	R	

Address	Point ID	Description	Options/Range ²	Units ²	Type	R/W	Notes
+28,29	0x108E	I3 Current angle	-1800-1800	×0.1°	INT32	R	
+30,31	0x108F	Not used			INT32	R	
13952-14017		1-Second Phase Values					
+0,1	0x1100	V1/V12 Voltage	0-Vmax	U1	UINT32	R	1
+2,3	0x1101	V2/V23 Voltage	0-Vmax	U1	UINT32	R	1
+4,5	0x1102	V3/V31 Voltage	0-Vmax	U1	UINT32	R	1
+6,7	0x1103	I1 Current	0-Imax	U2	UINT32	R	
+8,9	0x1104	I2 Current	0-Imax	U2	UINT32	R	
+10,11	0x1105	I3 Current	0-Imax	U2	UINT32	R	
+12,13	0x1106	kW L1	-Pmax-Pmax	U3	INT32	R	
+14,15	0x1107	kW L2	-Pmax-Pmax	U3	INT32	R	
+16,17	0x1108	kW L3	-Pmax-Pmax	U3	INT32	R	
+18,19	0x1109	kvar L1	-Pmax-Pmax	U3	INT32	R	
+20,21	0x110A	kvar L2	-Pmax-Pmax	U3	INT32	R	
+22,23	0x110B	kvar L3	-Pmax-Pmax	U3	INT32	R	
+24,25	0x110C	kVA L1	0-Pmax	U3	UINT32	R	
+26,27	0x110D	kVA L2	0-Pmax	U3	UINT32	R	
+28,29	0x110E	kVA L3	0-Pmax	U3	UINT32	R	
+30,31	0x110F	Power factor L1	-1000-1000	×0.001	INT32	R	
+32,33	0x1110	Power factor L2	-1000-1000	×0.001	INT32	R	
+34,35	0x1111	Power factor L3	-1000-1000	×0.001	INT32	R	
+36,37	0x1112	V1/V12 Voltage THD	0-9999	×0.1%	UINT32	R	1 3-sec value
+38,39	0x1113	V2/V23 Voltage THD	0-9999	×0.1%	UINT32	R	1 3-sec value
+40,41	0x1114	V3/V31 Voltage THD	0-9999	×0.1%	UINT32	R	1 3-sec value
+42,43	0x1115	I1 Current THD	0-9999	×0.1%	UINT32	R	3-sec value
+44,45	0x1116	I2 Current THD	0-9999	×0.1%	UINT32	R	3-sec value
+46,47	0x1117	I3 Current THD	0-9999	×0.1%	UINT32	R	3-sec value
+48,49	0x1118	I1 K-Factor	10-9999	×0.1	UINT32	R	3-sec value
+50,51	0x1119	I2 K-Factor	10-9999	×0.1	UINT32	R	3-sec value
+52,53	0x111A	I3 K-Factor	10-9999	×0.1	UINT32	R	3-sec value
+54,55	0x111B	I1 Current TDD	0-1000	×0.1%	UINT32	R	3-sec value
+56,57	0x111C	I2 Current TDD	0-1000	×0.1%	UINT32	R	3-sec value
+58,59	0x111D	I3 Current TDD	0-1000	×0.1%	UINT32	R	3-sec value
+60,61	0x111E	V12 Voltage	0-Vmax	U1	UINT32	R	
+62,63	0x111F	V23 Voltage	0-Vmax	U1	UINT32	R	
+64,65	0x1120	V31 Voltage	0-Vmax	U1	UINT32	R	
14336-14343		1-Second Total Values					
+0,1	0x1400	Total kW	-Pmax-Pmax	U3	INT32	R	
+2,3	0x1401	Total kvar	-Pmax-Pmax	U3	INT32	R	
+4,5	0x1402	Total kVA	0-Pmax	U3	UINT32	R	
+6,7	0x1403	Total PF	-1000-1000	×0.001	INT32	R	
+8,9	0x1404	Total PF lag	0-1000	×0.001	UINT16	R	
+10,11	0x1405	Total PF lead	0-1000	×0.001	UINT16	R	

Address	Point ID	Description	Options/Range ²	Units ²	Type	R/W	Notes
+12,13	0x1406	Total kW import	0-Pmax	U3	UINT32	R	
+14,15	0x1407	Total kW export	0-Pmax	U3	UINT32	R	
+16,17	0x1408	Total kvar import	0-Pmax	U3	UINT32	R	
+18,19	0x1409	Total kvar export	0-Pmax	U3	UINT32	R	
+20,21	0x140A	3-phase average L-N/L-L voltage	0-Vmax	U1	UINT32	R	1
+22,23	0x140B	3-phase average L-L voltage	0-Vmax	U1	UINT32	R	
+24,25	0x140C	3-phase average current	0-Imax	U2	UINT32	R	
14464-14473		1-Second Auxiliary Values					
+0,1	0x1500	Not used			UINT32	R	
+2,3	0x1501	In (neutral) Current	0-Imax	U2	UINT32	R	
+4,5	0x1502	Frequency	0-Fmax	×0.01Hz	UINT32	R	
+6,7	0x1503	Voltage unbalance	0-300	%	UINT32	R	
+8,9	0x1504	Current unbalance	0-300	%	UINT32	R	
14504-14527		Present Harmonic Demands					
+0,1	0x1580	V1/V12 THD demand	0-9999	×0.1%	UINT32	R	1
+2,3	0x1581	V2/V23 THD demand	0-9999	×0.1%	UINT32	R	1
+4,5	0x1582	V3/V31 THD demand	0-9999	×0.1%	UINT32	R	1
+6,7	0x1583	Not used			UINT32	R	
+8,9	0x1584	I1 THD demand	0-9999	×0.1%	UINT32	R	
+10,11	0x1585	I2 THD demand	0-9999	×0.1%	UINT32	R	
+12,13	0x1586	I3 THD demand	0-9999	×0.1%	UINT32	R	
+14,15	0x1587	Not used			UINT32	R	
+16,17	0x1588	I1 TDD demand	0-1000	×0.1%	UINT32	R	
+18,19	0x1589	I2 TDD demand	0-1000	×0.1%	UINT32	R	
+20,21	0x158A	I3 TDD demand	0-1000	×0.1%	UINT32	R	
+22,23	0x158B	Not used			UINT32	R	
14592-14651		Present Volt, Ampere and Power Demands					
+0,1	0x1600	V1/V12 Volt demand	0-Vmax	U1	UINT32	R	1
+2,3	0x1601	V2/V23 Volt demand	0-Vmax	U1	UINT32	R	1
+4,5	0x1602	V3/V31 Volt demand	0-Vmax	U1	UINT32	R	1
+6,7	0x1603	I1 Ampere demand	0-Imax	U2	UINT32	R	
+8,9	0x1604	I2 Ampere demand	0-Imax	U2	UINT32	R	
+10,11	0x1605	I3 Ampere demand	0-Imax	U2	UINT32	R	
+12,13	0x1606	kW import block demand	0-Pmax	U3	UINT32	R	
+14,15	0x1607	kvar import block demand	0-Pmax	U3	UINT32	R	
+16,17	0x1608	kVA block demand	0-Pmax	U3	UINT32	R	
+18,19	0x1609	kW import sliding window demand	0-Pmax	U3	UINT32	R	
+20,21	0x160A	kvar import sliding window demand	0-Pmax	U3	UINT32	R	
+22,23	0x160B	kVA sliding window demand	0-Pmax	U3	UINT32	R	
+24,25	0x160C	Not used			UINT32	R	
+26,27	0x160D	Not used			UINT32	R	
+28,29	0x160E	Not used			UINT32	R	
+30,31	0x160F	kW import accumulated demand	0-Pmax	U3	UINT32	R	

Address	Point ID	Description	Options/Range ²	Units ²	Type	R/W	Notes
+32,33	0x1610	kvar import accumulated demand	0-Pmax	U3	UINT32	R	
+34,35	0x1611	kVA accumulated demand	0-Pmax	U3	UINT32	R	
+36,37	0x1612	kW import predicted sliding window demand	0-Pmax	U3	UINT32	R	
+38,39	0x1613	kvar import predicted sliding window demand	0-Pmax	U3	UINT32	R	
+40,41	0x1614	kVA predicted sliding window demand	0-Pmax	U3	UINT32	R	
+42,43	0x1615	PF (import) at Max. kVA sliding window demand	0-1000	×0.001	UINT32	R	
+44,45	0x1616	kW export block demand	0-Pmax	U3	UINT32	R	
+46,47	0x1617	kvar export block demand	0-Pmax	U3	UINT32	R	
+48,49	0x1618	kW export sliding window demand	0-Pmax	U3	UINT32	R	
+50,51	0x1619	kvar export sliding window demand	0-Pmax	U3	UINT32	R	
+52,53	0x161A	kW export accumulated demand	0-Pmax	U3	UINT32	R	
+54,55	0x161B	kvar export accumulated demand	0-Pmax	U3	UINT32	R	
+56,57	0x161C	kW export predicted sliding window demand	0-Pmax	U3	UINT32	R	
+58,59	0x161D	kvar export predicted sliding window demand	0-Pmax	U3	UINT32	R	
14720-14755		Total Energies^E					
+0,1	0x1700	kWh import	0-10 ⁹ -1	1 kWh	UINT32	R	
+2,3	0x1701	kWh export	0-10 ⁹ -1	1 kWh	UINT32	R	
+4,5	0x1702	Not used			INT32	R	
+6,7	0x1703	Not used			UINT32	R	
+8,9	0x1704	kvarh import	0-10 ⁹ -1	1 kvarh	UINT32	R	
+10,11	0x1705	kvarh export	0-10 ⁹ -1	1 kvarh	UINT32	R	
+12,13	0x1706	Not used			INT32	R	
+14,15	0x1707	Not used			UINT32	R	
+16,17	0x1708	kVAh total	0-10 ⁹ -1	1 kVAh	UINT32	R	
+18-25		Not used			UINT32	R	
+26,27	0x170D	Harmonic kWh import ^{EH}	0-10 ⁹ -1	1 kWh	UINT32	R	
+28,29	0x170E	Harmonic kWh export ^{EH}	0-10 ⁹ -1	1 kWh	UINT32	R	
+30-33		Not used			UINT32	R	
+34,35	0x1711	Harmonic kVAh total ^{EH}	0-10 ⁹ -1	1 kVAh	UINT32	R	
14760-14775		Summary Energy Registers^E					
+0,1	0x1780	Summary energy register #1	0-10 ⁹ -1	1 kWh	UINT32	R	
+2,3	0x1781	Summary energy register #2	0-10 ⁹ -1	1 kWh	UINT32	R	
		...					
+14,15	0x1787	Summary energy register #16	0-10 ⁹ -1	1 kWh	UINT32	R	
14848-14865		Phase Energies^E					
+0,1	0x1800	kWh import L1	0-10 ⁹ -1	1 kWh	UINT32	R	
+2,3	0x1801	kWh import L2	0-10 ⁹ -1	1 kWh	UINT32	R	
+4,5	0x1802	kWh import L3	0-10 ⁹ -1	1 kWh	UINT32	R	
+6,7	0x1803	kvarh import L1	0-10 ⁹ -1	1 kvarh	UINT32	R	
+8,9	0x1804	kvarh import L2	0-10 ⁹ -1	1 kvarh	UINT32	R	
+10,11	0x1805	kvarh import L3	0-10 ⁹ -1	1 kvarh	UINT32	R	

Address	Point ID	Description	Options/Range ²	Units ²	Type	R/W	Notes
+12,13	0x1806	kVAh total L1	0-10 ⁹ -1	1 kVAh	UINT32	R	
+14,15	0x1807	kVAh total L2	0-10 ⁹ -1	1 kVAh	UINT32	R	
+16,17	0x1808	kVAh total L3	0-10 ⁹ -1	1 kVAh	UINT32	R	
14976-15055		V1/V12 Harmonic Distortions ^{EH}					1
+0,1	0x1900	H01 Harmonic distortion	0-10000	0.01%	UINT32	R	
+2,3	0x1901	H02 Harmonic distortion	0-10000	0.01%	UINT32	R	
		...					
+78,79	0x1927	H40 Harmonic distortion	0-10000	0.01%	UINT32	R	
15104-15183		V2/V23 Harmonic Distortions ^{EH}					1
+0,1	0x1A00	H01 Harmonic distortion	0-10000	0.01%	UINT32	R	
+2,3	0x1A01	H02 Harmonic distortion	0-10000	0.01%	UINT32	R	
		...					
+78,79	0x1A27	H40 Harmonic distortion	0-10000	0.01%	UINT32	R	
15232-15311		V3/V31 Harmonic Distortions ^{EH}					1
+0,1	0x1B00	H01 Harmonic distortion	0-10000	0.01%	UINT32	R	
+2,3	0x1B01	H02 Harmonic distortion	0-10000	0.01%	UINT32	R	
		...					
+78,79	0x1B27	H40 Harmonic distortion	0-10000	0.01%	UINT32	R	
15360-15439		I1 Harmonic Distortions ^{EH}					
+0,1	0x1C00	H01 Harmonic distortion	0-10000	0.01%	UINT32	R	
+2,3	0x1C01	H02 Harmonic distortion	0-10000	0.01%	UINT32	R	
		...					
+78,79	0x1C27	H40 Harmonic distortion	0-10000	0.01%	UINT32	R	
15488-15567		I2 Harmonic Distortions ^{EH}					
+0,1	0x1D00	H01 Harmonic distortion	0-10000	0.01%	UINT32	R	
+2,3	0x1D01	H02 Harmonic distortion	0-10000	0.01%	UINT32	R	
		...					
+78,79	0x1D27	H40 Harmonic distortion	0-10000	0.01%	UINT32	R	
15616-15695		I3 Harmonic Distortions ^{EH}					
+0,1	0x1E00	H01 Harmonic distortion	0-10000	0.01%	UINT32	R	
+2,3	0x1E01	H02 Harmonic distortion	0-10000	0.01%	UINT32	R	
		...					
+78,79	0x1E27	H40 Harmonic distortion	0-10000	0.01%	UINT32	R	
17024-17059		Fundamental (H01) Phase Values					4-cycle values
+0,1	0x2900	V1/V12 Voltage	0-Vmax	U1	UINT32	R	1
+2,3	0x2901	V2/V23 Voltage	0-Vmax	U1	UINT32	R	1
+4,5	0x2902	V3/V31 Voltage	0-Vmax	U1	UINT32	R	1
+6,7	0x2903	I1 Current	0-Imax	U2	UINT32	R	
+8,9	0x2904	I2 Current	0-Imax	U2	UINT32	R	
+10,11	0x2905	I3 Current	0-Imax	U2	UINT32	R	
+12,13	0x2906	kW L1	-Pmax-Pmax	U3	INT32	R	

Address	Point ID	Description	Options/Range ²	Units ²	Type	R/W	Notes
+14,15	0x2907	kW L2	-Pmax-Pmax	U3	INT32	R	
+16,17	0x2908	kW L3	-Pmax-Pmax	U3	INT32	R	
+18,19	0x2909	kvar L1	-Pmax-Pmax	U3	INT32	R	
+20,21	0x290A	kvar L2	-Pmax-Pmax	U3	INT32	R	
+22,23	0x290B	kvar L3	-Pmax-Pmax	U3	INT32	R	
+24,25	0x290C	kVA L1	0-Pmax	U3	UINT32	R	
+26,27	0x290D	kVA L2	0-Pmax	U3	UINT32	R	
+28,29	0x290E	kVA L3	0-Pmax	U3	UINT32	R	
+30,31	0x290F	Power factor L1	-1000-1000	×0.001	INT32	R	
+32,33	0x2910	Power factor L2	-1000-1000	×0.001	INT32	R	
+34,35	0x2911	Power factor L3	-1000-1000	×0.001	INT32	R	
17152-17164		Harmonic Total Values					4-cycle values
+0,1	0x2A00	Total fundamental kW	-Pmax-Pmax	U3	INT32	R	
+2,3	0x2A01	Total fundamental kvar	-Pmax-Pmax	U3	INT32	R	
+4,5	0x2A02	Total fundamental kVA	0-Pmax	U3	UINT32	R	
+6,7	0x2A03	Total fundamental PF	-1000-1000	×0.001	INT32	R	
+8,9	0x2A04	Total harmonic kW ^{EH}	-Pmax-Pmax	U3	INT32	R	
+10,11	0x2A05	Not used			INT32	R	
+12,13	0x2A06	Total harmonic kVA ^{EH}	0-Pmax	U3	UINT32	R	
+14,15	0x2A07	Not used			INT32	R	
17408-17467		Minimum 1-Cycle Phase Values					
+0,1	0x2C00	V1/V12 Voltage	0-Vmax	U1	UINT32	R	¹
+2,3	0x2C01	V2/V23 Voltage	0-Vmax	U1	UINT32	R	¹
+4,5	0x2C02	V3/V31 Voltage	0-Vmax	U1	UINT32	R	¹
+6,7	0x2C03	I1 Current	0-Imax	U2	UINT32	R	
+8,9	0x2C04	I2 Current	0-Imax	U2	UINT32	R	
+10,11	0x2C05	I3 Current	0-Imax	U2	UINT32	R	
+12-35	0x2C06- 0x2C11	Not used	0		INT32	R	
+36,37	0x2C12	V1/V12 Voltage THD	0-9999	×0.1%	UINT32	R	¹ 4-cycle value
+38,39	0x2C13	V2/V23 Voltage THD	0-9999	×0.1%	UINT32	R	¹ 4-cycle value
+40,41	0x2C14	V3/V31 Voltage THD	0-9999	×0.1%	UINT32	R	¹ 4-cycle value
+42,43	0x2C15	I1 Current THD	0-9999	×0.1%	UINT32	R	4-cycle value
+44,45	0x2C16	I2 Current THD	0-9999	×0.1%	UINT32	R	4-cycle value
+46,47	0x2C17	I3 Current THD	0-9999	×0.1%	UINT32	R	4-cycle value
+48,49	0x2C18	I1 K-Factor	10-9999	×0.1	UINT32	R	4-cycle value
+50,51	0x2C19	I2 K-Factor	10-9999	×0.1	UINT32	R	4-cycle value
+52,53	0x2C1A	I3 K-Factor	10-9999	×0.1	UINT32	R	4-cycle value
+54,55	0x2C1B	I1 Current TDD	0-1000	×0.1%	UINT32	R	4-cycle value
+56,57	0x2C1C	I2 Current TDD	0-1000	×0.1%	UINT32	R	4-cycle value
+58,59	0x2C1D	I3 Current TDD	0-1000	×0.1%	UINT32	R	4-cycle value
17536-17543		Minimum 1-Cycle Total Values					
+0,1	0x2D00	Total kW	-Pmax-Pmax	U3	INT32	R	

Address	Point ID	Description	Options/Range ²	Units ²	Type	R/W	Notes
+2,3	0x2D01	Total kvar	-Pmax-Pmax	U3	INT32	R	
+4,5	0x2D02	Total kVA	0-Pmax	U3	UINT32	R	
+6,7	0x2D03	Total PF	0-1000	×0.001	UINT32	R	Absolute value
17664-17669		Minimum 1-Cycle Auxiliary Values					
+0,1	0x2E00	Not used			UINT32	R	
+2,3	0x2E01	In Current	0-Imax	U2	UINT32	R	
+4,5	0x2E02	Frequency	0-Fmax	×0.01Hz	UINT32	R	
18432-18491		Maximum 1-Cycle Phase Values					
+0,1	0x3400	V1/V12 Voltage	0-Vmax	U1	UINT32	R	¹
+2,3	0x3401	V2/V23 Voltage	0-Vmax	U1	UINT32	R	¹
+4,5	0x3402	V3/V31 Voltage	0-Vmax	U1	UINT32	R	¹
+6,7	0x3403	I1 Current	0-Imax	U2	UINT32	R	
+8,9	0x3404	I2 Current	0-Imax	U2	UINT32	R	
+10,11	0x3405	I3 Current	0-Imax	U2	UINT32	R	
+12-35	0x3406- 0x3411	Not used	0		INT32	R	
+36,37	0x3412	V1/V12 Voltage THD	0-9999	×0.1%	UINT32	R	¹ 4-cycle value
+38,39	0x3413	V2/V23 Voltage THD	0-9999	×0.1%	UINT32	R	¹ 4-cycle value
+40,41	0x3414	V3/V31 Voltage THD	0-9999	×0.1%	UINT32	R	¹ 4-cycle value
+42,43	0x3415	I1 Current THD	0-9999	×0.1%	UINT32	R	4-cycle value
+44,45	0x3416	I2 Current THD	0-9999	×0.1%	UINT32	R	4-cycle value
+46,47	0x3417	I3 Current THD	0-9999	×0.1%	UINT32	R	4-cycle value
+48,49	0x3418	I1 K-Factor	10-9999	×0.1	UINT32	R	4-cycle value
+50,51	0x3419	I2 K-Factor	10-9999	×0.1	UINT32	R	4-cycle value
+52,53	0x341A	I3 K-Factor	10-9999	×0.1	UINT32	R	4-cycle value
+54,55	0x341B	I1 Current TDD	0-1000	×0.1%	UINT32	R	4-cycle value
+56,57	0x341C	I2 Current TDD	0-1000	×0.1%	UINT32	R	4-cycle value
+58,59	0x341D	I3 Current TDD	0-1000	×0.1%	UINT32	R	4-cycle value
18560-18567		Maximum 1-Cycle Total Values					
+0,1	0x3500	Total kW	-Pmax-Pmax	U3	INT32	R	
+2,3	0x3501	Total kvar	-Pmax-Pmax	U3	INT32	R	
+4,5	0x3502	Total kVA	0-Pmax	U3	UINT32	R	
+6,7	0x3503	Total PF	0-1000	×0.001	UINT32	R	Absolute value
18688-18693		Maximum 1-Cycle Auxiliary Values					
+0,1	0x3600	Not used			UINT32	R	
+2,3	0x3601	In Current	0-Imax	U2	UINT32	R	
+4,5	0x3602	Frequency	0-Fmax	×0.01Hz	UINT32	R	
18816-18849		Maximum Demands					
+0,1	0x3700	V1/V12 Maximum volt demand	0-Vmax	U1	UINT32	R	¹
+2,3	0x3701	V2/V23 Maximum volt demand	0-Vmax	U1	UINT32	R	¹
+4,5	0x3702	V3/V31 Maximum volt demand	0-Vmax	U1	UINT32	R	¹
+6,7	0x3703	I1 Maximum ampere demand	0-Imax	U2	UINT32	R	
+8,9	0x3704	I2 Maximum ampere demand	0-Imax	U2	UINT32	R	

Address	Point ID	Description	Options/Range ²	Units ²	Type	R/W	Notes
+10,11	0x3705	I3 Maximum ampere demand	0-Imax	U2	UINT32	R	
+12,13	0x3706	Not used			UINT32	R	
+14,15	0x3707	Not used			UINT32	R	
+16,17	0x3708	Not used			UINT32	R	
+18,19	0x3709	Maximum kW import sliding window demand	0-Pmax	U3	UINT32	R	
+20,21	0x370A	Maximum kvar import sliding window demand	0-Pmax	U3	UINT32	R	
+22,23	0x370B	Maximum kVA sliding window demand	0-Pmax	U3	UINT32	R	
+24,25	0x3737	Not used			UINT32	R	
+26,27	0x370D	Not used			UINT32	R	
+28,29	0x370E	Not used			UINT32	R	
+30,31	0x370F	Maximum kW export sliding window demand	0-Pmax	U3	UINT32	R	
+32,33	0x3710	Maximum kvar export sliding window demand	0-Pmax	U3	UINT32	R	
18984-19007		Maximum Harmonic Demands					
+0,1	0x3880	V1/V12 THD demand	0-9999	×0.1%	UINT32	R	1
+2,3	0x3881	V2/V23 THD demand	0-9999	×0.1%	UINT32	R	1
+4,5	0x3882	V3/V31 THD demand	0-9999	×0.1%	UINT32	R	1
+6,7	0x3883	Not used			UINT32	R	
+8,9	0x3884	I1 THD demand	0-9999	×0.1%	UINT32	R	
+10,11	0x3885	I2 THD demand	0-9999	×0.1%	UINT32	R	
+12,13	0x3886	I3 THD demand	0-9999	×0.1%	UINT32	R	
+14,15	0x3887	Not used			UINT32	R	
+16,17	0x3888	I1 TDD demand	0-1000	×0.1%	UINT32	R	
+18,19	0x3889	I2 TDD demand	0-1000	×0.1%	UINT32	R	
+20,21	0x388A	I3 TDD demand	0-1000	×0.1%	UINT32	R	
+22,23	0x388B	Not used			UINT32	R	
19328-19359		Scaled Analog Inputs					
+0,1	0x3B00	Analog input AI1	AI1min-AI1Max		UINT32	R	
+2,3	0x3B01	Analog input AI2	AI2min-AI2Max		UINT32	R	
19368-19371		Raw Analog Inputs					
+0,1	0x3B80	Analog input AI1	0-4095		UINT32	R	
+2,3	0x3B81	Analog input AI2	0-4095		UINT32	R	
19456-19459		TOU Parameters^E					
+0,1	0x3C00	Active tariff	0-7		UINT32	R	
+2,3	0x3C01	Active profile	0-15: 1-3 = Season 1 Profile #1-4, 4-7 = Season 2 Profile #1-4, 8-11 = Season 3 Profile #1-4, 12-15 = Season 4 Profile #1-4		UINT32	R	
19496-19499		Scaled Analog Outputs					
+0,1	0x3C80	Analog output AO1	0-4095		UINT32	R/W	
+2,3	0x3C81	Analog output AO2	0-4095		UINT32	R/W	
19584-19599		TOU Energy Register #1^E					
+0,1	0x3D00	Tariff #1 register	0-10 ⁹ -1	1 kWh	UINT32	R	

Address	Point ID	Description	Options/Range ²	Units ²	Type	R/W	Notes
+2,3	0x3D01	Tariff #2 register	0-10 ⁹ -1	1 kWh	UINT32	R	
		...				R	
+14,15	0x3D07	Tariff #8 register	0-10 ⁹ -1	1 kWh	UINT32	R	
19712-19727		TOU Energy Register #2^E					
+0,1	0x3E00	Tariff #1 register	0-10 ⁹ -1	1 kWh	UINT32	R	
+2,3	0x3E01	Tariff #2 register	0-10 ⁹ -1	1 kWh	UINT32	R	
		...				R	
+14,15	0x3E07	Tariff #8 register	0-10 ⁹ -1	1 kWh	UINT32	R	
19840-19855		TOU Energy Register #3^E					
+0,1	0x3F00	Tariff #1 register	0-10 ⁹ -1	1 kWh	UINT32	R	
+2,3	0x3F01	Tariff #2 register	0-10 ⁹ -1	1 kWh	UINT32	R	
		...				R	
+14,15	0x3F07	Tariff #8 register	0-10 ⁹ -1	1 kWh	UINT32	R	
19968-19983		TOU Energy Register #4^E					
+0,1	0x4000	Tariff #1 register	0-10 ⁹ -1	1 kWh	UINT32	R	
+2,3	0x4001	Tariff #2 register	0-10 ⁹ -1	1 kWh	UINT32	R	
		...				R	
+14,15	0x4007	Tariff #8 register	0-10 ⁹ -1	1 kWh	UINT32	R	
20096-20111		TOU Energy Register #5^E					
+0,1	0x4100	Tariff #1 register	0-10 ⁹ -1	1 kWh	UINT32	R	
+2,3	0x4101	Tariff #2 register	0-10 ⁹ -1	1 kWh	UINT32	R	
		...				R	
+14,15	0x4107	Tariff #8 register	0-10 ⁹ -1	1 kWh	UINT32	R	
20224-20239		TOU Energy Register #6^E					
+0,1	0x4200	Tariff #1 register	0-10 ⁹ -1	1 kWh	UINT32	R	
+2,3	0x4201	Tariff #2 register	0-10 ⁹ -1	1 kWh	UINT32	R	
		...				R	
+14,15	0x4207	Tariff #8 register	0-10 ⁹ -1	1 kWh	UINT32	R	
20352-20367		TOU Energy Register #7^E					
+0,1	0x4300	Tariff #1 register	0-10 ⁹ -1	1 kWh	UINT32	R	
+2,3	0x4301	Tariff #2 register	0-10 ⁹ -1	1 kWh	UINT32	R	
		...				R	
+14,15	0x4307	Tariff #8 register	0-10 ⁹ -1	1 kWh	UINT32	R	
20480-20495		TOU Energy Register #8^E					
+0,1	0x4400	Tariff #1 register	0-10 ⁹ -1	1 kWh	UINT32	R	
+2,3	0x4401	Tariff #2 register	0-10 ⁹ -1	1 kWh	UINT32	R	
		...				R	
+14,15	0x4407	Tariff #8 register	0-10 ⁹ -1	1 kWh	UINT32	R	
20608-20623		Summary Energy Accumulated Demands^E					
+0,1	0x4500	Summary register #1 demand	0-Pmax	U3	UINT32	R	

Address	Point ID	Description	Options/Range ²	Units ²	Type	R/W	Notes
+2,3	0x4501	Summary register #2 demand	0-Pmax	U3	UINT32	R	
		...					
+14,15	0x4507	Summary register #8 demand	0-Pmax	U3	UINT32	R	
20648-20663		Summary Energy Block Demands^E					
+0,1	0x4580	Summary register #1 demand	0-Pmax	U3	UINT32	R	
+2,3	0x4581	Summary register #2 demand	0-Pmax	U3	UINT32	R	
		...					
+14,15	0x4587	Summary register #8 demand	0-Pmax	U3	UINT32	R	
20736-20751		Summary Energy Sliding Window Demands^E					
+0,1	0x4600	Summary register #1 demand	0-Pmax	U3	UINT32	R	
+2,3	0x4601	Summary register #2 demand	0-Pmax	U3	UINT32	R	
		...					
+14,15	0x4607	Summary register #8 demand	0-Pmax	U3	UINT32	R	
20904-20919		Summary Energy Maximum Demands^E					
+0,1	0x4780	Summary register #1 maximum demand	0-Pmax	U3	UINT32	R	
+2,3	0x4781	Summary register #2 maximum demand	0-Pmax	U3	UINT32	R	
		...					
+14,15	0x4787	Summary register #8 maximum demand	0-Pmax	U3	UINT32	R	
20992-21023		TOU Maximum Demand Register #1^E					
+0,1	0x4800	Tariff #1 maximum demand	0-Pmax	U3	UINT32	R	
+2,3	0x4801	Tariff #2 maximum demand	0-Pmax	U3	UINT32	R	
		...				R	
+14,15	0x4807	Tariff #8 maximum demand	0-Pmax	U3	UINT32	R	
21120-21135		TOU Maximum Demand Register #2^E					
+0,1	0x4900	Tariff #1 maximum demand	0-Pmax	U3	UINT32	R	
+2,3	0x4901	Tariff #2 maximum demand	0-Pmax	U3	UINT32	R	
		...				R	
+14,15	0x4907	Tariff #8 maximum demand	0-Pmax	U3	UINT32	R	
21248-21263		TOU Maximum Demand Register #3^E					
+0,1	0x4A00	Tariff #1 maximum demand	0-Pmax	U3	UINT32	R	
+2,3	0x4A01	Tariff #2 maximum demand	0-Pmax	U3	UINT32	R	
		...				R	
+14,15	0x4A07	Tariff #8 maximum demand	0-Pmax	U3	UINT32	R	
21032-21047		TOU Maximum Demand Register #4^E					
+0,1	0x4880	Tariff #1 maximum demand	0-Pmax	U3	UINT32	R	
+2,3	0x4881	Tariff #2 maximum demand	0-Pmax	U3	UINT32	R	
		...				R	
+14,15	0x4887	Tariff #8 maximum demand	0-Pmax	U3	UINT32	R	
21160-21175		TOU Maximum Demand Register #5^E					
+0,1	0x4980	Tariff #1 maximum demand	0-Pmax	U3	UINT32	R	

Address	Point ID	Description	Options/Range ²	Units ²	Type	R/W	Notes
+2,3	0x4981	Tariff #2 maximum demand	0-Pmax	U3	UINT32	R	
		...				R	
+14,15	0x4987	Tariff #8 maximum demand	0-Pmax	U3	UINT32	R	
21288-21303		TOU Maximum Demand Register #6^E					
+0,1	0x4A80	Tariff #1 maximum demand	0-Pmax	U3	UINT32	R	
+2,3	0x4A81	Tariff #2 maximum demand	0-Pmax	U3	UINT32	R	
		...				R	
+14,15	0x4A87	Tariff #8 maximum demand	0-Pmax	U3	UINT32	R	
22400-22415		TOU Maximum Demand Register #7^E					
+0,1	0x5300	Tariff #1 maximum demand	0-Pmax	U3	UINT32	R	
+2,3	0x5301	Tariff #2 maximum demand	0-Pmax	U3	UINT32	R	
		...				R	
+14,15	0x5307	Tariff #8 maximum demand	0-Pmax	U3	UINT32	R	
22440-22455		TOU Maximum Demand Register #8^E					
+0,1	0x5380	Tariff #1 maximum demand	0-Pmax	U3	UINT32	R	
+2,3	0x5381	Tariff #2 maximum demand	0-Pmax	U3	UINT32	R	
		...				R	
+14,15	0x5387	Tariff #8 maximum demand	0-Pmax	U3	UINT32	R	
24576-24655		V1/V12 Harmonic Angles^{EH}					1, 3
+0,1	0x6400	H01 Harmonic angle	-1800-1800	×0.1°	INT32	R	
+2,3	0x6401	H02 Harmonic angle	-1800-1800	×0.1°	INT32	R	
		...					
+78,79	0x6427	H40 Harmonic angle	-1800-1800	×0.1°	INT32	R	
24704-24783		V2/V23 Harmonic Angles^{EH}					1, 3
+0,1	0x6500	H01 Harmonic angle	-1800-1800	×0.1°	INT32	R	
+2,3	0x6501	H02 Harmonic angle	-1800-1800	×0.1°	INT32	R	
		...					
+78,79	0x6527	H40 Harmonic angle	-1800-1800	×0.1°	INT32	R	
24832-24911		V1/V31 Harmonic Angles^{EH}					1, 3
+0,1	0x6600	H01 Harmonic angle	-1800-1800	×0.1°	INT32	R	
+2,3	0x6601	H02 Harmonic angle	-1800-1800	×0.1°	INT32	R	
		...					
+78,79	0x6627	H40 Harmonic angle	-1800-1800	×0.1°	INT32	R	
25088-25167		I1 Harmonic Angles^{EH}					3
+0,1	0x6800	H01 Harmonic angle	-1800-1800	×0.1°	INT32	R	
+2,3	0x6801	H02 Harmonic angle	-1800-1800	×0.1°	INT32	R	
		...					
+78,79	0x6827	H40 Harmonic angle	-1800-1800	×0.1°	INT32	R	
25216-25295		I2 Harmonic Angles^{EH}					3
+0,1	0x6900	H01 Harmonic angle	-1800-1800	×0.1°	INT32	R	

Address	Point ID	Description	Options/Range ²	Units ²	Type	R/W	Notes
+2,3	0x6901	H02 Harmonic angle	-1800-1800	×0.1°	INT32	R	
		...					
+78,79	0x6927	H40 Harmonic angle	-1800-1800	×0.1°	INT32	R	
25344-25423		I3 Harmonic Angles ^{EH}					3
+0,1	0x6A00	H01 Harmonic angle	-1800-1800	×0.1°	INT32	R	
+2,3	0x6A01	H02 Harmonic angle	-1800-1800	×0.1°	INT32	R	
		...					
+78,79	0x6A27	H40 Harmonic angle	-1800-1800	×0.1°	INT32	R	
		Generic TOU Season Energy Registers ID's ^E					Point references only
	0x7000	Tariff #1 register	0-10 ⁹ -1	1 kWh	UINT32		
	0x7001	Tariff #2 register	0-10 ⁹ -1	1 kWh	UINT32		
		...					
	0x7007	Tariff #8 register	0-10 ⁹ -1	1 kWh	UINT32		
		Generic TOU Season Maximum Demand Registers ID's ^E					Point references only
	0x7100	Tariff #1 register	0-Pmax	U3	UINT32		
	0x7101	Tariff #2 register	0-Pmax	U3	UINT32		
		...					
	0x7107	Tariff #8 register	0-Pmax	U3	UINT32		
27648-27649	0x7C00	Setpoint Status SP1-SP16 (bitmap)	0x00000000-0x0000FFFF		UINT32	R	

NOTES:

Energy and Power demand readings are only available in the meters with suffixes E and EH.

¹ Voltage and Voltage Harmonics Readings:

When the 4LN3, 3LN3 or 3BLN3 wiring mode is selected, the voltages will be line-to-neutral; for any other wiring mode, they will be line-to-line voltages.

When the 4LN3, 4LL3, 3LN3, 3LL3, 3BLN3 or 3BLL3 wiring mode is selected, the voltage harmonics will be line-to-neutral; for any other wiring mode, they will be line-to-line.

² For volts, amps, power and frequency scales and units, refer to Section 4 "Data Scales and Units".

³ Harmonic angles are referenced to the fundamental voltage harmonic H01 on phase L1.

3.5 Minimum/Maximum Log Registers

Address	Point ID	Description	Options/Range/Format ²	Units ²	Type	R/W	Notes
35840-35959		Minimum Phase Values					
+0,1 +2,3	0x2C00	Min. V1/V12 Voltage Timestamp	0-Vmax F1	U1 sec	UINT32 UINT32	R R	¹
+4,5 +6,7	0x2C01	Min. V2/V23 Voltage Timestamp	0-Vmax F1	U1 sec	UINT32 UINT32	R R	¹
+8,9 +10,11	0x2C02	Min. V3/V31 Voltage Timestamp	0-Vmax F1	U1 sec	UINT32 UINT32	R R	¹
+12,13 +14,15	0x2C03	Min. I1 Current Timestamp	0-Imax F1	U2 sec	UINT32 UINT32	R R	
+16,17 +18,19	0x2C04	Min. I2 Current Timestamp	0-Imax	U2 sec	UINT32 UINT32	R R	
+20,21 +22,23	0x2C05	Min. I3 Current Timestamp	0-Imax	U2 sec	UINT32 UINT32	R R	
+24-71	0x2C06- 0x2C11	Not used	0		INT32	R	
+72,73 +74,75	0x2C12	Min. V1/V12 Voltage THD Timestamp	0-9999	×0.1% sec	UINT32 UINT32	R R	¹ 4-cycle value
+76,77 +78,79	0x2C13	Min. V2/V23 Voltage THD Timestamp	0-9999	×0.1% sec	UINT32 UINT32	R R	¹ 4-cycle value
+80,81 +82,83	0x2C14	Min. V3/V31 Voltage THD Timestamp	0-9999	×0.1% sec	UINT32 UINT32	R R	¹ 4-cycle value
+84,85 +86,87	0x2C15	Min. I1 Current THD Timestamp	0-9999	×0.1% sec	UINT32 UINT32	R R	¹ 4-cycle value
+88,89 +90,91	0x2C16	Min. I2 Current THD Timestamp	0-9999	×0.1% sec	UINT32 UINT32	R R	4-cycle value
+92,93 +94,95	0x2C17	Min. I3 Current THD Timestamp	0-9999	×0.1% sec	UINT32 UINT32	R R	4-cycle value
+96,97 +98,99	0x2C18	Min. I1 K-Factor Timestamp	10-9999	×0.1 sec	UINT32 UINT32	R R	4-cycle value
+100,101 +102,103	0x2C19	Min. I2 K-Factor Timestamp	10-9999	×0.1 sec	UINT32 UINT32	R R	4-cycle value
+104,105 +106,107	0x2C1A	Min. I3 K-Factor Timestamp	10-9999	×0.1 sec	UINT32 UINT32	R R	4-cycle value
+108,109 +110,111	0x2C1B	Min. I1 Current TDD Timestamp	0-1000	×0.1% sec	UINT32 UINT32	R R	4-cycle value
+112,113 +114,115	0x2C1C	Min. I2 Current TDD Timestamp	0-1000	×0.1% sec	UINT32 UINT32	R R	4-cycle value
+116,117 +118,119	0x2C1D	Min. I3 Current TDD Timestamp	0-1000	×0.1% sec	UINT32 UINT32	R R	4-cycle value
36096-36111		Minimum Total Values					
+0,1	0x2D00	Min. Total kW	-Pmax-Pmax	U3	INT32	R	

Address	Point ID	Description	Options/Range/Format ²	Units ²	Type	R/W	Notes
+2,3		Timestamp		sec	UINT32	R	
+4,5	0x2D01	Min. Total kvar	-Pmax-Pmax	U3	INT32	R	
+6,7		Timestamp		sec	UINT32	R	
+8,9	0x2D02	Min. Total kVA	0-Pmax	U3	UINT32	R	
+10,11		Timestamp		sec	UINT32	R	
+12,13	0x2D03	Min. Total PF	-1000-1000	×0.001	INT32	R	
+14,15		Timestamp		sec	UINT32	R	
36352-36362		Minimum Auxiliary Values					
+0,1	0x2E00	Not used			UINT32	R	
+2,3					UINT32	R	
+4,5	0x2E01	Min. In Current	0-I _{max}	U2	UINT32	R	
+6,7		Timestamp		sec	UINT32	R	
+8,9	0x2E02	Min. Frequency	0-F _{max}	×0.01Hz	UINT32	R	
+10,11		Timestamp		sec	UINT32	R	
36864-36983		Maximum Phase Values					
+0,1	0x3400	Max. V1/V12 Voltage	0-V _{max}	U1	UINT32	R	¹
+2,3		Timestamp		sec	UINT32	R	
+4,5	0x3401	Max. V2/V23 Voltage	0-V _{max}	U1	UINT32	R	¹
+6,7		Timestamp		sec	UINT32	R	
+8,9	0x3402	Max. V3/V31 Voltage	0-V _{max}	U1	UINT32	R	¹
+10,11		Timestamp		sec	UINT32	R	
+12,13	0x3403	Max. I1 Current	0-I _{max}	U2	UINT32	R	
+14,15		Timestamp		sec	UINT32	R	
+16,17	0x3404	Max. I2 Current	0-I _{max}	U2	UINT32	R	
+18,19		Timestamp		sec	UINT32	R	
+20,21	0x3405	Max. I3 Current	0-I _{max}	U2	UINT32	R	
+22,23		Timestamp		sec	UINT32	R	
+24-71	0x3406-0x3411	Not used	0		INT32	R	
+72,73	0x3412	Max. V1/V12 Voltage THD	0-9999	×0.1%	UINT32	R	¹ 4-cycle value
+74,75		Timestamp		sec	UINT32	R	
+76,77	0x3413	Max. V2/V23 Voltage THD	0-9999	×0.1%	UINT32	R	¹ 4-cycle value
+78,79		Timestamp		sec	UINT32	R	
+80,81	0x3414	Max. V3/V31 Voltage THD	0-9999	×0.1%	UINT32	R	¹ 4-cycle value
+82,83		Timestamp		sec	UINT32	R	
+84,85	0x3415	Max. I1 Current THD	0-9999	×0.1%	UINT32	R	4-cycle value
+86,87		Timestamp		sec	UINT32	R	
+88,89	0x3416	Max. I2 Current THD	0-9999	×0.1%	UINT32	R	4-cycle value
+90,91		Timestamp		sec	UINT32	R	
+92,93	0x3417	Max. I3 Current THD	0-9999	×0.1%	UINT32	R	4-cycle value
+94,95		Timestamp		sec	UINT32	R	
+96,97	0x3418	Max. I1 K-Factor	10-9999	×0.1	UINT32	R	4-cycle value
+98,99		Timestamp		sec	UINT32	R	
+100,101	0x3419	Max. I2 K-Factor	10-9999	×0.1	UINT32	R	4-cycle value

Address	Point ID	Description	Options/Range/Format ²	Units ²	Type	R/W	Notes
+102,103		Timestamp		sec	UINT32	R	
+104,105 +106,107	0x341A	Max. I3 K-Factor Timestamp	10-9999	×0.1 sec	UINT32 UINT32	R R	4-cycle value
+108,109 +110,111	0x341B	Max. I1 Current TDD Timestamp	0-1000	×0.1% sec	UINT32 UINT32	R R	4-cycle value
+112,113 +114,115	0x341C	Max. I2 Current TDD Timestamp	0-1000	×0.1% sec	UINT32 UINT32	R R	4-cycle value
+116,117 +118,119	0x341D	Max. I3 Current TDD Timestamp	0-1000	×0.1% sec	UINT32 UINT32	R R	4-cycle value
37120-37135		Maximum Total Values					
+0,1 +2,3	0x3500	Max. Total kW Timestamp	-Pmax-Pmax	U3 sec	INT32 UINT32	R R	
+4,5 +6,7	0x3501	Max. Total kvar Timestamp	-Pmax-Pmax	U3 sec	INT32 UINT32	R R	
+8,9 +10,11	0x3502	Max. Total kVA Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
+12,13 +14,15	0x3503	Max. Total PF Timestamp	-1000-1000	×0.001 sec	INT32 UINT32	R R	
37376-37387		Maximum Auxiliary Values					
+0,1 +2,3	0x3600	Not used			UINT32 UINT32	R R	
+4,5 +6,7	0x3601	Max. In Current Timestamp	0-Imax	U2 sec	UINT32 UINT32	R R	
+8,9 +10,11	0x3602	Max. Frequency Timestamp	0-Fmax	×0.01Hz sec	UINT32 UINT32	R R	
37504-37535		Summary Energy Maximum Demands^E					
+0,1 +2,3	0x4780	Summary register #1 Maximum Demand Timestamp	0-Pmax	U3	UINT32	R	
+4,5 +6,7	0x4781	Summary register #2 Maximum Demand Timestamp	0-Pmax	U3	UINT32	R	
		...					
+28,29 +30,31	0x4783	Summary register #8 Maximum Demand Timestamp	0-Pmax	U3	UINT32	R	
37632-37695		Maximum Demands					
+0,1 +2,3	0x3700	V1/V12 Maximum volt demand Timestamp	0-Vmax	U1 sec	UINT32 UINT32	R R	¹
+4,5 +6,7	0x3701	V2/V23 Maximum volt demand Timestamp	0-Vmax	U1 sec	UINT32 UINT32	R R	¹
+8,9 +10,11	0x3702	V3/V31 Maximum volt demand Timestamp	0-Vmax	U1 sec	UINT32 UINT32	R R	¹
+12,13 +14,15	0x3703	I1 Maximum ampere demand Timestamp	0-Imax	U2 sec	UINT32 UINT32	R R	
+16,17	0x3704	I2 Maximum ampere demand	0-Imax	U2	UINT32	R	

Address	Point ID	Description	Options/Range/Format ²	Units ²	Type	R/W	Notes
+18,19		Timestamp		sec	UINT32	R	
+20,21 +22,23	0x3705	I3 Maximum ampere demand Timestamp	0-I _{max}	U2 sec	UINT32 UINT32	R R	
+24,25 +26,27	0x3706	Not used Timestamp			UINT32 UINT32	R R	
+28,29 +30,31	0x3707	Not used Timestamp			UINT32 UINT32	R R	
+32,33 +34,35	0x3708	Not used Timestamp			UINT32 UINT32	R R	
+36,37 +38,39	0x3709	Maximum kW import sliding window demand Timestamp	0-P _{max}	U3 sec	UINT32 UINT32	R R	
+40,41 +42,43	0x370A	Maximum kvar import sliding window demand Timestamp	0-P _{max}	U3 sec	UINT32 UINT32	R R	
+44,45 +46,47	0x370B	Maximum kVA sliding window demand Timestamp	0-P _{max}	U3 sec	UINT32 UINT32	R R	
+48,49 +50,51	0x3737	Not used Timestamp			UINT32 UINT32	R R	
+52,53 +54,55	0x370D	Not used Timestamp			UINT32 UINT32	R R	
+56,57 +58,59	0x370E	Not used Timestamp			UINT32 UINT32	R R	
+60,61 +62,63	0x370F	Maximum kW export sliding window demand Timestamp	0-P _{max}	U3 sec	UINT32 UINT32	R R	
+64,65 +66,67	0x3710	Maximum kvar export sliding window demand Timestamp	0-P _{max}	U3 sec	UINT32 UINT32	R R	
38016-38063		Maximum Harmonic Demands					
+0,1 +2,3	0x3880	V1/V12 THD demand Timestamp	0-9999	×0.1% sec	UINT32 UINT32	R R	1
+4,5 +6,7	0x3881	V2/V23 THD demand Timestamp	0-9999	×0.1% sec	UINT32 UINT32	R R	1
+8,9 +10,11	0x3882	V3/V31 THD demand Timestamp	0-9999	×0.1% sec	UINT32 UINT32	R R	1
+12,13 +14,15	0x3883	Not used			UINT32 UINT32	R R	
+16,17 +18,19	0x3884	I1 THD demand Timestamp	0-9999	×0.1% sec	UINT32 UINT32	R R	
+20,21 +22,23	0x3885	I2 THD demand Timestamp	0-9999	×0.1% sec	UINT32 UINT32	R R	
+24,25 +26,27	0x3886	I3 THD demand Timestamp	0-9999	×0.1% sec	UINT32 UINT32	R R	
+28,29 +30,31	0x3887	Not used			UINT32 UINT32	R R	
+32,33 +34,35	0x3888	I1 TDD demand Timestamp	0-1000	×0.1% sec	UINT32 UINT32	R R	

Address	Point ID	Description	Options/Range/Format ²	Units ²	Type	R/W	Notes
+36,37 +38,39	0x3889	I2 TDD demand Timestamp	0-1000	×0.1% sec	UINT32 UINT32	R R	
+40,41 +42,43	0x388A	I3 TDD demand Timestamp	0-1000	×0.1% sec	UINT32 UINT32	R R	
+44,45 +46,47	0x388B	Not used			UINT32 UINT32	R R	
38144-38175		TOU Maximum Demand Register #1^E					
+0,1 +2,3	0x4800	Tariff #1 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
+4,5 +6,7	0x4801	Tariff #2 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
		...				R	
+28,29 +30,31	0x4807	Tariff #8 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
38400-38431		TOU Maximum Demand Register #2^E					
+0,1 +2,3	0x4900	Tariff #1 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
+4,5 +6,7	0x4901	Tariff #2 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
		...				R	
+28,29 +30,31	0x4907	Tariff #8 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
38656-38687		TOU Maximum Demand Register #3^E					
+0,1 +2,3	0x4A00	Tariff #1 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
+4,5 +6,7	0x4A01	Tariff #2 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
		...				R	
+28,29 +30,31	0x4A07	Tariff #8 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
38272-38313		TOU Maximum Demand Register #4^E					
+0,1 +2,3	0x4880	Tariff #1 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
+4,5 +6,7	0x4881	Tariff #2 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
		...				R	
+28,29 +30,31	0x4887	Tariff #8 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
38528-38559		TOU Maximum Demand Register #5^E					
+0,1 +2,3	0x4980	Tariff #1 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
+4,5	0x4981	Tariff #2 maximum demand	0-Pmax	U3	UINT32	R	

Address	Point ID	Description	Options/Range/Format ²	Units ²	Type	R/W	Notes
+6,7		Timestamp		sec	UINT32	R	
		...				R	
+28,29 +30,31	0x4987	Tariff #8 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
38784-38815		TOU Maximum Demand Register #6^E					
+0,1 +2,3	0x4A80	Tariff #1 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
+4,5 +6,7	0x4A81	Tariff #2 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
		...				R	
+28,29 +30,31	0x4A87	Tariff #8 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
38912-38943		TOU Maximum Demand Register #7^E					
+0,1 +2,3	0x5300	Tariff #1 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
+4,5 +6,7	0x5301	Tariff #2 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
		...				R	
+28,29 +30,31	0x5307	Tariff #8 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
39040-39071		TOU Maximum Demand Register #8^E					
+0,1 +2,3	0x5380	Tariff #1 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
+4,5 +6,7	0x5381	Tariff #2 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	
		...				R	
+28,29 +30,31	0x5387	Tariff #8 maximum demand Timestamp	0-Pmax	U3 sec	UINT32 UINT32	R R	

NOTES:

Power demand readings are only available in the meters with suffixes E and EH.

¹ Voltage and Voltage Harmonics Readings:

When the 4LN3, 3LN3 or 3BLN3 wiring mode is selected, the voltages will be line-to-neutral; for any other wiring mode, they will be line-to-line voltages.

When the 4LN3, 4LL3, 3LN3, 3LL3, 3BLN3 or 3BLL3 wiring mode is selected, the voltage harmonics will be line-to-neutral; for any other wiring mode, they will be line-to-line.

² For volts, amps, power and frequency scales and units, refer to Section 4 "Data Scales and Units".

3.6 Device Control and Status Registers

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
Device Restart Register							
2560		Warm restart of the device	0 when read, 0xFFFF when written = restart the device		UINT16	R/W	
Device Authorization Registers							
2575		When write: 4-digit password. When read: 0 = access permitted, -1 = authorization required.	0-9999 (write) 0/-1 (read)		INT16	R/W	
44378-44379		When write: 8-digit password. When read: 0 = access permitted, -1 = authorization required.	0 - 99999999 (write) 0/-1 (read)		INT32	R/W	
Event Flags Control ^{EH}							
2916-2923							
2916		Event Flag #1 Status	0-1		UINT16	R/W	
2917		Event Flag #2 Status	0-1		UINT16	R/W	
2918		Event Flag #3 Status	0-1		UINT16	R/W	
2919		Event Flag #4 Status	0-1		UINT16	R/W	
2920		Event Flag #5 Status	0-1		UINT16	R/W	
2921		Event Flag #6 Status	0-1		UINT16	R/W	
2922		Event Flag #7 Status	0-1		UINT16	R/W	
2923		Event Flag #8 Status	0-1		UINT16	R/W	
Remote Relay Control							
3244-3245							
+0		Remote relay command	0 = remove a remote command 1 = operate relay 2 = remove a remote command and release a locally latched relay		UINT16	W	
3244		RO1 Control					
3245		RO2 Control					
Device Reset/Clear Registers							
3404		Clear total energy registers	0		UINT16	W	
3405		Clear total maximum demand registers	0 = Clear all maximum demands 1 = Clear power demands ^E 2 = Clear volt, ampere and harmonic demands		UINT16	W	
3406		Clear TOU energy registers ^E	0		UINT16	W	
3407		Clear TOU maximum demand registers ^E	0		UINT16	W	
3408		Clear pulse counters	0 = Clear all counters 1-4 = Clear counter #1-#4		UINT16	W	
3409		Clear Min/Max log	0		UINT16	W	
3410		Clear event log ^E	0		UINT16	W	
3411		Clear data log ^E	0-7 = Clear Data log #1-#8		UINT16	W	

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
			16 = Clear all data logs				
3412		Clear waveform log #1 ^{EH}	0		UINT16	W	
3413		Clear waveform log #2 ^{EH}	0		UINT16	W	
3414		Reserved			UINT16	W	
3415		Restore event log read pointer	0		UINT16	W	
3416		Restore data log read pointer	0-7 = Data log #1-#8 48-55, 64-66 = Daily profile data log #8 (same as 7)		UINT16	W	
3417		Restore waveform log #1 read pointer ^{EH}	0		UINT16	W	
3418		Restore waveform log #2 read pointer ^{EH}	0		UINT16	W	
Device Identification							
2561-2562		Reserved	0		UINT16	R	
2563		Firmware build number	1-99		UINT16	R	
2564		Reserved	0		UINT16	R	
2565		Firmware version number	1300-1399,1500-1599(PM172P/E), 1400-1499,1600-1699 (PM172EH)		UINT16	R	Two higher decimal digits = major version number, two lower decimal digits = minor version number
2566,2567		Instrument options	F28		UINT32	R	
3484		Current serial port number	0=COM1, 1=COM2		UINT16	R	
Device Status Registers							
3452		Relay status RO1-RO2 (bitmap)	0x0000-0x0003		UINT16	R	Bits set to 1 indicate closed relay contacts.
3453		Event flags (bitmap) ^{EH}	0x0000-0x00FF		UINT16	R	
3454		Digital (status) inputs DI1-DI2	0x0000-0x0003		UINT16	R	Bits set to 1 indicate closed input contacts.
3455		Present setpoint status SP1-SP16 (bitmap)	0x0000-0xFFFF		UINT16	R	Bits set to 1 indicate operated (activated) setpoints.
Log Notification Registers ^E							
3456		Log status (bitmap)	F26		UINT16	R	Bits set to 1 indicate that at least one new record is present in the designated files.
3457		Data log status (bitmap)	F27		UINT16	R	Bits set to 1 indicate that at least one new record is present in the designated files.
3458-3473		Reserved	0		UINT16	R	
Alarm Notification Registers							
3474		Setpoint alarm status SP1-SP16 (bitmap). Nonvolatile register that keeps the status of the operated setpoints.	0x0000-0xFFFF		UINT16	R/W	When read: Bits set to 1 indicate that the designated setpoint have been operated at least once since the alarm bits were reset. When written: Bits preset to 0 clear corresponding alarms, Bits set to 1 have no effect.
3475		Self-check alarm status (device diagnostics).	F23		UINT16	R/W	When read: Bits set to 1 indicate

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
		Nonvolatile register that keeps the status of the internal device diagnostics.					that the designated diagnostics failed at least once since the alarm bits were reset. When written: Bits preset to 0 clear corresponding alarms; bits set to 1 have no effect.
3476-3483		Reserved	0		UINT16	R	
3485		Battery status	0 = low battery, 1 = normal		UINT16	R	

3.7 Device Setup Registers

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
Device Identification							
46080-46111							
+0,1		Device serial number	0-999999		UINT32	R	
+2,3		Device model ID	17210=PM172P, 17220=PM172E, 17230=PM172EH		UINT32	R	
+4-11		Device model name	"PM172P", "PM172E", "PM172EH"		CHAR16	R	Null-terminated string
+12-13		Device options (bitmap)	0		UINT32	R	
+14-19		Reserved			UINT16	R	
+20		Device firmware version number	1300-1399,1500-1599(PM172P/E), 1400-1499,1600-1699 (PM172EH)		UINT16	R	Two higher decimal digits = major version number, two lower decimal digits = minor version number
+21		Device firmware build number	1-99		UINT16	R	
+22,23		Reserved			UINT16	R	
+24		Boot loader version number			UINT16	R	Two higher decimal digits = major version number, two lower decimal digits = minor version number
+25		Boot loader build number	1-99		UINT16	R	
+26-31		Reserved			UINT16	R	
Factory Device Settings							
46112-46125							
+0		V1-V3 input range	690, 120 (option U)	V	UINT16	R	Does not limit the 690V input range
+1		V1-V3 input overload	120	%	UINT16	R	
+2,3		Reserved			UINT16	R	
+4		I1-I3 input range	1, 5	A	UINT16	R	
+5		I1-I3 input overload	200	%	UINT16	R	
+6-13		Reserved			UINT16	R	
+14-63		Unused			UINT16	R	
+64		Ethernet MAC address 0-1	0x0500		UINT16	R	
+65		Ethernet MAC address 2-3	0x00F0		UINT16	R	
+66		Ethernet MAC address 4-5	0x0000-0xFFFF		UINT16	R	
Basic Setup							
2304-2324							
+0		Wiring mode	F2		UINT16	R/W	
+1		PT ratio	10 to 65000	×0.1	UINT16	R/W	
+2		CT primary current	1 to 20,000	A	UINT16	R/W	
+3		Power block demand period ^E	1,2,3,5,10,15,20,30,60 min, 255 = external synchronization	min	UINT16	R/W	If the external synchronization is selected, the DI1 input is considered a pulse or KYZ input. The pulse edge restarts the power demand block accumulation

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
							interval. ^E
+4		Volt/ampere/harmonic demand period	0 to 1800	sec	UINT16	R/W	
+5-7		Reserved			UINT16	R/W	Read as 65535
+8		Number of blocks in a sliding window ^E	1 to 15		UINT16	R/W	^E
+9		Reserved			UINT16	R/W	Read as 65535
+10		Number of cycles before trigger for the Waveform log #1 ^{EH}	1 to 8		UINT16	R/W	Obsolete register. Refer to the Waveform Log setup registers. ^{EH}
+11		Nominal line frequency	25, 50, 60, 400	Hz	UINT16	R/W	
+12		Maximum demand load current	0 to 20,000 (0 = CT primary current)	A	UINT16	R/W	
+13-15		Reserved			UINT16	R/W	Read as 65535
+16		Number of cycles per series for the Waveform log #1 ^{EH}	16 to 2560		UINT16	R/W	Obsolete register. Refer to the Waveform Log setup registers. ^{EH}
+17		Reserved			UINT16	R/W	Read as 65535
+18		Nominal secondary voltage ^{EH}	10 to 690 V		UINT16	R/W	^{EH}
+19		Reserved			UINT16	R/W	Read as 65535
+20		PT ratio multiplication factor	×1, ×10		UINT16	R/W	
Communication Ports Setup							
2344-2359							
+0		Communication protocol	COM1: 0=SATEC ASCII, 1=Modbus RTU, 2=DNP3.0, 4=DTE, 5=Profibus DP COM2: 0=SATEC ASCII, 1=Modbus RTU, 2=DNP3.0, 4=DTE		UINT16	R/W	
+1		Interface	COM1: 0=RS-232, 1=RS-422, 2=RS-485, 4=Dial-up Modem, 6=Ethernet, 7=Profibus COM2: 1=RS-422, 2=RS-485		UINT16	R/W	
+2		Device address	SATEC ASCII: 0-99 Modbus RTU: 1-247 DNP3.0: 0-65532 DTE: 1-65532 Profibus DP: 0-126		UINT16	R/W	
+3		Baud rate	1=300 bps, 2=600 bps, 3=1200 bps, 4=2400 bps, 5=4800 bps, 6=9600 bps, 7=19200 bps, 8=38400 bps, 9=57600 bps, 10=115200 bps		UINT16	R/W	
+4		Data format	0=7 bits/even parity, 1=8 bits/no parity, 2=8 bits/even parity		UINT16	R/W	
+5		Flow control	0=no flow control 1=software (XON/XOFF) 2=hardware (CTS)		UINT16	R/W	N/A for COM2 (read as 65535)

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
+6		RTS mode	0=not used, 1=RTS is permanently asserted 2=RTS is asserted during the transmission		UINT16	R/W	N/A for COM2 (read as 65535)
+7		ASCII compatibility mode	0=disabled, 1=enabled		UINT16	R/W	
2344-2351		COM1 Setup					
2352-2359		COM2 Setup					
Device Options Setup							
2376-2386							
+0		Power calculation mode	0=using reactive power: $S=f(P,Q)$, 1=using non-active power: $Q=f(S,P)$		UINT16	R/W	
+1		Energy roll value ^E	0= 1×10^4 , 1= 1×10^5 , 2= 1×10^6 , 3= 1×10^7 , 4= 1×10^8 , 5= 1×10^9		UINT16	R/W	^E
+2		Phase energy calculation mode ^E	0=disabled, 1=enabled		UINT16	R/W	^E
+3		Reserved			UINT16	R/W	Read as 65535
+4		Analog expander output option	0=none 1=0-20 mA 2=4-20 mA 3=0-1 mA 4= ± 1 mA		UINT16	R/W	
+5		Battery mode	0 = battery is OFF, 1 = battery is ON		UINT16	R/W	
+6-8		Reserved			UINT16	R/W	Read as 65535
+9		Harmonic power/energy calculation mode ^{EH}	0=disabled, 1=enabled		UINT16	R/W	^{EH}
+10		Energy LED test mode ^E	0=disabled, 1=Wh test, 2=varh test		UINT16	R/W	LED pulse rate is 10,000 pulses/kWh
+11		Reserved			UINT16	R/W	Read as 65535
+12		Starting current, percent of full scale	1-20	$\times 0.1\%$	UINT16	R/W	
Local Settings							
4320-4330							
+0		Daylight savings time (DST) option	0 = DST disabled (standard time only), 1 = DST enabled		UINT16	R/W	
+1		DST start month	1-12		UINT16	R/W	
+2		DST start week of the month	1-4 = 1st, 2nd, 3rd and 4th week, 5=the last week of the month		UINT16	R/W	
+3		DST start weekday	1-7 (1=Sun, 7=Sat)		UINT16	R/W	
+4		DST end month	1-12		UINT16	R/W	
+5		DST end week of the month	1-4=1st, 2nd, 3 rd and 4th week, 5=the last week of the month		UINT16	R/W	
+6		DST end weekday	1-7 (1=Sun, 7=Sat)		UINT16	R/W	
+7		Clock synchronization source	1-2 = DI1-DI2, 32767 = meter clock		UINT16	R/W	A DI input is considered a pulse or KYZ input. The pulse edge adjusts the clock at the nearest whole

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
							minute.
+8		Country code	ITU calling number		UINT16	R/W	
+9		DST start hour	1-6		UINT16	R/W	
+10		DST end hour	1-6		UINT16	R/W	
Clock Indication and Setup							
4352-4358							
+0		Seconds	0-59		UINT16	R/W	
+1		Minutes	0-59		UINT16	R/W	
+2		Hour	0-23		UINT16	R/W	
+3		Day of month	1-31		UINT16	R/W	
+4		Month	1-12		UINT16	R/W	
+5		Year (calendar year minus 2000)	0-99		UINT16	R/W	
+6		Weekday	1-7 (1=Sun, 7=Sat)		UINT16	R/W	Ignored when written
Alarm/Event Setpoints Setup							
352-1055							
+0		Condition #1: Logical operator	0 = OR, 1 = AND		UINT16	R/W	
+1		Condition #1: Trigger parameter ID	F12		UINT16	R/W	
+2		Condition #1: Reserved	0		UINT16	R/W	
+3		Condition #1: Reserved	0		UINT16	R/W	
+4,5		Condition #1: Operate limit	See Section 3.3		UINT32	R/W	Scaled value
+6,7		Condition #1: Release limit	See Section 3.3		UINT32	R/W	Scaled value
+8		Condition #2: Logical operator	0 = OR, 1 = AND		UINT16	R/W	
+9		Condition #2: Trigger parameter ID	F12		UINT16	R/W	
+10		Condition #2: Reserved	0		UINT16	R/W	
+11		Condition #2: Reserved	0		UINT16	R/W	
+12,13		Condition #2: Operate limit	See Section 3.3		UINT32	R/W	Scaled value
+14,15		Condition #2: Release limit	See Section 3.3		UINT32	R/W	Scaled value
+16		Condition #3: Logical operator	0 = OR, 1 = AND		UINT16	R/W	
+17		Condition #3: Trigger parameter ID	F12		UINT16	R/W	
+18		Condition #3: Reserved	0		UINT16	R/W	
+19		Condition #3: Reserved	0		UINT16	R/W	
+20,21		Condition #3: Operate limit	See Section 3.3		UINT32	R/W	Scaled value
+22,23		Condition #3: Release limit	See Section 3.3		UINT32	R/W	Scaled value
+24		Condition #4: Logical operator	0 = OR, 1 = AND		UINT16	R/W	
+25		Condition #4: Trigger parameter ID	F12		UINT16	R/W	
+26		Condition #4: Reserved	0		UINT16	R/W	
+27		Condition #4: Reserved	0		UINT16	R/W	
+28,29		Condition #4: Operate limit	See Section 3.3		UINT32	R/W	Scaled value
+30,31		Condition #4: Release limit	See Section 3.3		UINT32	R/W	Scaled value
+32		Action #1: Action type	F14		UINT16	R/W	
+33		Action #1: Action target	F14		UINT16	R/W	
+34		Action #2: Action type	F14		UINT16	R/W	
+35		Action #2: Action target	F14		UINT16	R/W	

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
+36		Action #3: Action type	F14		UINT16	R/W	
+37		Action #3: Action target	F14		UINT16	R/W	
+38		Action #4: Action type	F14		UINT16	R/W	
+39		Action #4: Action target	F14		UINT16	R/W	
+40		Not used	0		UINT16	R/W	
+41		Operate delay	0-9999	×0.1 sec	UINT16	R/W	
+42		Release delay	0-9999	×0.1 sec	UINT16	R/W	
+43		Not used	0		UINT16	R/W	
352-395		Setpoint #1					
396-439		Setpoint #2					
440-483		Setpoint #3					
484-527		Setpoint #4					
528-571		Setpoint #5					
572-615		Setpoint #6					
616-659		Setpoint #7					
660-703		Setpoint #8					
704-747		Setpoint #9					
748-791		Setpoint #10					
792-835		Setpoint #11					
836-879		Setpoint #12					
880-923		Setpoint #13					
924-967		Setpoint #14					
968-1011		Setpoint #15					
1012-1055		Setpoint #16					
Data Log Setup^E							
1792-1919							
+0		Data log parameter #1 ID	See Section 3.4		UINT16	R/W	
+1		Data log parameter #2 ID			UINT16	R/W	
+2		Data log parameter #3 ID			UINT16	R/W	
+3		Data log parameter #4 ID			UINT16	R/W	
+4		Data log parameter #5 ID			UINT16	R/W	
+5		Data log parameter #6 ID			UINT16	R/W	
+6		Data log parameter #7 ID			UINT16	R/W	
+7		Data log parameter #8 ID			UINT16	R/W	
+8		Data log parameter #9 ID			UINT16	R/W	
+9		Data log parameter #10 ID			UINT16	R/W	
+10		Data log parameter #11 ID			UINT16	R/W	
+11		Data log parameter #12 ID			UINT16	R/W	
+12		Data log parameter #13 ID			UINT16	R/W	
+13		Data log parameter #14 ID			UINT16	R/W	
+14		Data log parameter #15 ID			UINT16	R/W	
+15		Data log parameter #16 ID			UINT16	R/W	
1792-1807		Data log #1 Setup					

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
1808-1823		Data log #2 Setup					
1824-1839		Data log #3 Setup					
1840-1855		Data log #4 Setup					
1856-1871		Data log #5 Setup					
1872-1887		Data log #6 Setup					
1888-1903		Data log #7 Setup					
1904-1919		Data log #8 Setup					
Pulse Counters Setup							
2940-2947							
+0		Source digital input ID	0=not assigned, 1=D11, 2=D12		UINT16	R/W	
+1		Multiplier	0-9999		UINT16	R/W	
2940-2941		Counter #1 Setup					
2942-2943		Counter #2 Setup					
2944-2945		Counter #3 Setup					
2946-2947		Counter #4 Setup					
Analog Outputs Setup							
3148-3153							
+0		Output parameter ID	F18		UINT16	R/W	
+1		Zero scale value (0/4 mA)	See Section 3.3		UINT16	R/W	Scaled value
+2		Full scale value (1/20 mA)	See Section 3.3		UINT16	R/W	Scaled value
3148-3150		AO1 Setup					
3151-3153		AO2 Setup					
Analog Expander Setup							
3196-3243							Analog expander outputs settings will not be in effect until the analog expander output is globally enabled through the Device Options setup
+0		Output parameter ID	F18		UINT16	R/W	
+1		Zero scale value (0/4 mA)	See Section 3.3		UINT16	R/W	Scaled value
+2		Full scale value (1/20 mA)	See Section 3.3		UINT16	R/W	Scaled value
3196-3198		AX8 #1 Channel 1 Setup					
3199-3201		AX8 #1 Channel 2 Setup					
3202-3204		AX8 #1 Channel 3 Setup					
3205-3207		AX8 #1 Channel 4 Setup					
3208-3210		AX8 #1 Channel 5 Setup					
3211-3213		AX8 #1 Channel 6 Setup					
3214-3216		AX8 #1 Channel 7 Setup					
3217-3219		AX8 #1 Channel 8 Setup					
3220-3222		AX8 #2 Channel 1 Setup					
3223-3225		AX8 #2 Channel 2 Setup					
3226-3228		AX8 #2 Channel 3 Setup					
3229-3231		AX8 #2 Channel 4 Setup					
3232-3234		AX8 #2 Channel 5 Setup					

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
3235-3237		AX8 #2 Channel 6 Setup					
3238-3240		AX8 #2 Channel 7 Setup					
3241-3243		AX8 #2 Channel 8 Setup					
Digital Inputs Setup							
3292-3296							Obsolete registers. Refer to Digital Inputs setup registers 61728-61735
+0		Status inputs (bitmap)	0x0003		UINT16	R/W	Ignored when written
+1		Pulse inputs (bitmap)	0x0003		UINT16	R/W	Ignored when written
+2		Not used	0		UINT16	R/W	
+3		External demand synchronization input (bitmap)	0x0001=DI1		UINT16	R/W	Ignored when written
+4		Time synchronization input (bitmap)	0x0001=DI1, 0x0002=DI2		UINT16	R/W	
Periodic Timers Setup ^E							
3300-3301							
+0		Time interval	0=timer disabled, 1-9999 sec	sec	UINT16	R/W	
3300		Timer #1 Setup			UINT16	R/W	
3301		Timer #2 Setup			UINT16	R/W	
File Setup ^E							
3660-3811							
+0		Number of records in the file	0=delete a file, 1-65535		UINT16	R/W	
+1		Number of parameters per record	1-16		UINT16	R/W	Write 0 for event and waveform log files
+2		File attributes (bitmap)	F3		UINT16	R/W	
+3		File record size, bytes (for info only)			UINT16	R	
+4,5		Allocated file size, bytes (for info only)			UINT32	R	
+6,7		Reserved			UINT16	R	
3660-3667		Event Log Setup					
3668-3675		Data Log #1 Setup					
3676-3683		Data Log #2 Setup					
3684-3691		Data Log #3 Setup					
3692-3699		Data Log #4 Setup					
3700-3707		Data Log #5 Setup					
3708-3715		Data Log #6 Setup					
3716-3723		Data Log #7 Setup					
3724-3729		Data Log #8 Setup					
3730-3795		Reserved					
3796-3803		Waveform Log #1 Setup					
3804-3811		Waveform Log #2 Setup					
Network Setup							
46576-46703							
+0,1		Device IP Address	0x01000000-0xFFFFFFFF		UINT32	R/W	Network byte order
+2,3		Network subnet mask	0x00000001-0xFFFFFFFF		UINT32	R/W	Network byte order
+4,5		Network default gateway	0x00000000-0xFFFFFFFF		UINT32	R/W	Network byte order

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
+6,7		Use DHCP	0 = NO, 1 = YES		UINT32	R/W	
+8,9		TCP service port	502 = Modbus/TCP, 20000 = DNP3.0/TCP		UINT32	R/W	
+10-127		Reserved				R/W	
Password Setup							
46704-46707							
+0,1		Communications password (4 digits)	0-9999		UINT32	R/W	Read as 0
+2		Password protection enabled	0 = disabled, 1 = enabled		UINT16	R/W	
+3		Reserved			UINT16	R/W	
Expert Power Service Setup							
46768-46783							
+0,1		Expert Power server IP Address	0x01000000-0xFFFFFFFF		UINT32	R/W	Default = 207.232.60.18
+2,3		Expert Power server TCP service port	0-65535		UINT32	R/W	Default = 5001
+4,5		Expert Power client enabled	0 = client disabled, 1 = client enabled		UINT32	R/W	
+6,7		Time to next session	1-99999	min	UINT32	R/W	
+8,9		Time to next session	1-99999	min	UINT32	R	Same as previous
+10-15		Reserved					
Internet Service Provider (ISP) accounts							
46784-46879							
+0-15		ISP telephone number			CHAR32	R/W	
+16-31		Login name			CHAR32	R/W	
+32-47		Login password			CHAR32	R/W	
46784-46831		Account No.1					
46832-46879		Account No.2					
Transformer Correction Setup							
47072-47099							
+0		Ratio correction factor	900-1100	×0.001	UINT16	R/W	
+1		Phase angle error	-600 to 600	minutes	INT16	R/W	-2700 to 2700 in V13.71.12
+2, 3		Reserved			INT16	R/W	
47072-47075		V1 transformer correction					
47076-47079		V2 transformer correction					
47080-47083		V3 transformer correction					
47084-47087		Reserved					
47088-47091		I1 transformer correction					
47092-47095		I2 transformer correction					
47096-47099		I3 transformer correction					
EGD Producer Exchanges Setup							
50454-50837							
+0-1		Exchange consumer IP Address	0x01000000-0xFFFFFFFF		UINT32	R/W	Network byte order
+2		Production interval	1-60000	×10 ms	UINT16	R/W	
+3		Exchange status	0=disabled, 1=enabled		UINT16	R/W	
+4,5		Reserved	0		UINT16	R/W	

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
+6		Address range #1: Start point ID	0-65535, 0=end of the range list		UINT16	R/W	
+7		Address range #1: End point ID	1-65535		UINT16	R/W	
+8		Address range #1: Data type	0=Word, 1=DWord, 2= Float		UINT16	R/W	
+9		Address range #2: Start point ID	0-65535, 0=end of the range list		UINT16	R/W	
+10		Address range #2: End point ID	1-65535		UINT16	R/W	
+11		Address range #2: Data type	0=Word, 1=DWord, 2= Float		UINT16	R/W	
		...				R/W	
+93		Address range #30: Start point ID	0-65535, 0=end of the range list		UINT16	R/W	
+94		Address range #30: End point ID	1-65535		UINT16	R/W	
+95		Address range #30: Data type	0=Word, 1=DWord, 2= Float		UINT16	R/W	
50454-50549		Exchange #1					
50550-50645		Exchange #2					
50646-50741		Exchange #3					
50742-50837		Exchange #4					
DNP Options Setup							
51158-51183							
+0		Binary Input Static Objects	F24 (default 0)		UINT16	R/W	
+1		Binary Input Change Objects	F24 (default 1)		UINT16	R/W	
+2		Binary Counter Objects	F24 (default 3)		UINT16	R/W	
+3		Frozen Binary Counter Objects	F24 (default 4)		UINT16	R/W	
+4		Reserved			UINT16	R/W	
+5		Binary Counter Change Event Objects	F24 (default 2)		UINT16	R/W	
+6		Analog Input Objects	F24 (default 3)		UINT16	R/W	
+7		Reserved			UINT16	R/W	
+8		Reserved			UINT16	R/W	
+9		Analog Input Change Event Objects	F24 (default 2)		UINT16	R/W	
+10		Re-mapping static point indices for event objects	0=disabled (default), 1=enabled		UINT16	R/W	
+11		16-bit BC Scaling	0= $\times 1$ (default), 1= $\times 10$, 2= $\times 100$, 3= $\times 1000$		UINT16	R/W	
+12		16-bit AI Scaling	0 – scaling OFF, 1-scaling ON		UINT16	R/W	
+13		Number of mapped points of the Analog Input object	0 to 43 (default 43)		UINT16	R/W	
+14		Number of mapped points of the Binary Input object	0 to 32 (default 21)		UINT16	R/W	
+15		Number of mapped points of the Binary Counter object	0 to 16 (default 0)		UINT16	R/W	
+16		Select/Operate Timeout	2 to 30 seconds (default 10 sec)		UINT16	R/W	
+17		Multi Fragment Interval	50 to 500 ms (default 50 ms)		UINT16	R/W	
+18-21		Reserved	Read as 65535		UINT16	R/W	
+22,23		Time Sync Period	1 to 86400 seconds (default 86400 sec)		UINT32	R/W	
+24		Voltage scale, volts secondary	60 to 828V (default 144V)	V	UINT16	R/W	
+25		Current scale, amps secondary	100	$\times 0.1A$	UINT16	R/W	

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
51184-51189		Reserved					
DNP Events Setup							
51190-51445							
+0,1		Threshold/Deadband	0 to 4.3×10 ⁹		UINT32	R/W	A hysteresis for the point return threshold is 0.05Hz for frequency and 2% of the operating threshold for other points
+2		DNP point number	DNP point number available for the selected object		UINT16	R/W	
+3		Event scan control field (bitmap)	Bits 0-1 - DNP Object: 0 = none, 1=AI, 2=BI, 3=BC Bit 2 – Object change event scan: 0= event disabled, 1=enabled Bits 5-6 - DNP event poll class: 0=Class 1, 1=Class 2, 2=Class 3 Bit 7 - Event log on an event: 0= disabled, 1=enabled Bits 8-9 – Threshold/Deadband relation: 0=Delta, 1= more than (over threshold), 2=less than (under threshold)		UINT16	R/W	If Event log is enabled, the source of a DNP event will be recorded to the device Event log file as a general Setpoint #17.
51190-51193		DNP Event #1					
51194-51197		DNP Event #2					
		...					
51442-51445		DNP Event #64					
51446-51701		Reserved					
DNP Class 0 Point Assignments							
51702-51797							
+0		DNP object and variation	F25		UINT16	R/W	
+1		DNP point number	Point number for the selected object		UINT16	R/W	
+2		Number of points	0-128		UINT16	R/W	
51702-51704		DNP Class 0 Points Group 1					
51705-51707		DNP Class 0 Points Group 2					
		...					
51795-51797		DNP Class 0 Points Group 32					
51798-51893		Reserved					
Waveform Recorder Setup ^{EH}							
53878-53949							
+0		Sampling rate, samples per cycle	32 (Waveform log #1), 128 (Waveform log #2)		UINT16	R/W	Ignored when written
+1		Number of cycles per series	16-2560 (32 samples/cycle), 4-640 (128 samples/cycle)		UINT16	R/W	

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
+3		Not used	0		UINT16	R/W	
+4		Number of cycles before a trigger	1-20		UINT16	R/W	
+4,5		File channel mask, bitmap	F9, 0x00000033		UINT32	R/W	Ignored when written
+6,7		Not used	0		UINT32	R/W	
53878-53885		Waveform Log #1 Setup					
53886-53893		Waveform Log #2 Setup					
TOU Daily Profile Setup ^E							
55574-55701							
+0		1 st tariff change	F10		UINT16	R/W	
+1		2 nd tariff change	F10		UINT16	R/W	
+2		3 rd tariff change	F10		UINT16	R/W	
+3		4 th tariff change	F10		UINT16	R/W	
+4		5 th tariff change	F10		UINT16	R/W	
+5		6 th tariff change	F10		UINT16	R/W	
+6		7 th tariff change	F10		UINT16	R/W	
+7		8 th tariff change	F10		UINT16	R/W	
55574-55581		Daily profile #1: Season 1, Day type 1					
55582-55589		Daily profile #2: Season 1, Day type 2					
55590-55597		Daily profile #3: Season 1, Day type 3					
55598-55605		Daily profile #4: Season 1, Day type 4					
55606-55613		Daily profile #5: Season 2, Day type 1					
55614-55621		Daily profile #6: Season 2, Day type 2					
55622-55629		Daily profile #7: Season 2, Day type 3					
55630-55637		Daily profile #8: Season 2, Day type 4					
55638-55645		Daily profile #9: Season 3, Day type 1					
55646-55653		Daily profile #10: Season 3, Day type 2					
55654-55661		Daily profile #11: Season 3, Day type 3					
55662-55669		Daily profile #12: Season 3, Day type 4					
55670-55677		Daily profile #13: Season 4, Day type 1					
55678-55685		Daily profile #14: Season 4, Day type 2					
55686-55693		Daily profile #15: Season 4, Day type 3					
55694-55701		Daily profile #16: Season 4, Day type 4					
55702-55711		Reserved					
TOU Calendar Setup ^E							
55712-56031							
+0-9		Calendar entry record				R/W	
+0		Daily profile	0-3 = Season 1, Day types 0-3 4-7 = Season 2, Day types 0-3 8-11 = Season 3, Day types 0-3 12-15 = Season 4, Day types 0-3		UINT16	R/W	
+1		Week of month	0=all, 1=1st, 2=2nd, 3=3 rd , 4=4th, 5=last week of the month		UINT16	R/W	
+2		Weekday	0=all, 1-7 (Sun=1, Sat=7)		UINT16	R/W	

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
+3		Till Weekday	0=all, 1-7 (Sun=1, Sat=7)		UINT16	R/W	
+4		Month	0=all, 1-12=January - December		UINT16	R/W	
+5		Day of month	0=all, 1-31=day 1-31		UINT16	R/W	
+6		Till Month	0=all, 1-12=January - December		UINT16	R/W	
+7		Till Day of month	0=all, 1-31=day 1-31		UINT16	R/W	
+8-9		Reserved			UINT16	R/W	
55712-55721		Calendar entry #1					
55722-55731		Calendar entry #2					
55732-55741		Calendar entry #3					
...							
56022-56031		Calendar entry #32					
56032-56191		Reserved					
Summary Energy/TOU Registers Setup ^E							
56672-56703							
+0		Not used			UINT16	R/W	
+1		Units of measurement	0=none, 1=kWh, 2=kvarh, 3=kVAh, 4=m ³ , 5=CF (cubic feet), 6=CCF (hundred cubic feet)		UINT16	R/W	
+2		Flags (bitmap)	Bit 0=1 - TOU enabled Bit 1=1 - Use profile enabled Bit 2=1 - Max. Demand profile enabled Bit 3=1 - Summary (total) profile enabled		UINT16	R/W	
+3		Not used	0		UINT16	R/W	
56672-56675		Register #1 Setup					
56676-56679		Register #2 Setup					
56680-56683		Register #3 Setup					
56684-56687		Register #4 Setup					
56688-56691		Register #5 Setup					
56692-56695		Register #6 Setup					
56696-56699		Register #7 Setup					
56700-56703		Register #8 Setup					
Summary Energy/TOU Registers Source Setup ^E							
56928-57183							
+0		Energy source ID	F11		UINT16	R/W	
+1		Target summary register number	0-7 = register #1-#8		UINT16	R/W	
+2,3		Multiplier	0-1000000	×0.001	INT32	R/W	
56928-56931		Energy Source #1					
56932-56935		Energy Source #2					
56936-56939		Energy Source #3					
56940-56943		Energy Source #4					
56944-56947		Energy Source #5					

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
56948-56951		Energy Source #6					
56952-56955		Energy Source #7					
56956-56959		Energy Source #8					
Digital Inputs Setup							
61728-61735							
+0		Pulse mode	0 = pulse, 1 = KYZ		UINT16	R/W	
+1		Polarity	0 = normal, 1 = inverting		UINT16	R/W	
+2		De-bounce time, ms	1-1000		UINT16	R/W	Debounce time will be the same for both inputs
+3		Reserved			UINT16	R/W	
61728-61731		DI1 Setup					
61732-61735		DI2 Setup					
Relay Outputs Setup							
61984-61995							
+0		Operation Mode	0=unlatched, 1=latched, 2=pulse, 3=KYZ		UINT16	R/W	
+1		Polarity	Bit 0 - Polarity: 0=normal, 1=inverting, Bit 1 - Retentive mode: 0=disabled, 1=enabled		UINT16	R/W	
+2		Pulse width, ms	1-1000		UINT16	R/W	
+3		Pulse source ID	F17		UINT16	R/W	
+4		Units per pulse	1-10000	x0.1	UINT16	R/W	
+5		Reserved			UINT16	R/W	
61984-61989		RO1 Setup					
61990-61995		RO2 Setup					
Analog Inputs Setup							
62368-62379							
+0		Input parameter ID	0 = input not assigned		UINT16	R/W	
+1		Not used	0		UINT16	R/W	
+2,3		Zero scale value (0/4 mA)			INT32	R/W	
+4,5		Full scale value (20/1 mA)			INT32	R/W	
62368-62373		AI1 Setup					
62374-62379		AI2 Setup					
Analog Outputs Setup							
62560-62571							
+0		Output parameter ID	F18		UINT16	R/W	
+1		Not used	0		UINT16	R/W	
+2,3		Zero scale value (0/4 mA)	See Section 3.4		INT32	R/W	
+4,5		Full scale value (20/1 mA)	See Section 3.4		INT32	R/W	
62560-62565		AO1 Setup					
62566-62571		AO2 Setup					

3.8 Analog and Digital I/O Configuration

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
I/O Slots Configuration Info							
63008-63055							
+0		I/O type	F29		UINT16	R	
+1		Number of I/Os on the slot	0-2		UINT16	R	
+2		First I/O number on the slot	0		UINT16	R	
+3		Last I/O number on the slot	0-1		UINT16	R	
63008-63011		DI Slot Configuration					
63012-63015		RO Slot Configuration					
63016-63019		AI/AO Slot Configuration					
63020-63055		Reserved					
I/O Type Info							
63056-63119							
+0		Number of I/O slots of this type	0-1		UINT16	R	
+1		Total number of I/O's of this type	0-2		UINT16	R	
+2		Number of I/O's in the slot	0-2		UINT16	R	
+3		Not used	0		UINT16	R	
63056-63059		DI Type Info					
63060-63063		RO Type Info					
63064-63067		AI Type Info					
63068-63071		AO Type Info					
63076-63119		Reserved					

3.9 File Transfer Registers ^E

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
File Allocation Status Registers							
3500,3501		File allocation map (bitmap)	F6		UINT32	R	Bits set to 1 indicate that the memory is allocated to the designated files
3502,3503		Reserved	0		UINT32	R	
3504,3505		Daily profile log sections map (bitmap)	F7		UINT32	R	Bits set to 1 indicate that the corresponding sections are allocated in the Data log #8 file to the designated energy/maximum demand registers
3506,3507		File memory size, Bytes	1040384		UINT32	R	
3508,3509		Free file memory size, Bytes	0-1040384		UINT32	R	
3510		Total number of records in the Event log file	0-65535		UINT16	R	
3511		Total number of records in the Data log #1 file	0-65535		UINT16	R	
3512		Total number of records in the Data log #2 file	0-65535		UINT16	R	
3513		Total number of records in the Data log #3 file	0-65535		UINT16	R	
3514		Total number of records in the Data log #4 file	0-65535		UINT16	R	
3515		Total number of records in the Data log #5 file	0-65535		UINT16	R	
3516		Total number of records in the Data log #6 file	0-65535		UINT16	R	
3517		Total number of records in the Data log #7 file	0-65535		UINT16	R	
3518		Total number of records in the Data log #8 file	0-65535		UINT16	R	
3519-3526		Reserved	0		UINT16	R	
3527		Total number of records in the Waveform log #1 file	0-65535		UINT16	R	
3528		Total number of records in the Waveform log #2 file	0-65535		UINT16	R	
3529		Number of new records in the Event log file	0-65535		UINT16	R	
3530		Number of new records in the Data log #1 file	0-65535		UINT16	R	
3531		Number of new records in the Data log #2 file	0-65535		UINT16	R	
3532		Number of new records in the Data log #3 file	0-65535		UINT16	R	
3533		Number of new records in the Data log #4 file	0-65535		UINT16	R	
3534		Number of new records in the Data log #5 file	0-65535		UINT16	R	
3535		Number of new records in the Data log #6 file	0-65535		UINT16	R	
3536		Number of new records in the Data log #7 file	0-65535		UINT16	R	
3537		Number of new records in the Data log #8 file	0-65535		UINT16	R	
3538-3545		Reserved	0		UINT16	R	
3546		Number of new records in the Waveform log #1 file	0-65535		UINT16	R	
3547		Number of new records in the Waveform log #2 file	0-65535		UINT16	R	
File Transfer Control/Status Registers							
28160-28927							1
+0		File status (bitmap)	F4		UINT16	R	
+1		Number of records logged in the file	0 to 65535		UINT16	R	

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
+2		Number of the new records never read before	0 to 65535		UINT16	R	
+3		Sequence number of the last record in a file + 1 (modulo 65536)	0 to 65535 (increments modulo 65536 with each new record)		UINT16	R	Will return zero if the file is empty
+4		Sequence number of the first (oldest) record in a file	0 to 65535		UINT16	R	
+5		Sequence number of the first new record in a file never read before	0 to 65535		UINT16	R	
+6		Sequence number of the current record to be read through the file read window. Can be overwritten to point to the desired record in a file	0 to 65535		UINT16	R/W	If there is no a record in the file that matches the written sequence, the device will respond with the exception code 03 (invalid data)
+7		Command register (write-only)	Write value: 0 = point to the first (oldest) record in a file 1 = point to the first new record never read before. If there are no new records, the file pointer will be set to the oldest record in a file		UINT16	R/W	Read as 0
28160-28167		Event log file control			UINT16	R	
28168-28175		Data log #1 file control			UINT16	R	
28176-28183		Data log #2 file control			UINT16	R	
28184-28191		Data log #3 file control			UINT16	R	
28192-28199		Data log #4 file control			UINT16	R	
28200-28207		Data log #5 file control			UINT16	R	
28208-28215		Data log #6 file control			UINT16	R	
28216-28223		Data log #7 file control			UINT16	R	
28224-28231		Data log #8 file control			UINT16	R	
28232-28295		Reserved			UINT16	R	
28296-28303		Waveform log #1 file control			UINT16	R	
28304-28311		Waveform log #2 file control			UINT16	R	
28312-28671		Reserved			UINT16	R	
28672-28679		Daily Profile Log, Energy/Usage Reg.#1 control			UINT16	R	
28680-28687		Daily Profile Log, Energy/Usage Reg.#2 control			UINT16	R	
28688-28695		Daily Profile Log, Energy/Usage Reg.#3 control			UINT16	R	
28696-28703		Daily Profile Log, Energy/Usage Reg.#4 control			UINT16	R	
28704-28711		Daily Profile Log, Energy/Usage Reg.#5 control			UINT16	R	
28712-28719		Daily Profile Log, Energy/Usage Reg.#6 control			UINT16	R	
28720-28727		Daily Profile Log, Energy/Usage Reg.#7 control			UINT16	R	
28728-28735		Daily Profile Log, Energy/Usage Reg.#8 control			UINT16	R	
28736-28799		Reserved			UINT16	R	
28800-28807		Daily Profile Log, Max. Demand Reg.#1 control			UINT16	R	
28808-28815		Daily Profile Log, Max. Demand Reg.#2 control			UINT16	R	
28816-28823		Daily Profile Log, Max. Demand Reg.#3 control			UINT16	R	
28824-28823		Daily Profile Log, Max. Demand Reg.#4 control			UINT16	R	
28832-28839		Daily Profile Log, Max. Demand Reg.#5 control			UINT16	R	

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
28840-28847		Daily Profile Log, Max. Demand Reg.#6 control			UINT16	R	
28848-28855		Daily Profile Log, Max. Demand Reg.#7 control			UINT16	R	
28856-28823		Daily Profile Log, Max. Demand Reg.#8 control			UINT16	R	
28824-28927		Reserved			UINT16	R	
Event Log File Transfer Registers							
29440-29559							
		Event Record Structure					
+0		Record status (bitmap)	F5		UINT16	R	
+1		Record sequence number	0 to 65535 (increments modulo 65536)		UINT16	R	
+2,3		Record time, sec	F1	s	UINT32	R	
+4		Record time, fractional seconds, ms	0-999	ms	UINT16	R	
+5		Event point/cause ID	F19		UINT16	R	
+6,7		Log value			UINT32	R	32-bit non-scaled register
+8		Event effect	F20		UINT16	R	
+9		Reserved	0		UINT16	R	
		Event Log Transfer Blocks					
29440-29449		Event log record #1				R	
29450-29459		Event log record #2				R	
29460-29469		Event log record #3				R	
29470-29479		Event log record #4				R	
29480-29489		Event log record #5				R	
29490-29499		Event log record #6				R	
29500-29509		Event log record #7				R	
29510-29519		Event log record #8				R	
29520-29529		Event log record #9				R	
29530-29539		Event log record #10				R	
29540-29549		Event log record #11				R	
29550-29559		Event log record #12				R	
Data Log File Transfer Registers							
29696-32895							
		Data Log Record Structure					
+0		Record status (bitmap)	F5		UINT16	R	
+1		Record sequence number	0 to 65535 (increments modulo 65536)		UINT16	R	
+2,3		Record time, sec	F1	sec	UINT32	R	
+4		Record time, fractional seconds, ms	0-999	ms	UINT16	R	
+5		Trigger event ID	0=Profile log file, 1-16=SP1-SP16		UINT16	R	
+6,7		Parameter #1 value			INT32	R	32-bit non-scaled register
+8,8		Parameter #2 value			INT32	R	32-bit non-scaled register
+10,11		Parameter #3 value			INT32	R	32-bit non-scaled register
+12,13		Parameter #4 value			INT32	R	32-bit non-scaled register
+14,15		Parameter #5 value			INT32	R	32-bit non-scaled register

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
+16,17		Parameter #6 value			INT32	R	32-bit non-scaled register
+18,19		Parameter #7 value			INT32	R	32-bit non-scaled register
+20,21		Parameter #8 value			INT32	R	32-bit non-scaled register
+22,23		Parameter #9 value			INT32	R	32-bit non-scaled register
+24,25		Parameter #10 value			INT32	R	32-bit non-scaled register
+26,27		Parameter #12 value			INT32	R	32-bit non-scaled register
+28,29		Parameter #13 value			INT32	R	32-bit non-scaled register
+30,31		Parameter #13 value			INT32	R	32-bit non-scaled register
+32,33		Parameter #14 value			INT32	R	32-bit non-scaled register
+34,35		Parameter #15 value			INT32	R	32-bit non-scaled register
+36,37		Parameter #16 value			INT32	R	32-bit non-scaled register
+38,39		Reserved			INT32	R	32-bit non-scaled register
		Data Log Transfer Blocks					
29696-29735		Data log #1				R	
29736-29775		Data log #2				R	
29776-29815		Data log #3				R	
29816-29855		Data log #4				R	
29856-29895		Data log #5				R	
29896-29935		Data log #6				R	
29936-29975		Data log #7				R	
29976-30015		Data log #8				R	
30016-31615		Reserved				R	
31616-31655		Daily Profile Log, Energy/Usage Reg.#1 section				R	
31656-31695		Daily Profile Log, Energy/Usage Reg.#2 section				R	
31696-31735		Daily Profile Log, Energy/Usage Reg.#3 section				R	
31736-31775		Daily Profile Log, Energy/Usage Reg.#4 section				R	
31776-31815		Daily Profile Log, Energy/Usage Reg.#5 section				R	
31816-31855		Daily Profile Log, Energy/Usage Reg.#6 section				R	
31856-31895		Daily Profile Log, Energy/Usage Reg.#7 section				R	
31896-31935		Daily Profile Log, Energy/Usage Reg.#8 section				R	
31936-32255		Reserved				R	
32256-32295		Daily Profile Log, Max. Demand Reg.#1 section				R	
32296-32335		Daily Profile Log, Max. Demand Reg.#2 section				R	
32336-32375		Daily Profile Log, Max. Demand Reg.#3 section				R	
32376-32415		Daily Profile Log, Max. Demand Reg.#4 section				R	
32416-32455		Daily Profile Log, Max. Demand Reg.#5 section				R	
32456-32495		Daily Profile Log, Max. Demand Reg.#6 section				R	
32496-32535		Daily Profile Log, Max. Demand Reg.#7 section				R	
32536-32575		Daily Profile Log, Max. Demand Reg.#8 section				R	
32576-32895		Reserved				R	

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
Waveform Header Transfer Registers ^{EH}							
29696-32895							
		Waveform Header Structure					
+0		Record status (bitmap)	F5		UINT16	R	
+1		Record sequence number in a file	0 to 65535 (increments modulo 65536)		UINT16	R	
+2,3		Record time, sec	F1	sec	UINT32	R	Indicates the time for the last sample point in the record
+4		Record time, fractional seconds, ms	0-999	ms	UINT16	R	
+5		Trigger event ID	0=real-time waveform, 1-16=SP1-SP16		UINT16	R	
+6		Waveform series (compound waveform) number	1-65535 (rolls over to 1 after 65535)		UINT16	R	Each series can comprise up to 160 contiguous records of a compound waveform
+7		Record sequence number in a waveform series	0-159		UINT16	R	
+8,9		Analog input full scale, engineering units (volts/amperes) (ANALOG_SCALE)	Vmax, Imax		UINT32	R	
+10		Digital full scale for the channel, sample code (DIGITAL_SCALE)	-32768 to 32767		INT16	R	Corresponds to twice the analog input full-scale range.
+11		Zero offset, sample code (ZERO_OFFSET)	0		INT16	R	Corresponds to the center of the digital scale range
+12		Line frequency	0 to 6500	x 0.01Hz	UINT16	R	The sampling frequency is equal to the line frequency multiplied by the sampling rate in samples per cycle (32 for Waveform log #1 and 128 for Waveform log #2)
+13		Trigger sample point offset in the waveform series	0-511		UINT16	R	Corresponds to the first record in the series
+14,15		Reserved	0		UINT16	R	
		Waveform Header Transfer Blocks					
35456-35471		Real-time waveform, channel V1/V12				R	2
35472-35487		Real-time waveform, channel V2/V23				R	2
35488-35503		Real-time waveform, channel V3/V31				R	2
35504-35519		Real-time waveform, channel I1				R	
35520-35535		Real-time waveform, channel I2				R	
35536-35551		Real-time waveform, channel I3				R	
35552-35567		Waveform log #1, channel V1/L12				R	2
35568-35583		Waveform log #1, channel V2/L23				R	2
35584-35599		Waveform log #1, channel V3/V31				R	2
35600-35615		Waveform log #1, channel I1				R	
35616-35631		Waveform log #1, channel I2				R	
35632-35647		Waveform log #1, channel I3				R	
35648-35663		Waveform log #2, channel V1/V12				R	2
35664-35679		Waveform log #2, channel V2/V23				R	2

Address	Point ID	Description	Options/Range	Units	Type	R/W	Notes
35680-35695		Waveform log #2, channel V3/V31				R	2
35696-35711		Waveform log #2, channel I1				R	
35712-35727		Waveform log #2, channel I2				R	
35728-35743		Waveform log #2, channel I3				R	
Waveform Series Transfer Block ^{EH}							
6144-6655		Waveform Sample Series					³
+0		Sample point 1	-32768 to 32767		INT16	R	
+1		Sample point 2	-32768 to 32767		INT16	R	
+2		Sample point 2	-32768 to 32767		INT16	R	
+511		Sample point 512	-32768 to 32767		INT16	R	

NOTES:

¹ If a file is read through a TCP connection, your assignments for the transfer will be effective only within the current connection socket. Since the device cannot guarantee that your next connection will be made through the same socket, you should not make any assumptions regarding the present block settings. When you open a new connection, always check the file status and pointers before reading file records.

² When the 4LN3, 4LL3, 3LN3, 3LL3, 3BLN3 or 3BLL3 wiring mode is selected, the voltages will be line-to-neutral; for any other wiring mode, they will be line-to-line.

³ To convert digital samples to their analog equivalents in input measurement units (volts, amps), the following scaling should be applied:

$$\text{ANALOG_SAMPLE [Volts/ Amps]} = \frac{(\text{DIGITAL_SAMPLE} - \text{ZERO_OFFSET}) \times \text{ANALOG_SCALE} \times 2}{\text{DIGITAL_SCALE}}$$

4 Data Scales and Units

Code	Condition	Value/Range	Notes
Data Scales			
Vmax		Voltage scale × PT Ratio, V	2
I _{max}		Current scale (2A/10A) × CT Ratio = CT Primary current × 2, A	1, 3
P _{max}	Wiring 4LN3, 3LN3, 3BLN3	V _{max} × I _{max} × 3, W	4
	Wiring 4LL3, 3LL3, 3BLL3, 3OP2, 3OP3, 3DIR2	V _{max} × I _{max} × 2, W	
F _{max}	Nominal frequency 25, 50 or 60 Hz	100 Hz	
	Nominal frequency 400Hz	500 Hz	
AI _{min} AI _{max}	+/-1mA	AI _{min} = -AI full scale × 2 AI _{max} = AI full scale × 2	
	0-20mA	AI _{min} = AI zero scale AI _{max} = AI full scale	
	4-20mA	AI _{min} = AI zero scale AI _{max} = AI full scale	
	0-1mA	AI _{min} = AI zero scale AI _{max} = AI full scale	
Data Units			
U1	PT Ratio = 1	0.1V	
	PT Ratio > 1	1V	
U2		0.01A	
U3	PT Ratio = 1	1W/Var/VA	
	PT Ratio > 1	1kW/kvar/kVA	

¹ CT Ratio = CT primary current/CT secondary current

² The default Voltage scale is 144V (120V +20%) unless you changed it in your device through the Device Data Scale setup registers (see Section 3.1) or via the supplemental PAS software.

³ The default Current scale is 2 × CT secondary current (1A or 5A depending on the order).

⁴ P_{max} is rounded to whole kilowatts. With PT=1.0, if P_{max} is greater than 9,999,000 W, it is truncated to 9,999,000 W.

5 Data Formats

Format Code	Value	Description	Notes
Timestamp			
F1		Local time in a UNIX-style format. Represents the number of seconds since midnight (00:00:00), January 1, 1970. The time is valid after January 1, 2000.	
Wiring Mode			
F2	0	3OP2 - 3-wire open delta using 2 CTs (2 element)	
	1	4LN3 - 4-wire WYE using 3 PTs (3 element), line-to-neutral voltage readings	
	2	3DIR2 - 3-wire direct connection using 2 CTs (2 element)	
	3	4LL3 - 4-wire WYE using 3 PTs (3 element), line-to-line voltage readings	
	4	3OP3 - 3-wire open delta using 3 CTs (2 1/2 element)	
	5	3LN3 - 4-wire WYE using 2 PTs (2 1/2 element), line-to-neutral voltage readings	
	6	3LL3 - 4-wire WYE using 2 PTs (2 1/2 element), line-to-line voltage readings	
	8	3BLN3 - 3-wire broken delta using 2 PTs (2 1/2 element), line-to-neutral voltage readings	
	9	3BLL3 - 3-wire broken delta using 2 PTs (2 1/2 element), line-to-line voltage readings	
File Attributes			
F3	Bit 0 = 0	Non-wrap (stop when filled)	
	Bit 0 = 1	Wrap-around (circular file)	
	Bit 5 = 1	TOU daily profile log	
File Status Word			
F4	Bit 0 = 0	Non-wrap (stop when filled)	
	Bit 0 = 1	Wrap-around (circular file)	
	Bit 5 = 1	Daily profile log file	
	Bit 9 = 1	Reading after EOF	
File Record Status Word			
F5	Bit 0 = 1	The last record of the file is being read	
	Bit 1 = 1	Reading after EOF	
	Bit 8 = 1	File is empty	
	Bit 9 = 1	Corrupted record (CRC error)	
	Bit 15 = 1	Generic read error (with one of the bits 8-9)	
File Allocation Map			
F6	Bit 0	Event log file	
	Bit 1	Data log #1 file	
	Bit 2	Data log #2 file	
	Bit 3	Data log #3 file	
	Bit 4	Data log #4 file	
	Bit 5	Data log #5 file	
	Bit 6	Data log #6 file	
	Bit 7	Data log #7 file	
	Bit 8	Data log #8 file	
	Bits 9-16	Reserved	
	Bit 17	Waveform log #1 file	
	Bit 18	Waveform log #2 file	
	Bits 19-31	Reserved	
Profile Log Sections Map			
F7	Bit 0:7 = 1	Summary/TOU energy/usage registers #1-#8	
	Bit 16:23 = 1	Summary/TOU maximum demand registers #1-#8	
Waveform Log Channel Mask			
F9	Bit 0 = 1	Channel V1/V12	Note 1
	Bit 1 = 1	Channel V2/V23	
	Bit 2 = 1	Channel V3/V31	
	Bit 3 = 1	N/A	
	Bit 4 = 1	Channel I1	
	Bit 5 = 1	Channel I2	
	Bit 6 = 1	Channel I3	
TOU Tariff Change Time			
F10	Bits 8:15 = 0-7	Tariff number #1-#8	
	Bits 2:7 = 0-23	Tariff start hour	
	Bits 0:1 = 0-3	Tariff start quarter of an hour	

Format Code	Value	Description	Notes
Summary/TOU Energy Register Source ID			
F11	0x0000	None	
	0x0700-0x0701	Pulse input DI1-DI2	
	0x1700	kWh import	
	0x1701	kWh export	
	0x1704	kvarh import	
	0x1705	kvarh export	
	0x1708	kVAh total	
Setpoint Trigger Parameters ID			
F12	0x0000	None (condition is not active)	
		Voltage Disturbance ^{EH}	
	0x0100	Voltage disturbance	
		Event Flags ^{EH}	
	0x0300	Event flag #1 ON	
	0x0301	Event flag #2 ON	
	0x0302	Event flag #3 ON	
	0x0303	Event flag #4 ON	
	0x0304	Event flag #5 ON	
	0x0305	Event flag #6 ON	
	0x0306	Event flag #7 ON	
	0x0307	Event flag #8 ON	
	0x8300	Event flag #1 OFF	
	0x8301	Event flag #2 OFF	
	0x8302	Event flag #3 OFF	
	0x8303	Event flag #4 OFF	
	0x8304	Event flag #5 OFF	
	0x8305	Event flag #6 OFF	
	0x8306	Event flag #7 OFF	
	0x8307	Event flag #8 OFF	
		Internal Events ^E	
	0x0400	kWh import pulse	
	0x0401	kWh export pulse	
	0x0403	kvarh import pulse	
	0x0404	kvarh export pulse	
	0x0405	kvarh total pulse	
	0x0406	kVAh total pulse	
	0x0407	Start new demand interval	
	0x0408	Start new tariff interval	
	0x0409	Start new volt/ampere demand interval	
	0x040A	Start new sliding window demand interval	
		Timers ^E	
	0x0500	Timer #1	
	0x0501	Timer #2	
		Status Inputs	
	0x0600	Status input #1 ON	
	0x0601	Status input #2 ON	
	0x8600	Status input #1 OFF	
	0x8601	Status input #2 OFF	
		Pulse Inputs	
	0x0700	Pulse input #1	
	0x0701	Pulse input #2	
		Relays	
	0x0800	Relay #1 ON	
	0x0801	Relay #2 ON	
	0x8800	Relay #1 OFF	
	0x8801	Relay #2 OFF	
		Phase Reversal	4
	0x8901	Positive phase rotation reversal	
	0x8902	Negative phase rotation reversal	
		Pulse Counters	
	0x0A00	High pulse counter #1	
	0x0A01	High pulse counter #2	
	0x0A02	High pulse counter #3	
	0x0A03	High pulse counter #4	
		Time and Date Parameters ^E	
	0x0B02	Day of week	

Format Code	Value	Description	Notes
	0x0B03	Year	
	0x0B04	Month	
	0x0B05	Day of month	
	0x0B06	Hour	
	0x0B07	Minutes	
	0x0B08	Seconds	
		1-Cycle Phase Values	
	0x0C03	High I1 current	
	0x0C04	High I2 current	
	0x0C05	High I3 current	
	0x8C03	Low I1 current	
	0x8C04	Low I2 current	
	0x8C05	Low I3 current	
		1-Cycle Values on any Phase	
	0x0E00	High voltage	
	0x8D00	Low voltage	
	0x0E01	High current	
	0x8D01	Low current	
	0x0E07	High voltage THD	
	0x0E08	High current THD	
	0x0E09	High K-Factor	
	0x0E0A	High current TDD	
		1-Cycle Auxiliary Values	
	0x1002	High frequency	
	0x9002	Low frequency	
	0x1003	High voltage unbalance	
	0x1004	High current unbalance	
		1-Sec Phase Values	
	0x1103	High I1 current	
	0x1104	High I2 current	
	0x1105	High I3 current	
	0x9103	Low I1 current	
	0x9104	Low I2 current	
	0x9105	Low I3 current	
		1-Sec Values on any Phase	
	0x1300	High voltage	
	0x9200	Low voltage	
	0x1301	High current	
	0x9201	Low current	
		1-Sec Total Values	
	0x1406	High total kW import	
	0x1407	High total kW export	
	0x1408	High total kvar import	
	0x1409	High total kvar export	
	0x1402	High total kVA	
	0x9404	Low total PF Lag	
	0x9405	Low total PF Lead	
		1-Sec Auxiliary Values	
	0x1501	High neutral current	
	0x1502	High frequency	
	0x9502	Low frequency	
	0x1503	High voltage unbalance	
	0x1504	High current unbalance	
		Present Demands	
	0x1600	High V1/V12 Volt demand	
	0x1601	High V2/V23 Volt demand	
	0x1602	High V3/V31 Volt demand	
	0x1603	High I1 Ampere demand	
	0x1604	High I2 Ampere demand	
	0x1605	High I3 Ampere demand	
	0x1606	High block kW import demand	
	0x1607	High block kvar import demand	
	0x1608	High block kVA demand	
	0x1609	High sliding window kW import demand	
	0x160A	High sliding window kvar import demand	
	0x160B	High sliding window kVA demand	
	0x160F	High accumulated kW import demand	

Format Code	Value	Description	Notes
	0x1610	High accumulated kvar import demand	
	0x1611	High accumulated kVA demand	
	0x1612	High predicted kW import demand	
	0x1613	High predicted kvar import demand	
	0x1614	High predicted kVA demand	
	0x1616	High block kW export demand	
	0x1617	High block kvar export demand	
	0x1618	High sliding window kW export demand	
	0x1619	High sliding window kvar export demand	
	0x161A	High accumulated kW export demand	
	0x161B	High accumulated kvar export demand	
	0x161C	High predicted kW export demand	
	0x161D	High predicted kvar export demand	
		Setpoint Status	
	0x7C00	Setpoint #1 ON	
	0x7C01	Setpoint #2 ON	
	0x7C02	Setpoint #3 ON	
	0x7C03	Setpoint #4 ON	
	0x7C04	Setpoint #5 ON	
	0x7C05	Setpoint #6 ON	
	0x7C06	Setpoint #7 ON	
	0x7C07	Setpoint #8 ON	
	0x7C08	Setpoint #9 ON	
	0x7C09	Setpoint #10 ON	
	0x7C0A	Setpoint #11 ON	
	0x7C0B	Setpoint #12 ON	
	0x7C0C	Setpoint #13 ON	
	0x7C0D	Setpoint #14 ON	
	0x7C0E	Setpoint #15 ON	
	0x7C0F	Setpoint #16 ON	
Setpoint Action ID			
F14	Action type	Target	
	0x00	0x00	No action
	0x20	0x00	Set Event flag #1 EH
	0x20	0x01	Set Event flag #2 EH
	0x20	0x02	Set Event flag #3 EH
	0x20	0x03	Set Event flag #4 EH
	0x21	0x00	Clear Event flag #1 EH
	0x21	0x01	Clear Event flag #2 EH
	0x21	0x02	Clear Event flag #3 EH
	0x21	0x03	Clear Event flag #4 EH
	0x30	0x00	Operate Relay #1
	0x30	0x01	Operate Relay #2
	0x31	0x00	Release latched Relay #1
	0x31	0x01	Release latched Relay #2
	0x40	0x00	Increment counter #1
	0x40	0x01	Increment counter #2
	0x40	0x02	Increment counter #3
	0x40	0x03	Increment counter #4
	0x41	0x00	Clear counter #1
	0x41	0x01	Clear counter #2
	0x41	0x02	Clear counter #3
	0x41	0x03	Clear counter #4
	0x64	0x00	Clear all counters
	0x60	0x00	Reset total energy ^E
	0x61	0x00	Reset all total maximum demands
	0x61	0x01	Reset power maximum demands ^E
	0x61	0x02	Reset volt/ampere/harmonic maximum demands
	0x62	0x00	Reset TOU energy ^E
	0x63	0x00	Reset TOU maximum demands ^E
	0x65	0x00	Clear Min/Max registers
	0x70	0x02	Event log ^E
	0x71	0x00	Data log #1 ^E
	0x71	0x01	Data log #2 ^E
	0x71	0x02	Data log #3 ^E
	0x71	0x03	Data log #4 ^E
	0x71	0x04	Data log #5 ^E

Format Code	Value	Description	Notes	
	0x71	0x05	Data log #6 ^E	
	0x71	0x06	Data log #7 ^E	
	0x71	0x07	Data log #8 ^E	
	0x72	0x00	Waveform log #1 ^{EH}	
	0x73	0x00	Waveform log #2 ^{EH}	
Counter Source ID				
F16	0x0000	None		
	0x0001-0x0002	Pulse input D11-D12		
Relay Output Pulse Source ID ^E				
F17	0x0000	None		
	0x0400	kWh import pulse		
	0x0401	kWh export pulse		
	0x0403	kvarh import pulse		
	0x0404	kvarh export pulse		
	0x0405	kvarh total pulse		
	0x0406	kVAh pulse		
AO/Analog Expander Output Parameters ID				
F18	0x0000	None (output disabled)	Note 2	
		1-Cycle Phase Values		
	0x0C00	V1/V12 Voltage		
	0x0C01	V2/V23 Voltage		
	0x0C02	V3/V31 Voltage		
	0x0C03	I1 Current		
	0x0C04	I2 Current		
	0x0C05	I3 Current		
	0x0C1E	V12 Voltage		
	0x0C1F	V23 Voltage		
	0x0C20	V31 Voltage		
		1-Cycle Total Values		
	0x0F00	Total kW		
	0x0F01	Total kvar		
	0x0F02	Total kVA		
	0x0F03	Total PF		
	0x0F04	Total PF Lag		
	0x0F05	Total PF Lead		
		1-Cycle Auxiliary Values		
	0x1001	In Current		
	0x1002	Frequency		
		1-Sec Phase Values		
	0x1100	V1/V12 Voltage		
	0x1101	V2/V23 Voltage		
	0x1102	V3/V31 Voltage		
	0x1103	I1 Current		
	0x1104	I2 Current		
	0x1105	I3 Current		
	0x111E	V12 Voltage		
	0x111F	V23 Voltage		
	0x1120	V31 Voltage		
		1-Sec Total Values		
	0x1400	Total kW		
	0x1401	Total kvar		
	0x1402	Total kVA		
	0x1403	Total PF		
	0x1404	Total PF Lag		
	0x1405	Total PF Lead		
		1-Sec Auxiliary Values		
	0x1501	In Current		
	0x1502	Frequency		
		Present Demands ^E		
	0x160F	Accumulated kW import demand		
	0x1610	Accumulated kvar import demand		
	0x1611	Accumulated kVA demand		
	0x161A	Accumulated kW export demand		
	0x161B	Accumulated kvar export demand		
	Event Cause/Point ID			
	F19		Setpoint Operation Events	
		0x0000-0x59FF	Trigger parameter ID	

Format Code	Value	Description	Notes
	0x6400-0xFFFF	Trigger parameter ID	
		Setpoint Action Events	
	0x5A00-0x5A0F	Setpoint #1-#16	
		Communications Events	
	0x5B00-0x5BFF	Data point ID (low byte, see F21)	
		Front Panel Operations	
	0x5C00-0x5CFF	Data point ID (low byte, see F21)	
		Self-Check Diagnostics Events	
	0x5D00-0x5DFF	Data point ID (low byte, see F21)	
		Self-Update Events	
	0x5E08	RTC DST/Standard time update	
		Hardware Diagnostics Events	
	0x6202	RAM/Data error	
	0x6203	Hardware watchdog reset	
	0x6204	Sampling fault	
	0x6205	CPU exception	
	0x6206	Reserved	
	0x6207	Software watchdog reset	
	0x620D	Low battery	
	0x620F	EEPROM fault	
		External Events	
	0x6300	Power down	
	0x6308	Power up	
	0x6309	External reset	
Event Effect ID			
F20		Communications/Self-check/Front Panel Events	
	0x0000	None	
	0x6000	Total energy registers cleared	
	0x6100	All total maximum demands cleared	
	0x6101	Power maximum demands cleared	
	0x6102	Volt/Ampere/Harmonic maximum demands cleared	
	0x6200	Summary/TOU energy registers cleared	
	0x6300	Summary/TOU maximum demand registers cleared	
	0x6400	All counters cleared	
	0x6401-0x6403	Counter cleared (low byte = counter ID)	
	0x6500	Min/Max log cleared	
	0x6600	Event log file cleared (low byte = File ID)	
	0x6700-0x6707	Data log file cleared (low byte = File ID)	
	0x6710	All data logs cleared	
	0x6800	Waveform log #1 file cleared	
	0x6900	Waveform log #2 file cleared	
	0xF100-0xF10F	Setpoint cleared (low byte = setpoint ID)	
	0xF200	Setup/Data cleared	
	0xF300	Setup reset (set by default)	
	0xF400	Setup changed	
	0xF500	RTC set	
		Setpoint Operation Events	
	0xE100-0xE10F	Setpoint operated (low byte = setpoint ID)	
	0xE200-0xE20F	Setpoint released (low byte = setpoint ID)	
		Setpoint Action Events	
	See F14	Setpoint action ID	
Data Point ID			
F21		Data Locations	
	0x03	Data memory	
	0x04	Factory setup	
	0x05	Access/Password setup	
	0x06	Basic setup	
	0x07	Communications setup	
	0x08	Real-time clock	
	0x09	Digital inputs setup	
	0x0A	Pulse counters setup	
	0x0B	AO setup	
	0x0E	Timers setup	
	0x10	Event/alarm setpoints	
	0x11	Pulsing setup	
	0x12	User assignable register map	
	0x13	Programmable Min/Max log setup	

Format Code	Value	Description	Notes
	0x14	Data log setup	
	0x15	File/Memory setup	
	0x16	TOU energy registers setup	
	0x18	TOU daily profiles	
	0x19	TOU calendar	
	0x1D	RO Setup	
	0x1C	User selectable options	
	0x1F	DNP 3.0 Class 0 map	
	0x20	DNP 3.0 options setup	
	0x21	DNP 3.0 events setup	
	0x22	DNP 3.0 event setpoints	
	0x23	Calibration registers	
	0x24	Date/Time Setup	
	0x25	Net setup	
	0x26	AI setup	
	0x27	Waveform log setup	
	0x2B-0x3F	Reserved	
Device Diagnostics			
F23	Bit 0	Reserved	
	Bit 1	Reserved	
	Bit 2 = 1	RAM/Data error	
	Bit 3 = 1	CPU watchdog reset	
	Bit 4 = 1	Sampling fault	
	Bit 5 = 1	CPU exception	
	Bit 6	Reserved	
	Bit 7 = 1	Software watchdog reset	
	Bit 8 = 1	Power down	
	Bit 9 = 1	Device reset	
	Bit 10 = 1	Configuration reset	
	Bit 11 = 1	RTC fault	
	Bit 12	Reserved	
	Bit 13 = 1	Low battery	
	Bit 14	Reserved	
	Bit 15 = 1	EEPROM fault	
DNP Object Types			
F24		Static Binary Input Objects	
	0	Single-Bit Binary Input	
	1	Binary Input With Status	
		Binary Input Change Event Objects	
	0	Binary Input Change Without Time	
	1	Binary Input Change With Time	
		Static Binary Counters	
	0	32-bit Binary Counter	
	1	32-bit Binary Counter Without Flag	
	2	16-bit Binary Counter	
	3	16-bit Binary Counter Without Flag	
		Binary Counter Change Events	
	0	32-bit Counter Change Event Without Time	
	1	32-bit Counter Change Event With Time	
	2	16-bit Counter Change Event Without Time	
	3	16-bit Counter Change Event With Time	
		Frozen Binary Counters	
	0	32-bit Frozen Counter	
	1	32-bit Frozen Counter Without Flag	
	2	32-bit Frozen Counter With Time of Freeze	
	3	16-bit Frozen Counter	
	4	16-bit Frozen Counter Without Flag	
	5	16-bit Frozen Counter With Time of Freeze	
		Static Analog Input Objects	
	0	32-bit Analog Input	
	1	32-bit Analog Input Without Flag	
	2	16-bit Analog Input	
	3	16-bit Analog Input Without Flag	
		Analog Input Change Events	
	0	32-bit Analog Change Event Without Time	
	1	32-bit Analog Change Event With Time	
	2	16-bit Analog Change Event Without Time	

Format Code	Value		Description	Notes
	3		16-bit Analog Change Event With Time	
DNP Class 0 Objects				
F25	0x1E01		Analog Input 30:01	
	0x1E02		Analog Input 30:02	
	0x1E03		Analog Input 30:03	
	0x1E04		Analog Input 30:04	
	0x1F01		Frozen Analog Input 31:01	
	0x1F02		Frozen Analog Input 31:02	
	0x1F03		Frozen Analog Input 31:03	
	0x1F04		Frozen Analog Input 31:04	
	0x1F05		Frozen Analog Input 31:05	
	0x1F06		Frozen Analog Input 31:06	
	0x2801		Analog Output 40:01	
	0x2802		Analog Output 40:02	
	0x0101		Binary Input 01:01	
	0x0102		Binary Input 01:02	
	0x1401		Binary Counter 20:01	
	0x1402		Binary Counter 20:02	
	0x1405		Binary Counter 20:05	
	0x1406		Binary Counter 20:06	
	0x1501		Frozen Counter 21:01	
	0x1502		Frozen Counter 21:02	
	0x1505		Frozen Counter 21:05	
	0x1506		Frozen Counter 21:06	
0x1509		Frozen Counter 21:09		
0x150A		Frozen Counter 21:10		
0x3201		Time and Date 50:01		
Log Notification Status				
F26	Bit 0		Reserved	
	Bit 1=1		New Min/Max Log	
	Bit 2=1		New Event log record	
	Bit 3=1		New Data log record	
	Bit 4=1		New Waveform log #1 record	
	Bit 5=1		New Waveform log #2 record	
	Bits 6-15		Reserved	
Data Log Notification Status				
F27	Bit 0=1		New Data log #1 record	
	Bit 1=1		New Data log #2 record	
	Bit 2=1		New Data log #3 record	
	Bit 3=1		New Data log #4 record	
	Bit 4=1		New Data log #5 record	
	Bit 5=1		New Data log #6 record	
	Bit 6=1		New Data log #7 record	
	Bit 7=1		New Data log #8 record	
Bits 8-15		Reserved		
Instrument Options				
F28	Bit 0=1		120V Option	
	Bit 1=1		690V Option	
	Bits 2-5		Reserved	
	Bit 6=1		Analog output 0/4 or 4/20mA	
	Bit 7=1		Analog output 0-1mA	
	Bit 8=1		Analog output ± 1 mA	
	Bit 9=1		RO option	
	Bit 10=1		DI option	
	Bit 11=1		Reserved	
	Bit 12=1		Setup is secured by a password (authorization required)	
	Bit 13=1		Reserved	
	Bit 14=1		Analog expander option ± 1 mA	
	Bit 15		Reserved	
	Bits 16-18		Number of RO - 1	
	Bits 19-22		Number of DI - 1	
	Bits 23-24		Number of AO - 1	
Bits 25-29		Reserved		
Bits 30-31=11		Memory module 1MBytes ^E		
I/O Slot Types				
F29	DI	DRY	0000000B	x = Don't care
	RO		0010000B	

Format Code	Value		Description	Notes
	AI	±1 mA	01010000B	
	AI	0-20 mA	01010001B	
	AI	4-20 mA	01010010B	
	AI	0-1 mA	01010011B	
	AO	±1 mA	01100000B	
	AO	0-20 mA	01100001B	
	AO	4-20 mA	01100010B	
	AO	0-1 mA	01100011B	
	Empty slot		1111x×x×B	

NOTES:

1 Voltage Waveforms

When the 4LN3, 4LL3, 3LN3, 3LL3, 3BLN3 or 3BLL3 wiring mode is selected, the voltage waveforms will be line-to-neutral; for any other wiring mode, they will be line-to-line.

2 Analog Outputs

1) For bi-directional analog output (±1 mA), the zero scale setup corresponds to the center (0 mA) of the scale range, and the direction of the current matches the sign of the output parameter. Unsigned parameters are output within the current range 0 to +1 mA and can be scaled as in the case of single-ended analog output (0-1 mA).

For signed values, such as powers and signed power factor, the scale is always symmetrical with regard to 0 mA, and the full scale corresponds to +1 mA output for positive readings and to -1 mA output for negative readings. The zero scale (0 mA output) is permanently set in the instrument to zero for all parameters except the signed power factor for which it is set to 1.000 (see Note 2). In write requests, the zero scale is ignored.

2) Except for the signed power factor, the setup scale is continuous within the entire value range. For signed power factor, the setup scale is broken at +1.000 in order to provide continuous output current when the power factor changes close to ±1.000. The setup scale is symmetrical in the range of -0 to +0 with a center at 1.000 (-1.000 is assumed to be equal to +1.000). Negative power factor is output as -1.000 minus measured value, and non-negative power factor is output as +1.000 minus measured value. To set the entire range for power factor from -0 to +0, the scales would be specified as -0 to 0. Because of the fact that negative zero may not be transmitted through communications, the value of -0.001 is used to specify the scale of -0, and both +0.001 and 0.000 are used to specify the scale of +0.

3 Voltage Disturbance Trigger

The operate limit specifies the voltage deviation in percent of the nominal secondary voltage.

4 Phase Reversal Trigger

The setpoint is operated when the actual phase sequence does not match the designated phase rotation order.