

INTERFACE (ABT) METER AS PER CEA GUIDE LINES — EM133+ ABT

- DIN Rail mounted Multi-Function Meter
- Provides all parameters as per CEA guide lines for Interface (ABT) Meter
- Serial RS485 for MODBUS, DNP3 and IEC-60870-5-101
- Optional second port for communication—RS485, RS232 or ETH
- Protocols available over ETH—MODBUS TCP, DNP 3.0 and IEC- 60870-5-104
- Accuracy class 0.2S as per IEC-62053-22
- Data log memory
- Meter sealing arrangement

As per CEA guidelines published on 17th March 2006 and its amendment dated 4th June 2010, Interface (ABT) meters are to be installed by all consumers who have been permitted open access at following locations.

i) Generating Stations:

- a) On all generation feeders
- b) On all outgoing feeders.
- c) On each on high voltage side of generator transformers.
- d) High voltage side of all station auxiliary transformers.

ii) Transmission and Distribution Systems:

- a) At one end of line between the sub-stations of the same license.
- b) At both ends of line between sub-stations of two different licensees.
- c) High voltage side of interconnecting transformers.
- d) Consumers directly connected to inter-State Transmission system who are covered under ABT.

These special meters allow monitoring of exchange of energy between two open access



EM133+ ABT

Panel mounted, four quadrant Satec Smart MFM EM133+ ABT provides all required electrical parameters for interface meters (ABT) as per CEA guidelines with accuracy class 0.2S. The meter comes with one isolated RS485 communication port as standard. This port can be configured for MODBUS RTU, DNP3 or IEC-60870-5-101 communication protocols.

The smart meter also provides option of second communication port. The second communication port can be RS485, RS232 or ETH. The second communication port can be configured for required baud rate and protocol—(MODBUS RTU over RS485 or RS232, MODBUS TCP over ETH , DNP3 over RS485 or ETH, IEC-60870-5-104 over ETH).

Data log memory (130KB) for logging 15 minutes block data is provided.

Meter can also be sealed as required.

PAS software is supplied with each meter. The software enables configuration and operational testing of all meter parameters.

ABT PARAMETERS AS PER CEA GUIDELINES

 $Details\ of\ parameters\ in\ EM133+\ ABT as\ per\ CEA\ guidelines\ are\ provided\ below:$

Sr. No.	ABT Parameter as per CEA guidelines	MODBUS Register Address in PM130EH+ ABT
1	Phase wise KW at peak KVA	KW L1- 29958 KW L2—29960 KW L3- 29962
2	Phase wise KVAR (reactive) at peak KVA	KVAR L1– 29964 KVAR L2—29966 KVAR L3– 29968
3	Phase wise Voltage at peak KVA	V1- 29952 V2- 29954 V3-29956
4	KVA Block Demand	Import - 14666 Export—14668
5	KVAR Block Demand	Q1-14652 Q2-14654 Q3-14656 Q4-14658
6	Neutral Current Block Demand	14660
7	Voltage Block Demand (V-Average)	14662
8	Frequency Block Demand (Average Frequency)	14664
9	Power Down Time	Power off duration—44210
10	Cumulative Programming Counter	44216
11	Cumulative Tamper/Event Counter (POS/NEG Phase reversal, Low Volt/Amps RT, Low Volt/Amps Average and HI Volt/Amps unbalance RT)	44218
12	Cumulative MD Reset Counter (For current billing period)	44220
13	Cumulative MD Reset Counter (For previous billing period)	44222
14	Average Power Factor	Total PF—14342
15	Line Currents	L1-13958 L2-13960 L3- 13962
16	Phase Voltages	V1-13952 V2-13954 V3- 13956
17	Date and Time	Date and Time—4352 to 4358
18	Billing Summary Registers	14760—14779
19	Billing TOU Registers	20096—21519
20	Summary Accumulated Demands	20608– 20627
21	TOU Maximum Demand Registers	20992—22583
22	Summary Maximum Demand Registers	37504– 37533
23	TOU Profile—Daily Energy Register	
24	TOU Profile—Daily Maximum Demand Register	



31/1, Ahiripukur Road, Kolkata 700019, West Bengal, India

Call: +91 033 6565 1012, 98313 30473, 98312 06454 | Fax: +91 033 2287 0445

 $Email: enquiry@mbcontrol.com, service@mbcontrol.com \textit{(for service related quires)} \hspace{0.2cm} | \hspace{0.2cm} Website: www.mbcontrol.com$