

# PM130 PLUS Powermeter Series

## PM130P/PM130EH

### CERTIFICATIONS



## SATEC Instruments Types Statement



### DECLARATION

I HEREBY DECLARE THAT THE FOLLOWING PRODUCTS:


PM130P PLUS

ARE IDENTICAL ELECTRONICALLY, PHYSICALLY, AND MECHANICALLY  
TO:

PM130EH PLUS

Please relate to them (from an EMC point of view) as the same product.

Thank you,

  
April 18, 2007

Dany Shacked

Projects Manager


SATEC LTD.

ISRAEL

אזרו תעשייה הר חוצבים  
ר' המרפא 45022  
ת'ד 91450 ירושלים  
טל' 02-5812371 פקס 02-5411000  
www.satec.co.il

Har Hotzvim Industrial Park  
7 Hamarpe St.  
POB 45022 Jerusalem 91450 Israel  
Tel. +972-2-5411000 Fax +972-2-5812371  
satec@satec.co.il

# ISRAEL Accuracy and Insulation Tests Certification per IEC 62053-22 class 0.5S

 	<p>Israel Electric Corporation Marketing Division Central Metering Unit</p> <p>17 Ha-Lehi Street, Bnei Brak 51200, Israel Tel. 972 3 6174859 Fax 972 3 6174908</p> 																																						
<i>Test Certificate</i>																																							
Page 1 of 9	<b>Date:</b> 10/07/2007	<b>Test Certificate No.:</b> 167-2007																																					
<b>According to procedure No. n/a</b>		<b>And/or according to requirement:</b> 29-2007																																					
<b>Date of acceptance:</b> 25/06/2007		<b>Description of tested item:</b> Power Meter																																					
<b>Manufacturer:</b> SATEC		<b>Type:</b> PM130 PLUS																																					
<b>Status:</b> new		<b>Serial No.:</b> 72446, 72447																																					
<b>Customer:</b> SATEC <b>Address:</b> Har Ha-tzofim, Science Based Industrial Park, POBox 45022, Jerusalem 91450, Israel.																																							
<b>Environmental conditions:</b> Ambient temperature: $23^{\circ}\text{C} \pm 2^{\circ}\text{C}$ ; relative humidity: $50\% \pm 20\%$ <b>Method:</b> Comparison with reference standard <b>Suggested next test date:</b> n/a																																							
<b>List of main equipment used for the calibration</b>																																							
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 25%;">Description/Type</th> <th style="width: 25%;">Manufacturer</th> <th style="width: 25%;">Serial number</th> <th style="width: 25%;">Test date</th> </tr> </thead> <tbody> <tr> <td>RMM 3000</td> <td>Zera</td> <td>7/5302</td> <td>3/2006</td> </tr> <tr> <td>MTS 320</td> <td>Zera</td> <td>7/5130</td> <td>6/2007</td> </tr> <tr> <td>9500</td> <td>F.W.Bell</td> <td>7/4342</td> <td>11/2004</td> </tr> <tr> <td>UNITEST</td> <td>BEHA</td> <td>K2251/19</td> <td>2/2007</td> </tr> <tr> <td>UH 28 M</td> <td>RB</td> <td>7/4009</td> <td>2/2004</td> </tr> <tr> <td>GP3050</td> <td>SCHLUMBERGER</td> <td>7/5098</td> <td>6/2007</td> </tr> <tr> <td>VCL 4034 MH</td> <td>VOTSCHE</td> <td>7/5282</td> <td>9/2006</td> </tr> <tr> <td>51-548-1</td> <td>ZERA</td> <td>7/3671</td> <td>11/2004</td> </tr> </tbody> </table>				Description/Type	Manufacturer	Serial number	Test date	RMM 3000	Zera	7/5302	3/2006	MTS 320	Zera	7/5130	6/2007	9500	F.W.Bell	7/4342	11/2004	UNITEST	BEHA	K2251/19	2/2007	UH 28 M	RB	7/4009	2/2004	GP3050	SCHLUMBERGER	7/5098	6/2007	VCL 4034 MH	VOTSCHE	7/5282	9/2006	51-548-1	ZERA	7/3671	11/2004
Description/Type	Manufacturer	Serial number	Test date																																				
RMM 3000	Zera	7/5302	3/2006																																				
MTS 320	Zera	7/5130	6/2007																																				
9500	F.W.Bell	7/4342	11/2004																																				
UNITEST	BEHA	K2251/19	2/2007																																				
UH 28 M	RB	7/4009	2/2004																																				
GP3050	SCHLUMBERGER	7/5098	6/2007																																				
VCL 4034 MH	VOTSCHE	7/5282	9/2006																																				
51-548-1	ZERA	7/3671	11/2004																																				
<i>The reported expanded measurement uncertainties correspond to the coverage probability of approximately 95% and based on coverage factor <math>K=2</math>, or as stated in enclosed document. The results of calibration characterize the calibrated item at the time of calibration only, and not include any changes after this time.</i>																																							
<i>Reference should be made the full document. The document or part of it should not be copied without confirmation with the laboratory manager.</i>																																							
<i>This Calibration meets the requirements of ISO/IEC 17025 and reference quantities of the laboratory are traceable to national and international reference quantities.</i>																																							
<i>The use of ISRAC symbol relates to tests/calibrations which are included in the laboratory scope of accreditation, as detailed in the accreditation certificate.</i>																																							
<i>ILAC-ELECTRIC</i> <i>ISRAEL DIVISION-CENTRAL METERING</i> <i>TESTING LABORATORY</i> <i>DEPARTMENT</i> <i>STANDARDS LABORATORY</i>																																							
<b>Signature:</b> 		<b>Date:</b> 10/07/07	<b>Tested by:</b> G. Mitelman																																				
<b>Signature:</b> 		<b>Date:</b> 12/17/07	<b>Verified by:</b> <b>בן ציון רביבורי</b> <b>מינהל טכני במשרד התקנים</b> <b>מחלקה מרכזית למטרות</b>																																				
Form No.: 06/307/00/03-23, version 3																																							

**Test report of samples "Power Meter PM130 PLUS"**

**List of samples**

Manufacturer	Type	Serial number	Reference voltage, V	Rated (maximum) current, A	Reference frequency, Hz
SATEC	PM130 PLUS	724446	230/400	3 x 5(10)	50
		724447			

**List of performed tests**

# item in IEC62053-22- class 0.5 s	# item in IEC6205 2-11	Test	Pass/No pass	# test
8.1	-	Error due to variation of the current	Pass	1.
8.2	-	Error due to ambient temperature variation	Pass	2.
8.2	-	Error due to voltage variation	Pass	3.
8.2	-	Error due to frequency variation	Pass	4.
8.2	-	Error due to reversed phase sequence	Pass	5.
8.2	-	Error due to voltage unbalance	Pass	6.
8.2.1	-	Error due to harmonic components in the current and voltage circuit	Pass	7.
8.2.2		Error due to sub-harmonics in the a.c. current circuit	Pass	8.
8.2.3	-	Error due to magnetic indication of external origin 0.5 mT	Pass	9.
8.3.1	-	Test of initial start-up of the meter	Pass	10.
7.4	7.3.3	AC voltage Insulation test	Pass	11.
7	7.3.2	Impulse voltage tests for circuits and between the circuits	Pass	12.

Expanded uncertainty of energy error: 200ppm at PF = 1 and 250ppm at PF = 0.5

## EMC Tests Certification per IEC 61000-6-2

Approved to ISO/IEC 17025



# EMC Test Certificate

Certificate No **K72790.01** Page **1** Date of Issue **01 May 2007**

Applicant **Satec Ltd.**

Tested to	CISPR 22: 2005, Class A EN 61000-6-2: 2001 IEC 61000-4-2: 2001	Air Discharge, 8kV Contact Discharge, 4kV (80-1000 MHz), 10V/m
	IEC 61000-4-3: 2006	80% A.M. by 1kHz
	IEC 61000-4-4: 2004	2kV Power Lines, 1kV Signal Lines
	IEC 61000-4-5: 2005	COM. Mode: 1kV, Dif. Mode: 1kV Power Lines
	IEC 61000-4-6: 2006	2kV Signal lines (0.15-80 MHz) 10VRMS, 80% A.M. by 1kHz
	IEC 61000-4-8: 2001	Power and Signal Lines 30A/m, 50Hz

### Certified Product

E.U.T. **Power Meter**

Model: **PM130EH PLUS\***

Serial No.: **Not Designated**

\* See customer's declaration dated 18 April 2007 in ITL test report no. E72790.00.

This is to certify that the product specified herein has been tested and found compliant with the requirements noted above.

Signature:

D. Yadidi  
EMC Test Engineer

ITL091 Rev 1.6 26/06/05

Signature:

I. Raz  
EMC Laboratory Manager

**I.T.L. (Product Testing) Ltd.**  
HEAD OFFICES PRODUCT SAFETY LAB  
1 Batsheva St. P.O. B 87  
Latrun 51100 ISRAEL  
Tel: 972-8-9153100 Fax: 972-8-9153101

EMC LABORATORY  
Kfar Bin Nun 59780  
ISRAEL  
Tel: 972-8-9797799 Fax: 972-8-9797702

א.א.ט.א.ל בדיקת מוצאים (ב"מ)  
89780 ק.ב.נ. 59780  
טלפון: 972-8-9797702 פקס: 972-8-9797799  
טלפון: 972-8-9153101 פקס: 972-8-9153100



#### 4. Summary of Test Results

Test	Results
<b>Conducted Emissions</b> CISPR 22: 2005 Class A	The E.U.T met the performance requirements of the specification.  The margin between the emission levels and the specification limit was, in the worst case, 10.9 dB for the phase line at 0.51 MHz and 10.7 dB for the neutral line at 0.64 MHz.
<b>Radiated Emissions</b> CISPR 22: 2005 Class A	The E.U.T met the performance requirements of the specification.  The margin between the emission level and the specification limit was 6.4 dB in the worst case at the frequency of 182.20 MHz, vertical polarization.
<b>ESD</b> IEC 61000-4-2: 2001 Air Discharge, 8kV Contact Discharge, 4kV	The E.U.T met the performance requirements of the specification.
<b>Radiated Immunity</b> (80-1000 MHz) IEC 61000-4-3: 2006 10 V/m, 80% A.M. by 1kHz	The E.U.T met the performance requirements of the specification.
<b>EFT/B</b> IEC 61000-4-4: 2004 2kV Power lines, 1kV Signal lines	The E.U.T met the performance requirements of the specification.



## Summary of Test Results (cont'd.)

Test	Results
<b>Conductive Surges</b> IEC 61000-4-5: 2005 Differential mode; 1kV Signal lines, 2kV	The E.U.T met the performance requirements of the specification.
<b>Conducted Disturbances</b> (0.15-80 MHz) IEC 61000-4-6: 2006 10 VRMS, 80% A.M. by 1kHz	The E.U.T met the performance requirements of the specification.
<b>Immunity to Magnetic Field</b> IEC 61000-4-8: 2001 30 A/m, 50Hz	The E.U.T met the performance requirements of the specification.



מוניות לתקנים בינלאומיים בישראל

APPROVED TO ISO/IEC 17025

I.T.L (PRODUCT TESTING) Ltd.

HEAD OFFICE, SAFETY & TELECOMS LABS.

26 Hacharoshet St., POB 211

Or Yehuda 60251 ISRAEL

Tel. 972-3-5339022

Fax. 972-3-5339019

Email: [standard@itl.co.il](mailto:standard@itl.co.il), Web Site: <http://www.itl.co.il>

EMC LABORATORY

Kfar Bin Nun 99780

ISRAEL

Tel. 972-8-9797799

Fax. 972-8-9797702



TO: Satec Ltd.  
ATT: Dany Shacked  
FROM: Moshe Henig  
DATE: 22 July 2007

**Model: Power Meter PM130EH PLUS\***

Dear Danny

This is to confirm that the subject product has been submitted to us for engineering evaluation for STD: IEC 62052-11

The following test were performed:

1. Insulation Impulse Voltage.
2. 6kV surge 1.2/50 signals with - source impedance of 500 Ohm +/- 50 Ohm  
Impulse was applied 10 times one polarity and then repeated with the other polarity.
3. No failures were observed during the above test.

ITL is an independent test laboratory, certified to ISO/IEC 17025:1999, ISO9002 and EN45001.

International agencies and institutions that certified ITL include ISRAC, UL, MET, FCC, Industry Canada, A2LA, TUV, MedCert, and NATA.

\*Model PM130EH PLUS is Identical to PM130P PLUS See customer declaration.

*Moshe Henig*

Moshe Henig Dipl. Ing. SMIEEE NCE  
Senior Compliance Engineer

*E. Avital*

Elie Avital BSEE MBA  
Safety division Director



006174

सत्यमेव जयते

# CALIBRATION CERTIFICATE



भारत सरकार  
उपभोक्ता मामले, खाद्य एवं सार्वजनिक वितरण मंत्रालय  
Government Of India  
Ministry Of Consumer Affairs, Food and Public Distribution  
राष्ट्रीय परीक्षण शाला (पूर्वी क्षेत्र)

## National Test House

ब्लाक-सी.पी., सेक्टर-5, साल्ट लेक सिटी, कोलकाता-700 091

Block - CP, Sector - V, Salt Lake City, Kolkata - 700 091

Phone No : 91-33-2367-3429 / 3430 / 3431 / 3871 / 9741 / 3308 , Fax No : 91-33-2367- 3871 / 3308

email : nthsal@wb.nic.in



031295

भारत सरकार  
राष्ट्रीय परीक्षण शाला (पूर्वी क्षेत्र)  
National Test House (Eastern Region)  
ब्लाक-सी.पी., सेक्टर-5, साल्ट लेक सिटी, कोलकाता-700 091.  
Block - CP, Sector -V, Salt Lake City, Kolkata - 700 091.

FORM NO :NTH/SL/F/5



NABL ACCREDITED LABORATORY

006124

**CALIBRATION CERTIFICATE  
of THREE PHASE ENERGY METER**

**Certificate No.** NTH(ER)/CAL(EL)/2008/0017 **Date** 24.04.2008

**Page**

01

**No. of Pages**

02

M/s. M B Control & Systems Pvt. Ltd.,  
31/1, Ahrurpur Road,  
Kolkata - 700 019

MBCS/08-09/1701/055939  
Dated: 22.04.2008

Three Phase Energy Meter

Model: PM130EH PLUS

Make: SATEC

Serial No. 737363

22.04.2008

NTH/WATT/01 and on the lines of IEC 62053  
- 22 (2003)

Temperature: 25±1 deg C

Relative Humidity: 65 - 75%

Roktek Power/Energy Calibrator, USA.

NPL, New Delhi

NTH

NTH(ER)/CAL(EL)/2008/0017

**Party's Ref. No.****1. Description & Identification of EUC\*****2. EUC\* received on****3. Test Procedure followed****4. Environmental Conditions****5. Major Standards Used****6. Traceability of Measurement****7. Calibration Carried out at (NTH/On site)****8. NTH Identification Mark on the Label**

Calibrated by

V. Sivaguru

SA (Elect.)

Checked by

Avijit Das

Sc. SC (Elect.)

Approved by

Avijit Das

Sc. SC (Elect.)



031216

भारत सरकार

Government Of India

राष्ट्रीय परीक्षण शाला (पूर्वी क्षेत्र)

National Test House (Eastern Region)  
ब्लाक-सी.पी., सेक्टर-5, साल्ट लेक सिटी, कोलकाता-700 091.  
Block - CP, Sector -V, Salt Lake City, Kolkata - 700 091.

FORM NO :NTH/SL/F/5



006121

## CALIBRATION CERTIFICATE

## of THREE PHASE ENERGY METER

Certificate No. Date

NTH(ER)/CAL(EL)/2008/0017 24.04.2008

Date of Calibration

Page

No. of Pages

23.04.2008

02

02

## 9. Results of Test:

As desired the sample was subjected to accuracy test of energy, on the lines of IEC: 62053 – 22 (2003) and the results given below:

## Parameter: AC Power at 110V, 1A at 50Hz

Sl. No.	Specified Current	Power Factor	Value of Set Current	Error observed in %	Error limits as per IEC: 62053 – 22 (2003) in %	Expanded Uncertainty, k=2
1	0.01 $I_n \leq I \leq 0.05 I_n$	UPF	0.01 $I_n$	0.38	$\pm 0.4$	6.17E-03
2			0.045 $I_n$	0.35	$\pm 0.4$	6.80E-03
3	0.05 $I_n \leq I \leq I_{max}$	UPF	0.05 $I_n$	0.18	$\pm 0.2$	6.24E-03
4			$I_{max}$	0.16	$\pm 0.2$	1.47E-02
5		0.5Lag	0.02 $I_n$	0.44	$\pm 0.5$	1.02E-03
6	0.02 $I_n \leq I < 0.1 I_n$	0.8Lead	0.02 $I_n$	0.48	$\pm 0.5$	1.50E-03
7		0.5Lag	0.09 $I_n$	0.44	$\pm 0.5$	9.92E-04
8		0.8Lead	0.09 $I_n$	0.45	$\pm 0.5$	1.84E-03
9		0.5Lag	0.1 $I_n$	0.24	$\pm 0.3$	2.14E-03
10	0.1 $I_n \leq I \leq I_{max}$	0.8Lead	0.1 $I_n$	0.23	$\pm 0.3$	1.84E-03
11		0.5Lag	$I_{max}$	0.26	$\pm 0.3$	2.94E-03
12		0.8Lead	$I_{max}$	0.27	$\pm 0.3$	1.52E-02
13		0.25Lag	0.1 $I_n$	0.45	$\pm 0.5$	4.10E-03
14	0.1 $I_n \leq I \leq I_{max}$	0.5Lead	0.1 $I_n$	0.42	$\pm 0.5$	3.20E-03
15		0.25Lag	$I_{max}$	0.43	$\pm 0.5$	4.71E-02
16		0.5Lead	$I_{max}$	0.44	$\pm 0.5$	4.65E-02

EUC\* - Equipment Under Calibration

The meter complied to the requirements of Cl. 8.1 of IEC: 62053 - 22(2003) for accuracy - 0.2 S Class

10. Next calibration due on: 23.04.2009

Calibrated by  
V. Sivaguru  
SA (Elect.)Checked by  
Avijit Das  
Sc. SC (Elect.)Approved by  
Avijit Das  
Sc. SC (Elect.)

СИСТЕМА СЕРТИФИКАЦИИ ГОСТ Р  
ГОССТАНДАРТ РОССИИ



СЕРТИФИКАТ СООТВЕТСТВИЯ

№ РОСС IL.ME65.B01271

Срок действия с 14.09.2007 по 14.09.2010

6974599

ОРГАН ПО СЕРТИФИКАЦИИ РОСС. RU. 0001. 11МЕ65

Орган по сертификации средств измерений "Союз" АНО "Поток-Тест"  
(ОС "Союз")

119361, Москва, ул. Озерная, 46 тел.: (495) 437-29-22

ПРОДУКЦИЯ

Прибор для измерений показателей качества и учёта электрической  
энергии PM130P PLUS, PM130EH PLUS  
серийный выпуск

код ОК 005 (ОКП):

42 2860

СООТВЕТСТВУЕТ ТРЕБОВАНИЯМ НОРМАТИВНЫХ ДОКУМЕНТОВ

ГОСТ Р 52320 (МЭК 62052-11:2003)

код ТН ВЭД России:

9028301900

ИЗГОТОВИТЕЛЬ

SATEC Ltd, Израиль

Har Hotzvim Science Based Industrial Park P.O. Box 45022 Jerusalem 91450 Israel

СЕРТИФИКАТ ВЫДАН

SATEC Ltd, Израиль

Har Hotzvim Science Based Industrial Park P.O. Box 45022 Jerusalem 91450 Israel  
тел: +972-2-5411000, факс: +972-2-5812371

НА ОСНОВАНИИ

Протокол

№ 0526 от 07.09.2007

Испытательная лаборатория электропродукции  
ООО "ТЕСТЭП" Россия 249035 Обнинск  
Калужская обл. пр. Ленина, д. 127, офис 513

РОСС RU.0001.21MIO37

ДОПОЛНИТЕЛЬНАЯ ИНФОРМАЦИЯ

Маркирование продукции знаком соответствия производится по ГОСТ Р 50460-92



Руководитель органа

Эксперт

подпись  
Юрий  
подпись

В.Н.Яншин

индивидуалы, фамилия

О.В.Круг

индивидуалы, фамилия

Сертификат имеет юридическую силу на всей территории Российской Федерации

СИСТЕМА СЕРТИФИКАЦИИ ГОСТ Р  
ГОССТАНДАРТ РОССИИ



СЕРТИФИКАТ СООТВЕТСТВИЯ

№ РОСС IL.ME65.B01271

Срок действия с 14.09.2007 по 14.09.2010

6974599

ОРГАН ПО СЕРТИФИКАЦИИ РОСС. RU. 0001. 11МЕ65

Орган по сертификации средств измерений "Совет" АНО "Поток-Тест"  
(ОС "Совет")

119361, Москва, ул. Озерная, 46 тел.: (495) 437-29-22

ПРОДУКЦИЯ

Прибор для измерений показателей качества и учёта электрической  
энергии PM130P PLUS, PM130EH PLUS  
серийный выпуск

код ОК 005 (ОКП):

42 2860

СООТВЕТСТВУЕТ ТРЕБОВАНИЯМ НОРМАТИВНЫХ ДОКУМЕНТОВ

ГОСТ Р 52320 (МЭК 62052-11:2003)

код ТН ВЭД России:

9028301900

ИЗГОТОВИТЕЛЬ

SATEC Ltd, Израиль  
Har Hotzvim Science Based Industrial Park P.O. Box 45022 Jerusalem 91450 Israel

СЕРТИФИКАТ ВЫДАН

SATEC Ltd, Израиль  
Har Hotzvim Science Based Industrial Park P.O. Box 45022 Jerusalem 91450 Israel  
тел: +972-2-5411000, факс: +972-2-5812371

НА ОСНОВАНИИ

Протокол

№ 0526 от 07.09.2007

Испытательная лаборатория электропродукции

РОСС RU.0001.21MIO37

ООО "ТЕСТЭП" Россия 249035 Обнинск  
Калужская обл. пр. Ленина, д. 127, офис 513

ДОПОЛНИТЕЛЬНАЯ ИНФОРМАЦИЯ

Маркирование продукции знаком соответствия производится по ГОСТ Р 50460-92



Руководитель органа

подпись  
Ольга  
подпись

В.Н.Яншин

инициалы, фамилия

О.В.Круг

инициалы, фамилия

Сертификат имеет юридическую силу на всей территории Российской Федерации

## CE Declaration Of Conformity

# Declaration of Conformity

The Manufacturer of the Products covered by this Declaration is



**SATEC LTD.**  
*Har Hotzvim Industrial Park*  
POB 45022 Jerusalem 91450 ISRAEL

### The Directives covered by this Declaration

89/336/EEC Electromagnetic Compatibility directive, as amended  
73/23/EEC Low Voltage Equipment directive, amended by 93/68/EEC

### The Products Covered by this Declaration

PM130 PLUS series: **PM130P PLUS, PM130E PLUS, PM130EH PLUS**, all models with 3 power supplies options: **ACDC, 1DC and 23DC**

PM130 PLUS add-on modules: **4DI/2DO, 4AO, TOU, TOD, ETH, PROFIBUS**

### The Basis on which Conformity is being Declared

We hereby declare under our sole responsibility that the products identified above comply with the protection requirements of the EMC directive and with the principal elements of the safety objectives of the Low Voltage Equipment directive, and that the following standards have been applied:

#### Electromagnetic Immunity:

IEC 61000-6-2:

IEC 61000-4-2 level 3: Electrostatic Discharge  
IEC 61000-4-3 level 3: Radiated Electromagnetic RF Fields  
IEC 61000-4-4 level 3: Electric Fast Transient  
IEC 61000-4-5 level 3: Surge  
IEC 61000-4-6 level 3: Conducted Radio Frequency  
IEC 61000-4-8: Power Frequency Magnetic

#### Electromagnetic Emission:

IEC 61000-6-4: Radiated/Conducted class A

IEC CISPR 22: Radiated/Conducted class A

#### Safety:

IEC 61010-1

AC and Impulse insulation by IEC 62052

The technical documentation required to demonstrate that the products meet the requirements of the Low Voltage Equipment directive has been compiled and is available for inspection by the relevant enforcement authorities.

The CE mark was first applied in: *5/08/2007*

Signed: *Daniel Shaked*  
Authority: *R&D Projects Manager*  
Date: *29/07/2007*