



Federal state unitary enterprise  
"THE RUSSIAN RESEARCH INSTITUTE  
FOR METROLOGICAL SERVICE"

46, Ozernaya str., 119361,  
Moscow, Russia

Phone: +7 (495) 437 5577  
E-mail: Office@.vniims.ru

Fax: +7 (495) 437 5666  
<http://www.vniims.ru>

№ \_\_\_\_\_

## CERTIFICATE OF CONFORMITY

On the base of Certificate of Conformity №13.000.0494 dated 01.03.2013

***SATEC PM175 and EDL175XR Advanced Power Quality Analyzers*** comply with IEC 61000-4-30 standard as class A for paragraphs: 4.4, 4.6, 4.7, 5.1, 5.2, 5.4 and 5.5.

For details refer to document listed above and measurement results, applied to it.

\_\_\_\_\_  
Vladimir Yanshin,  
Deputy Director,

