

PM17X PLUS SERIES

Accuracy Statement

WE HEREBY STATE:

The PM17X PLUS – 1A (1A input current) Series accuracy complies accuracy class 0.2S for transformer-rated meter application only according to IEC 62053-22 standards, i.e. the accuracy performance is measured with a CT ratio of at least 10:1.

Date: November 9, 2015

Dany Shacked

VP R&d, SATEC LTD.

ISRAEL



אזור תעשייה הר חוצבים
רח' המרפא 7

ת"ד 45022 ירושלים 91450

טל' 02-5411000 פקס 02-5812371

www.satec.co.il

Har Hotzvim Industrial Park
7 Hamarpe St.

POB 45022 Jerusalem 91450 Israel

Tel. +972-2-5411000 Fax +972-2-5812371

satec@satec.co.il